

JI DETERMINATION REVIEW FORM

(version 02)						
(by submitting this form, a Party involved in a JI activity (through the DFP) or a JISC member request a review)						
Pa for		ved (DFP) / JISC member submi	itting the			
Reference number and title of the proposed JI activity:				0211 Utilization of coke gas with electricity generation by two 6 MWe CHP at "ZaporozhCox Plant"		
Ту	pe of JI	activity: X large scale	□ small so	ale 🗆 LULUCF	□ PoA/JPA	
Background						
1.	the CMP	e requirements of Article 6 of the Kyoto Protocol, the JI guidelines and further relevant requirements defined by CMP or the JISC with regard to determinations pursuant to paragraph 33 of the JI guidelines have to be met diappropriately dealt with by the accredited independent entity (AIE).				
2.	determin	Project participants shall submit to an AIE a JI PDD/PoA DD that contains all information needed for the determination of whether the proposed JI activity fulfills the conditions specified in the questions below, as provided in paragraph 31 of the JI guidelines.				
3.		AIE shall determine whether the proposed JI activity meets the conditions of paragraph 33 of the JI lelines, as specified in the questions below.				
4.	reasons,	e AIE shall make its determination publicly available through the secretariat, together with an explanation of its sons, including a summary of comments received and a report of how due account was taken of these, in cordance with paragraph 34 of the JI guidelines.				
5.	Where applicable, the AIE shall take into consideration paragraphs 26-39 of the procedures for programmes of activities under the verification procedure under the JISC (JI PoA procedures).					
Request for review						
Please respond to the questions presented below by marking the appropriate check box:						
Ye						
X	П	 Has the AIE determined appropriately that the proposed JI activity: has been approved by the Parties involved listed in the JI PDD/PoA DD? 				
		 has been approved by the Parties involved listed in the JI PDD/PoA DD? would result in a reduction of anthropogenic emissions by sources or an enhancer 				
	of anthropogenic removals by sinks that is additional to any that would otherwise				at would otherwise	
		 has an appropriate baseli in appendix B of the JI gu 		oring plan in accordance	e with the criteria set out	
 X □ ⇒ Has the AIE confirmed that the project participants have submitted analysis of the environmental impacts of the proposed JI activity, incl impacts, in accordance with procedures as determined by the host impacts are considered significant by the project participants or the undertaken an environmental impact assessment in accordance wirequired by the host Party? 				luding transboundary t Party, and, if those e host Party, have		
		➤ Has the AIE made its determination publicly available through the secretariat together with an explanation of its reasons, including a summary of the comments received and a report of how due account was taken on these?				
> Has the coordinating entity of the JI PoA included only JPA(s) that appear eligibility requirements defined in the JI PoA DD? (applicable to JI PoA of						
		 Has the AIE confirmed that the and the operational and mana have been established by the 	e eligibility cri	teria for inclusion of JP/	As have been fulfilled nentation of the JI PoA	
	Please describe in detail the reasons for requesting the review including the specific					

Please describe in detail the reasons for requesting the review, including the specific requirements in the JI guidelines that are not fulfilled, and attach supporting documentation, if appropriate.

- Regarding the crediting period, it is necessary to clarify of inconsistency between the PDD and Determination report.
- It is not clear that the project could not result in an overall increase in production of COG, and hence an increase in fossil fuel emissions, in order to increase steam generation and thereby electricity generation and ERU revenues from the new CHP units.
- The amount of COG delivered to Zaporozhstal should be monitored and compared with historical average deliveries to ensure that any decrease in externally delivered COG is not greater than that caused by the difference in steam input and output through the new units.