# FIFTH PERIODIC JI MONITORING REPORT

# Version 2.0 17 September 2010

## CONTENTS

- A. General project activity and monitoring information
- B. Key monitoring activities
- C. Quality assurance and quality control measures
- D. Calculation of GHG emission reductions

# SECTION A. General Project activity information

# A.1 Title of the project activity:

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine".

# A.2. JI registration number:

JI 0104

# A.3. Short description of the project activity:

The project activity consists of the energy efficiency measures at the premises of EMSS through the implementation of four subprojects:

**Subproject 1. Reconstruction of thermal and heating furnaces** – there are 35 thermal and heating furnaces in operation in different shops at the premises of EMSS. The main goal of this subproject is the reduction of the natural gas (NG) consumption for 26 of these furnaces by commissioning of new automated NG burners (which enables the required temperature inside of the furnace to be maintained) and by the implementation of new thermal insulation for the walls, front doors and roofs of the furnaces.

**Subproject 2. Installation of a new vacuum system** – The installation of a new vacuum system for the vacuumed steel production. The old vacuum system used heat and electricity, the new reconstructed vacuum system uses only electricity.

**Subproject 3. Installation of an arc ladle furnace** – The installation of a new arc ladle furnace for the steel production. This means that the part of the process of the steel preparation will be undertaken in the ladle, from which the steel will be cast into the forms. As a result there is reduction of the electricity consumption.

**Subproject 4. Modernization of press equipment** – The replacement of an old pump system, serving the 15,000 ton press, with a new more effective pump system. There are 24 old pumps (with 500 kW installed capacity each), which will be replaced by 11 new pumps (with 800 kW installed capacity each).

# A.4. Monitoring period:

- Monitoring period starting date: 01.04.2010 at 00:00;
- Monitoring period closing date: 30.06.2010 at 24:00.

# A.5. Methodology applied to the project activity (incl. version number):

**A.5.1. Baseline methodology:** The "Guidance on criteria for baseline setting and monitoring", issued by the Joint Implementation Supervisory Committee allows using approved methodologies of the CDM. The PDD, determined by an AIE, used a JI project specific approach to establish baseline scenario.

**A.5.2.** Monitoring methodology: A JI-specific monitoring approach was developed for this project in line with the "Guidance on criteria for baseline setting and monitoring". The resulting Monitoring Plan was determined as part of the determination process.

# A.6. Status of implementation including time table for major project parts:

Sub Project 1 implementation is behind schedule due to a lack of financing, detailed forecast and actual dates are shown in the table below:

| Activity   | Date of start up<br>according to PDD | Date of start up<br>actual |
|--|--------------------------------------|----------------------------|
| Subproject 1. Reconstruction of thermal and heating furnaces |                                      |                            |

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| Activity   | Date of start up<br>according to PDD | Date of start up<br>actual |
|--|--------------------------------------|----------------------------|
| Thermal #1, Thermal workshop                       | 2006                                 | 2006                       |
| Thermal #2, Thermal workshop                       | 2006                                 | 2006                       |
| Thermal #9, Thermal workshop                       | 2006                                 | 2006                       |
| Thermal #10, Thermal workshop                      | 2006                                 | 2006                       |
| Thermal #30, Forge Press workshop                  | April 2008                           | May 2008                   |
| Thermal #18, Forge Press workshop                  | July 2008                            | December 2008              |
| Heating #7, Forge Press Workshop                   | July 2008                            | October 2008               |
| Heating #8, Forge Press Workshop                   | 2007                                 | 2007                       |
| Heating #9, Forge Press Workshop                   | 2007                                 | 2007                       |
| Heating #10, Forge Press Workshop                  | 2007                                 | February 2008              |
| Thermal #19, Forge Press workshop                  | September 2008                       | February 2009              |
| Thermal #20, Forge Press workshop                  | October 2008                         | March 2009                 |
| Thermal #21, Forge Press workshop                  | October 2008                         | August 2009                |
| Thermal #32, Forge Press workshop                  | October 2008                         | July 2009                  |
| Heating #33, Forge Press workshop                  | October 2008                         | September 2009             |
| Thermal #37, Forge Press workshop                  | August 2009                          | September 2009             |
| Thermal #4, Thermal workshop                       | December 2008                        | 11 January 2010            |
| Heating #34, Forge Press workshop                  | December 2008                        | 1 January 2010             |
| Heating #35, Forge Press workshop                  | May 2009                             | 19 January 2010            |
| Heating #36, Forge Press workshop                  | August 2009                          | 1 March 2010               |
| Thermal #38, Forge Press workshop                  | August 2009                          | 1 May 2010                 |
| Subproject 2. Installation of a new vacuum system  | May 2007                             | February 2008              |
| Subproject 3. Installation of an arc ladle furnace | April 2007                           | April 2007                 |
| Subproject 4. Modernization of press equipment     | December 2007                        | August 2008                |

Table 1: Status of implementation (according to PDD)

The numbers of furnaces are correlated to the numbers in the original MSExcel sheet "ER calculation and Cash Flow Analysis English"<sup>1</sup>.

# A.7. Intended deviations or revisions to the determined PDD:

There are few deviations to the monitoring plan included in the determined PDD. Detailed descriptions of the deviations are given in the Monitoring Report 002 that has been finally verified (see <a href="http://ji.unfccc.int/JL\_Projects/DeterAndVerif/Verif/FinVerif.html">http://ji.unfccc.int/JL\_Projects/DeterAndVerif/Verif/FinVerif.html</a>). A revised monitoring plan has been submitted to the AIE during verification, which received a positive determination.

# A.8. Intended deviations or revisions to the determined monitoring plan:

<sup>&</sup>lt;sup>1</sup><u>http://ji.unfccc.int/JI\_Projects/DB/VY889VYDTR7YGFRYTY9TXLB4AWBLUR/Determination/Bureau%20Veritas%20Certification1246891334.73/viewDeterminationReport.html</u>

There are no deviations to the determined monitoring plan.

# A.9. Changes since last verification:

There is one furnace commissioned and put into the operation during second quarter of 2010. The number, type and location of the furnace are the following:

1. Thermal #38, Forge Press workshop;

In order to introduce automatic energy resources data acquisition system the following furnace have been equipped by certified logger-evaluators "Ergomera-126":

1. Heating #35, Forge Press workshop.

#### A.10. Person(s) responsible for the preparation and submission of the monitoring report:

OJSC "Energomashspetsstal"

• Alexander Masyuk, Deputy Chief Engineer

Global Carbon B.V.

- Lennard de Klerk, Director
- Oleg Bulany, Senior JI Consultant
- Anna Vilde, JI Consultant

# SECTION B. Key monitoring activities according to the monitoring plan for the monitoring period stated in A.4.

Key monitoring activities for each subproject could be described as follows.

**Subproject 1. Reconstruction of thermal and heating furnaces.** Each reconstructed furnace has a natural gas flow meter with pressure and temperature sensors in order to calculate normal cubic meters of natural gas burned in the furnace. Information from flow meters, pressure and temperature sensors are transmitting to the control and monitoring computer system where recalculation to the normal cubic meters taking place according to the approved standard.

All information about technological process is saved continuously. The archiving period for the log files is at least one year. Information that corresponds to the natural gas consumption in second quarter 2010 has been burned on CDs. These CDs are stored till the end of the crediting period plus two years.

Every half-finished product that processes through the furnaces has own unique certificate. This certificate reflects all operations performed on the product and the weight on the exit of every workshop. So, the weight of half-finished products that proceed through each furnace could be easily monitored. Information from the certificates is saved in the log books in order to simplify the monitoring process.

A report including natural gas consumption and weight of half finished products is generating on a monthly basis. The report is signing by Head of Energy Saving Department, Head of corresponding workshop and approved by Chief Engineer.

The natural gas meters (flow, pressure, temperature) are used in furnaces' control process. That is why any deviation/failure of the meters would be recognized immediately by disturbance of the heating process and reported to the workshop's head. As a result of disturbance furnace should be shut down fore the checking procedure.

The flowcharts of the natural gas supplying system with the metering points are presented in the following figures.



Figure 1. Natural gas metering system at the thermal workshop (TS)

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"



# Subproject 2. Installation of a new vacuum system.

Electricity that is consumed during the vacuum process is metered using dedicated meters for this system. Information from meters is passed to the control and monitoring computer system of the vacuumator. A computer system records information about every vacuumization session, including melt passport, time and electricity consumption. The archiving period for the log files is at least one year. Information that corresponds to the electricity consumption in the second quarter 2010 has been burned on CDs. These CDs are stored till the end of the crediting period plus two years.

page 7

Correctness of the meters' work is checking by the following formulae:

 $\sum$ (meter5 + meter6) -  $\sum$ (meter1 + meter2 + meter3 + meter4 + other consumers)  $\leq 1.5\%$ 

In the case of a difference of more than 1.5%, a verification of meters is performed, if found defective, the meter is substituted within one day.

The steel to the vacuum degasser (VD) coming either from ladle furnace (LF) or from the electric arc furnace (EAF) in special ladle. Each ladle with liquid steel has unique certificate of melt. The following figure presents the electricity supplying system to the VD with metering points.



Figure 3. Electricity metering system at VD

#### Subproject 3. Installation of an arc ladle furnace.

LF is a comprehensive solution for high quality steel melting has been installed in the Steel Making Workshop (SMW). The main electricity consumers of the SMW are powered by the following scheme.

page 9

Close Distribution Unit (CDU) #1, 2 are electricity powering points for the EAFs (EAF50 #1, EAF100 #3, EAF100 #5 and EAF12) and LF. CDUs are powered by Transformers (T1, and T2) and Autotransformers (AT1 and AT2). EAFs and LF could be powered from any of the Transformers or Autotransformers. Commercial electricity meters are installed on each of the Transformers and Autotransformer. Cross-checking of the meters is performed by the following formulae:

 $\sum(AT1+AT2+T1+T2) - \sum(EAF50 \#1 + EAF100 \#3 + EAF100 \#5 + EAF12+LF) \le 1.5\%$ In the case of a difference of more than 1.5%, a verification of meters is performed, if found defective, the meter is substituted within one day.

The data from electricity meters concerning electricity consumption is transmitted to the control and monitoring computer system continuously. The computer system records information about each melt process, including melt certificate. This certificate includes information about the number of EAF where steel was melted, steel content, amount of electricity consumed during melting and weight of steel. The archiving period for the log files is at least one year. All melt certificates for the second quarter of the year 2010 have been burned to CDs. These CDs are stored until the end of the crediting period plus two years.

The following figure presents electricity supplying system with metering points.



Figure 4. Electricity metering system at EAFs and LF

# Subproject 4. Modernization of press equipment.

Serving motors of the press pump station are powered from the 6kV line. Substation 110/6 kV has two transformers. Each transformer has a commercial electricity meter. There are some addition consumers on the 6kV line. The performance of the meters is checked using the following formulae:

 $\Sigma$ (Tp1+Tp2) -  $\Sigma$ (Consumers+Pump Station)  $\leq 1.5\%$ 

If the difference is more than 1.5%, verification of meters is performed. Defective meters being substituted within one day.

All data concerning electricity consumption is transmitted to the control and monitoring computer system. The press has a special registry log book, where working time of press is logged, among other data. The following figure presents electricity supplying system of the press with metering points.

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"



Figure 5. Electricity metering system at press

The control and monitoring system can be divided into an electrical part, a gas part, and steel weight part.

#### **Electrical measurements**

For the purpose of monitoring the emission reductions the following parameters are measured:

- Electricity consumption at EAFs;
- Electricity consumption at LF;
- Electricity consumption at VD;
- Electricity consumption at press' pump station.

# Natural gas measurements

For the purpose of monitoring the emission reductions the following parameters are measured:

• Natural gas consumption, temperature and pressure at 21 reconstructed heating and thermal furnaces.

# Steel weight measurement

For the purpose of monitoring the emission reductions the following parameters are measured:

- Weight of steel proceeded through the LF;
- Weight of steel proceeded through the VD;
- Weight of half-finished products proceeded through reconstructed heating and thermal furnaces.

# **B.1.** Monitoring equipment types

- 1. Electricity meters "Energia -9"
- 2. Electricity meters "SA ZU-I670M"
- 3. Electricity meters "EuroAlfha"
- 4. Natural gas flow meters "IRVIS K 300"
- 5. Natural gas flow meter "Kromeschroder"
- 6. Natural gas flow meter "ABB"
- 7. Natural gas flow meter "Ergomera-126"
- 8. Natural gas flow meter "Metran 100DD"
- 9. Natural gas temperature meters "TSMU 274-05"
- 10. Natural gas temperature meters "TSPU 205"
- 11. Natural gas temperature meters "TSMT -103 "
- 12. Natural gas pressure meters "Metran 100 DI"
- 13. Natural gas pressure meter "Metran 55Ex Da"
- 14. Natural gas pressure meters "Metran 100 DA"
- 15. Logger-evaluators "Ergomera-126"
- 16. Weighing machine "ErMack-Vk1rk-10"

- Weighing machine "ErMack-Vk1rk-20"
   Weighing machine "ErMack-Vk1rk-50"
   Weighing machine "ErMack-Vk1rk-80"
   Weighing machine "02VPT-200MC"

# **B.1.2.** Table providing information on the equipment used (incl. manufacturer, type, serial number, date of installation, date of last calibration, information to specific uncertainty, need for changes and replacements):

The control and monitoring system can be divided into an electrical part, a natural gas part and a steel weight part.

### **Electrical measurements**

For the purpose of monitoring the emission reductions the following parameters are measured:

- Electricity consumption at EAFs;
- Electricity consumption at LF;
- Electricity consumption at VD;
- Electricity consumption at press' pump station.

| ID of the meter | Measuring<br>parameter                            | Work parameter | Type        | Serial<br>number | Level of accuracy | Date<br>of installation | Electricity<br>consumed<br>1.04.2010-<br>30.06.2010 | Date of<br>last calibration | Date of next<br>calibration. |
|-----------------|---|----------------|-------------|------------------|-------------------|-------------------------|---|-----------------------------|------------------------------|
| EL1             | Electricity consumption at EAF50                  | MWh            | Energia 9   | 40688            | 0.2%              | 2009                    | 231.274   | 01.07.2007                  | 01.07.2013                   |
| EL2             | Electricity consumption at EAF100 #3 <sup>2</sup> | kWh            | SA ZU-I670M | 798599           | 2%                | 2003                    | 94.023  | 14.01.2008                  | 14.01.2012                   |
| EL3             | Electricity consumption at EAF100 #5              | kWh            | Energia 9   | 43898            | 0.2%              | 10.08.2008              | 182.074   | 31.01.2008                  | 30.01.2014                   |
| EL4             | Electricity consumption at LF <sup>3</sup>        | kWh            | EuroAlfha   | 1132201          | 0.5%              | 2007                    | 0   | 25.09.2006                  | 25.09.2012                   |
| EL5             | Electricity consumption at VD                     | kWh            | Energia 9   | 44701            | 0.2%              | 2008                    | 269.811   | 28.02.2008                  | 28.02.2014                   |
| EL6             | Electricity consumption at VD                     | kWh            | Energia 9   | 44702            | 0.2%              | 2008                    | 0.032   | 28.02.2008                  | 28.02.2014                   |
| EL7             | Electricity consumption at VD                     | kWh            | Energia 9   | 44705            | 0.2%              | 2008                    | 195.189   | 28.02.2008                  | 28.02.2014                   |
| EL8             | Electricity consumption at VD                     | kWh            | Energia 9   | 44706            | 0.2%              | 2008                    | 0.079   | 28.02.2008                  | 28.02.2014                   |
| EL9             | Electricity consumption at press                  | kWh            | Energia 9   | 40680            | 0.2%              | 26.08.2008              | 34.621  | 09.2006                     | 09.2012                      |

<sup>&</sup>lt;sup>2</sup> For more details see Section B.4 "Special Event Log"

<sup>&</sup>lt;sup>3</sup> For more details see Section B.4 "Special Event Log"

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| ID of the meter | Measuring<br>parameter | Work parameter | Type | Serial<br>number | Level of accuracy | Date<br>of installation | Electricity<br>consumed<br>1.04.2010-<br>30.06.2010 | Date of<br>last calibration | Date of next<br>calibration. |
|-----------------|------------------------|----------------|------|------------------|-------------------|-------------------------|---|-----------------------------|------------------------------|
|                 |                        |                |      |                  |                   |                         |   |                             |                              |

Table 2: List of electric meters

Electric current provided to the EAFs and LF have so high parameters (more then 5A), that they cannot be measured directly. The current parameters decreased through the transformers and measured. The following table presents list of transformers using in the electric current measuring.

| ID of       | Transforming         | Work      | Туре     | Serial     | Level of | Transformation | Date of     | Date of     |
|-------------|----------------------|-----------|----------|------------|----------|----------------|-------------|-------------|
| transformer | parameter            | parameter |          | number     | accuracy | factor         | last        | next        |
|             |                      |           |          |            |          |                | calibration | calibration |
| TR1         | Current at EAF50     | А         | TPOL-35  | 11         | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR2         | Current at EAF50     | А         | TPOL-35  | 37         | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR3         | Voltage at EAF50     | V         | ZNOM-35  | 1138121    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR4         | Voltage at EAF50     | V         | ZNOM-35  | 1138211    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR5         | Voltage at EAF50     | V         | ZNOM-35  | 1120877    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR6         | Current at EAF100 #3 | А         | TPOL-35  | 113        | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR7         | Current at EAF100 #3 | А         | TPOL-35  | 13         | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR8         | Voltage at EAF100 #3 | V         | ZNOM-35  | 854859     | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR9         | Voltage at EAF100 #3 | V         | ZNOM-35  | 854965     | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR10        | Voltage at EAF100 #3 | V         | ZNOM-35  | 849517     | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR11        | Current at EAF100 #5 | А         | TPOL-35  | 351        | 0.5%     | 1000/5         | 13.05.2009  | 13.05.2013  |
| TR12        | Current at EAF100 #5 | А         | TPOL-35  | 458        | 0.5%     | 1000/5         | 13.05.2009  | 13.05.2013  |
| TR13        | Voltage at EAF100 #5 | V         | ZNOM-35  | 1284276    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR14        | Voltage at EAF100 #5 | V         | ZNOM-35  | 1355405    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR15        | Voltage at EAF100 #5 | V         | ZNOM-35  | 1213200    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR16        | Current at LF        | А         | TPU 7051 | 5105040894 | 0.5%     | 500/5          | 13.05.2009  | 13.05.2013  |
| TR17        | Current at LF        | А         | TPU 7051 | 5105040895 | 0.5%     | 500/5          | 13.05.2009  | 13.05.2013  |
| TR18        | Current at LF        | А         | TPU 7051 | 5105040896 | 0.5%     | 500/5          | 13.05.2009  | 13.05.2013  |
| TR19        | Voltage at LF        | V         | ZNOM-35  | 1168572    | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |

page 13

| ID of       | Transforming     | Work      | Туре     | Serial  | Level of | Transformation | Date of     | Date of     |
|-------------|------------------|-----------|----------|---------|----------|----------------|-------------|-------------|
| transformer | parameter        | parameter |          | number  | accuracy | factor         | last        | next        |
|             |                  |           |          |         |          |                | calibration | calibration |
| TR20        | Voltage at LF    | V         | ZNOM-35  | 1427592 | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR21        | Voltage at LF    | V         | ZNOM-35  | 1279988 | 0.5%     | 35000/100      | 13.05.2009  | 13.05.2013  |
| TR22        | Current at VD    | А         | T-0.66-1 | 21387   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR23        | Current at VD    | А         | T-0.66-1 | 19132   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR24        | Current at VD    | А         | T-0.66-1 | 21526   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR25        | Current at VD    | А         | T-0.66-1 | 83614   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR26        | Current at VD    | А         | T-0.66-1 | 21837   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR27        | Current at VD    | А         | T-0.66-1 | 19100   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR28        | Current at VD    | А         | T-0.66-1 | 19687   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR29        | Current at VD    | А         | T-0.66-1 | 21888   | 0.5%     | 600/5          | 13.05.2009  | 13.05.2013  |
| TR30        | Current at press | A         | TLK-10   | 3051    | 0.5%     | 1500/5         | 13.05.2009  | 13.05.2013  |
| TR31        | Current at press | A         | TLK-10   | 3102    | 0.5%     | 6000/100       | 13.05.2009  | 13.05.2013  |

Table 3: List of transformers

# Natural gas measurements

For the purpose of monitoring the emission reductions the following parameters are measured:

• Natural gas consumption at 21 reconstructed heating and thermal furnace.

| ID of meter | Measuring<br>parameter                            | Work<br>parameter | Type                            | Serial<br>number | Level of<br>accuracy | Date<br>of installation | NG consumed<br>1.04.2010-<br>30.06.2010 | Date of<br>last<br>calibration | Date of<br>next<br>calibration |
|-------------|---|-------------------|---------------------------------|------------------|----------------------|-------------------------|---|--------------------------------|--------------------------------|
| NG1         | Consumption of the NG at thermal furnace #1, TS   | m <sup>3</sup>    | IRVIS - K - 300                 | 5274             | 1%                   | 01.2007                 | 249932                                  | 02.03.2010                     | 02.03.2012                     |
| NG2         | Consumption of the NG at thermal furnace #2, TS   | m <sup>3</sup>    | IRVIS - K - 300                 | 5275             | 1%                   | 01.2007                 | 180366                                  | 03.03.2010                     | 03.03.2012                     |
| NG3         | Consumption of the NG at thermal furnace #9, TS   | m <sup>3</sup>    | IRVIS - K - 300                 | 5182             | 1%                   | 01.2006                 | 114682                                  | 04.03.2010                     | 04.03.2012                     |
| NG4         | Consumption of the NG at thermal furnace #10, TS  | m <sup>3</sup>    | IRVIS - K - 300                 | 5183             | 1%                   | 01.2006                 | 114925                                  | 02.03.2010                     | 02.03.2012                     |
| NG5         | Consumption of the NG at heating furnace #7, FPS  | m <sup>3</sup>    | IRVIS - K - 300                 | 5740             | 1%                   | 10.2008                 | 614289                                  | 03.02.2010                     | 03.02.2012                     |
| NG6         | Consumption of the NG at heating furnace #8, FPS  | m <sup>3</sup>    | IRVIS - K - 300                 | 5480             | 1%                   | 12.2007                 | 370705                                  | 20.02.2009                     | 20.02.2011                     |
| NG7         | Consumption of the NG at heating furnace #9, FPS  | m <sup>3</sup>    | IRVIS - K - 300                 | 5482             | 1%                   | 12.2007                 | 388105                                  | 20.02.2009                     | 20.02.2011                     |
| NG8         | Consumption of the NG at heating furnace #10, FPS | m <sup>3</sup>    | IRVIS - K - 300                 | 5483             | 1%                   | 12.2007                 | 421741                                  | 20.02.2009                     | 20.02.2011                     |
| NG9         | Consumption of the NG at thermal furnace #30, FPS | m <sup>3</sup>    | IRVIS - K - 300                 | 5711             | 1%                   | 05.2007                 | 280458                                  | 16.10.2009                     | 16.10.2010                     |
| NG10        | Consumption of the NG at thermal furnace #18, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 98107            | 1.5%                 | 03.2008                 | 155910                                  | 23.03.2010                     | 23.03.2012                     |
| NG11        | Consumption of the NG at thermal furnace #19, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 69191748         | 1.5%                 | 05.2009                 | 201774                                  | 08.05.2009                     | 08.05.2011                     |
| NG12        | Consumption of the NG at thermal furnace #20, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 69193831         | 1.5%                 | 05.2009                 | 246609                                  | 08.05.2009                     | 08.05.2011                     |
| NG13        | Consumption of the NG at thermal furnace #21, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 69193830         | 1%                   | 09.2009                 | 161621                                  | 15.07.2009                     | 15.07.2011                     |

| ID of meter | Measuring<br>parameter                            | Work<br>parameter | Type                            | Serial<br>number | Level of<br>accuracy | Date<br>of installation | NG consumed<br>1.04.2010-<br>30.06.2010 | Date of<br>last<br>calibration | Date of<br>next<br>calibration |
|-------------|---|-------------------|---------------------------------|------------------|----------------------|-------------------------|---|--------------------------------|--------------------------------|
| NG14        | Consumption of the NG at thermal furnace #32, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 69191749         | 1%                   | 09.2009                 | 173370                                  | 15.07.2009                     | 15.07.2011                     |
| NG15        | Consumption of the NG at heating furnace #33, FPS | Nm <sup>3</sup>   | ABB FMT500-IG                   | 28751947         | 1%                   | 08.2009                 | 100578                                  | 12.08.2009                     | 12.08.2011                     |
| NG16        | Consumption of the NG at thermal furnace #37, FPS | m <sup>3</sup>    | Kromeschroder<br>DM 650 Z150-40 | 69196330         | 1 %                  | 09.2009                 | 51862                                   | 29.04.2010                     | 29.04.2012                     |
| NG17        | Consumption of the NG at thermal furnace #4, TS   | m <sup>3</sup>    | Kromeschroder<br>DM 650 Z150-40 | 10512270         | 1 %                  | 11.2009                 | 174061                                  | 04.09.2008                     | 04.09.2010                     |
| NG18        | Consumption of the NG at heating furnace #34, FPS | Nm <sup>3</sup>   | ABB FMT500-IG                   | 28751945         | 1%                   | 01.2009                 | 158048                                  | 21.08.2009                     | 21.08.2011                     |
| NG19        | Consumption of the NG at heating furnace #35, FPS | Nm <sup>3</sup>   | ABB FMT500-IG                   | 28751946         | 1%                   | 01.2009                 | 182490                                  | 21.08.2009                     | 21.08.2011                     |
| NG20        | Consumption of the NG at heating furnace #35, FPS | $m^3$             | Metran 100DD                    | 459415           | 0.5%                 | $06.2010^4$             | 5285                                    | 29.04.2010                     | 29.04.2011                     |
| NG21        | Consumption of the NG at heating furnace #36, FPS | m <sup>3</sup>    | Metran 100DD                    | 462213           | 0.5%                 | 01.2010                 | 165680                                  | 12.10.2009                     | 12.10.2010                     |
| NG22        | Consumption of the NG at thermal furnace #38, FPS | m <sup>3</sup>    | Kromeschroder DM<br>650 Z150-40 | 69199960         | 1 %                  | 06.2010                 | 30968                                   | 04.09.2008                     | 04.09.2010                     |

Table 4: List of natural gas meters

Natural gas meters measuring gas flow in the m<sup>3</sup>. To convert measuring value to Nm<sup>3</sup>, temperature and pressure meters are used. The following tables present temperature and pressure meters.

| ID of meter | Measuring<br>parameter | Work<br>parameter | Type | Serial<br>number | Level of<br>accuracy | Date<br>of installation | Date of<br>last calibration | Date of<br>next<br>calibration |
|-------------|------------------------|-------------------|------|------------------|----------------------|-------------------------|-----------------------------|--------------------------------|
|-------------|------------------------|-------------------|------|------------------|----------------------|-------------------------|-----------------------------|--------------------------------|

<sup>&</sup>lt;sup>4</sup> Meter has been installed in June 2010 in order to introduce common system of energy resources control. Documents provided to AIE.

page 16

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| TP1  | Temperature of the NG at thermal furnace #1, TS   | C° | TSMU 274-05   | 655358  | 0.5%   | 09.2008 | 16.09.2009 | 16.09.2010 |
|------|---|----|---------------|---------|--------|---------|------------|------------|
| TP2  | Temperature of the NG at thermal furnace #2, TS   | C° | TSMU 274-05   | 655355  | 0.5%   | 09.2008 | 16.09.2009 | 16.09.2010 |
| TP3  | Temperature of the NG at thermal furnace #9, TS   | C° | TSMU 274-05   | 655359  | 0.5%   | 09.2008 | 14.07.2009 | 14.07.2010 |
| TP4  | Temperature of the NG at thermal furnace #10, TS  | C° | TSMU 274-05   | 655363  | 0.5%   | 09.2008 | 14.07.2009 | 14.07.2010 |
| TP5  | Temperature of the NG at heating furnace #7, FPS  | C° | TSMU 274-05   | 655354  | 0.5%   | 09.2008 | 14.07.2009 | 14.07.2010 |
| TP6  | Temperature of the NG at heating furnace #8, FPS  | C° | TSMU 274-05   | 655362  | 0.5%   | 09.2008 | 14.07.2009 | 14.07.2010 |
| TP7  | Temperature of the NG at heating furnace #9, FPS  | C° | TSPU - 205    | 8360    | 0.008t | 09.2008 | 23.09.2009 | 23.09.2010 |
| TP8  | Temperature of the NG at heating furnace #10, FPS | C° | TSPU - 205    | 8362    | 0.008t | 09.2008 | 23.09.2009 | 23.09.2010 |
| TP9  | Temperature of the NG at thermal furnace #30, FPS | C° | TSPU - 205    | 8365    | 0.008t | 09.2008 | 22.09.2009 | 22.09.2010 |
| TP10 | Temperature of the NG at thermal furnace #18, FPS | C° | TCMU - 274-05 | 655360  | 0.008t | 07.2008 | 14.07.2009 | 14.07.2010 |
| TP11 | Temperature of the NG at thermal furnace #19, FPS | C° | TCMU - 205    | 6000    | 0.008t | 05.2009 | 12.05.2009 | 12.05.2010 |
| TP12 | Temperature of the NG at thermal furnace #20, FPS | C° | TCMU - 205    | 6011    | 0.008t | 05.2009 | 12.05.2009 | 12.05.2010 |
| TP13 | Temperature of the NG at thermal furnace #21, FPS | C° | TSPU - 205    | 655361  | 0.008t | 09.2009 | 17.09.2009 | 17.09.2010 |
| TP14 | Temperature of the NG at thermal furnace #32, FPS | C° | TCMU - 274    | 655356  | 0.008t | 09.2009 | 09.07.2009 | 09.07.2010 |
| TP15 | Temperature of the NG at thermal furnace #37, FPS | C° | TCMU - 274    | 750917  | 0.008t | 09.2009 | 21.07.2009 | 21.07.2010 |
| TP16 | Temperature of the NG at thermal furnace #4, TS   | C° | TCMU - 274-05 | 750977  | 0.25%  | 11.2009 | 21.07.2009 | 21.07.2010 |
| TP17 | Temperature of the NG at heating furnace #36, FPS | C° | TCMT - 103    | 195.447 | 0.25%  | 02.2010 | 16.02.2010 | 16.02.2011 |
| TP18 | Temperature of the NG at thermal furnace #38, FPS | C° | TCMT - 103    | 195.435 | 0.25%  | 06.2010 | 16.02.2010 | 16.02.2011 |
| TP19 | Temperature of the NG at thermal furnace #35, FPS | C° | TCMT - 103    | 195.443 | 0.25%  | 02.2010 | 16.02.2010 | 16.02.2011 |

Table 5: List of temperature meters

page 17

| ID of meter | Measuring<br>parameter                         | Work<br>parameter | Type            | Serial<br>number | Level of accuracy | Date<br>of installation | Date of<br>last calibration | Date of<br>next<br>calibration |
|-------------|--|-------------------|-----------------|------------------|-------------------|-------------------------|-----------------------------|--------------------------------|
| PR1         | Pressure of the NG at thermal furnace #1, TS   | kPa               | Metran 100 DI   | 274538           | 0.5%              | 01.2007                 | 30.11.2009                  | 30.11.2010                     |
| PR2         | Pressure of the NG at thermal furnace #2, TS   | kPa               | Metran 100 DI   | 275890           | 0.5%              | 01.2007                 | 3.12.2009                   | 3.12.2010                      |
| PR3         | Pressure of the NG at thermal furnace #9, TS   | kPa               | Metran 100 DI   | 241764           | 0.5%              | 01.2006                 | 17.05.2010                  | 17.05.2011                     |
| PR4         | Pressure of the NG at thermal furnace #10, TS  | kPa               | Metran 100 DI   | 241763           | 0.5%              | 01.2006                 | 01.09.2009                  | 01.09.2010                     |
| PR5         | Pressure of the NG at heating furnace #7, FPS  | kPa               | Metran 100 DI   | 422353           | 0.5%              | 10.2008                 | 31.08.2009                  | 31.08.2010                     |
| PR6         | Pressure of the NG at heating furnace #8, FPS  | kPa               | Metran 100 DI   | 376707           | 0.5%              | 12.2007                 | 04.03.2010                  | 04.03.2011                     |
| PR7         | Pressure of the NG at heating furnace #9, FPS  | kPa               | Metran 100 DI   | 000088           | 0.5%              | 12.2007                 | 23.03.2010                  | 23.03.2011                     |
| PR8         | Pressure of the NG at heating furnace #10, FPS | kPa               | Metran 100 DI   | 000087           | 0.5%              | 12.2007                 | 04.02.2010                  | 04.02.2011                     |
| PR9         | Pressure of the NG at thermal furnace #30, FPS | kPa               | Metran 100 DI   | 387352           | 0.5%              | 05.2007                 | 16.02.2010                  | 16.02.2011                     |
| PR10        | Pressure of the NG at thermal furnace #18, FPS | kPa               | Metran 55 Ex DA | 461211           | 0.25%             | 05.2008                 | 13.05.2010                  | 13.05.2011                     |
| PR11        | Pressure of the NG at thermal furnace #19, FPS | kPa               | Metran 55 Ex DA | 486509           | 0.25%             | 05.2009                 | 13.05.2010                  | 13.05.2011                     |
| PR12        | Pressure of the NG at thermal furnace #20, FPS | kPa               | Metran 55 Ex DA | 486786           | 0.25%             | 05.2009                 | 14.05.2010                  | 14.05.2011                     |
| PR13        | Pressure of the NG at thermal furnace #21, FPS | kPa               | Metran 55 DA    | 458976           | 0.5%              | 09.2009                 | 14.05.2010                  | 14.05.2011                     |
| PR14        | Pressure of the NG at thermal furnace #32, FPS | kPa               | Metran 55 DA    | 486510           | 0.5%              | 09.2009                 | 14.05.2010                  | 14.05.2011                     |
| PR15        | Pressure of the NG at thermal furnace #37, FPS | kPa               | Metran 55 Ex DA | 461217           | 0.25%             | 09.2009                 | 24.07.2009                  | 24.07.2010                     |
| PR16        | Pressure of the NG at thermal furnace #4, TS   | kPa               | Metran 100 DA   | 340571           | 0.5%              | 11.2009                 | 22.01.2010                  | 22.01.2011                     |
| PR17        | Pressure of the NG at heating furnace #36, FPS | kPa               | Metran 100 DA   | 442214           | 0.5%              | 01.2010                 | 13.10.2009                  | 13.10.2010                     |
| PR18        | Pressure of the NG at thermal furnace #38, FPS | kPa               | Metran 55 DA    | 458977           | 0.5%              | 06.2010                 | 26.10.2009                  | 26.10.2010                     |
| PR19        | Pressure of the NG at heating furnace #35, FPS | kPa               | Metran 100 DA   | 442216           | 0.5%              | 01.2010                 | 20.10.2009                  | 13.10.2010                     |

Table 6: List of pressure meters

#### **Steel weight measurement**

For the purpose of monitoring the emission reductions the following parameters are measured:

- Weight of steel proceeded in the Electro Steel Melting Workshop;
- Weight of half-finished products proceeded through reconstructed heating and thermal furnaces.

.

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| ID of weighing<br>machine | Measuring<br>parameter                  | Work<br>parameter | Type            | Serial<br>number | level of accuracy | Date<br>of installation | Date of<br>last calibration | Date of<br>next calibration |
|---------------------------|---|-------------------|-----------------|------------------|-------------------|-------------------------|-----------------------------|-----------------------------|
| WM1                       | Weight of half-finished products of FPS | t                 | ErMack-Vk1rk-10 | 0115047          | 6kg               | 2005                    | 01.07.2010                  | 01.07.2011                  |
| WM2                       | Weight of half-finished products of TS  | t                 | ErMack-Vk1rk-20 | 205122           | 15kg              | 2005                    | 19.03.2010                  | 19.03.2011                  |
| WM3                       | Weight of half-finished products of TS  | t                 | ErMack-Vk1rk-50 | 506149           | 60kg              | 2006                    | 03.06.2009                  | 03.06.2010                  |
| WM4                       | Weight of half-finished products of FPS | t                 | ErMack-Vk1rk-80 | 806148           | 150kg             | 2006                    | 03.06.2010                  | 03.06.2011                  |
| WM5                       | Weight of steel melted at LF            | t                 | 01VKT-200M      | 222              | 2kg               | 2007                    | 16.11.2009                  | 16.11.2010                  |

Table 7: List of weighting machines

The following table presents list of logger-evaluators.

| ID of meter | Measuring<br>parameter                                    | Work<br>parameter | Type         | Serial<br>number | Level of accuracy | Date<br>of installation | Date of<br>last calibration | Date of<br>next<br>calibration |
|-------------|---|-------------------|--------------|------------------|-------------------|-------------------------|-----------------------------|--------------------------------|
| LE1         | Logging of NG consumption at thermal furnace #4, TS       | Nm <sup>3</sup>   | Ergomera-126 | 838              | 0.1%              | 01.2010                 | 13.08.2009                  | 13.08.2011                     |
| LE2         | Logging of NG consumption at heating furnace #35, 36, FPS | Nm <sup>3</sup>   | Ergomera-126 | 836              | 0.1%              | 01.2010                 | 13.08.2009                  | 13.08.2011                     |
| LE3         | Logging of NG consumption at thermal furnace #37, FPS     | Nm <sup>3</sup>   | Ergomera-126 | 800              | 0.1%              | 01.2010                 | 13.08.2009                  | 13.08.2011                     |
| LE4         | Logging of NG consumption at thermal furnace #38, FPS     | Nm <sup>3</sup>   | Ergomera-126 | 834              | 0.1%              | 06.2010                 | 13.08.2009                  | 13.08.2011                     |

# **B.1.3.** Calibration procedures

For Electricity Meters:

| QA/QC procedures | Body responsible for calibration and certification |
|------------------|--|
|                  |  |

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| Calibration interval of such meters is 4 years for the meters produced before 01.01.1988 and | Ukrainian Centre for Standardization and Metrology |
|--|--|
| 6 years for the meters produced after 01.01.1988.  |  |

For Natural Gas Meters

| QA/QC procedures                                | Body responsible for calibration and certification |
|---|--|
| Calibration interval of such meters is 2 years. | Ukrainian Centre for Standardization and Metrology |

#### For temperature meters

| QA/QC procedures                               | Body responsible for calibration and certification |
|--|--|
| Calibration interval of such meters is 1 year. | Ukrainian Centre for Standardization and Metrology |

### For pressure meters

| QA/QC procedures                               | Body responsible for calibration and certification |
|--|--|
| Calibration interval of such meters is 1 year. | Ukrainian Centre for Standardization and Metrology |

For weighting machines:

| QA/QC procedures                               | Body responsible for calibration and certification |
|--|--|
| Calibration interval of such meters is 1 year. | Ukrainian Centre for Standardization and Metrology |

For transformers:

| QA/QC procedures                                | Body responsible for calibration and certification |
|---|--|
| Calibration interval of such meters is 4 years. | Ukrainian Centre for Standardization and Metrology |

For loggers-evaluators:

| <u> </u>         |  |
|------------------|--|
| QA/QC procedures | Body responsible for calibration and certification |
|                  |  |

page 20

"Improvement of the Energy efficiency at Energomashspetsstal (EMSS), Kramatorsk, Ukraine"

| Calibration interval of such meters is 2 years. | Ukrainian Centre for Standardization and Metrology |
|---|--|
|---|--|

### **B.1.4.** Involvement of Third Parties:

Ukrainian Centre for Standardization and Metrology.

## **B.2.** Data collection (accumulated data for the whole monitoring period):

The operational and management structure of the project see PDD, Flowchart D.3.1: Responsibilities within the monitoring team.

page 21



Figure 6. The operational and management structure

| Data variable   | Source of data     | Data unit | Comment   |
|---|--------------------|-----------|---|
| $EF_{NG}$ ,<br>emission factor of the NG<br>burning process                       | IPCC 2006          | tCO2/MWh  | IPCC 2006 default value = $0.0561 \text{ tCO}_2/\text{GJ}.$ |
| $EF_{el,y}$ ,<br>emission factor of the<br>Ukrainian grid for reducing<br>project | See Annex 4 of PDD | tCO2/MWh  | = 0.896 tCO <sub>2</sub> /MWh                               |

# **B.2.1.** List of fixed default values and ex-ante baseline factors:

Table 8: Project fixed default values

| Data variable  | Source of data | Data unit | Comment                       |
|--|----------------|-----------|-------------------------------|
| $EF_{Coal}$ ,  | IPCC 2006      | tCO2/MWh  | IPCC 2006 default value =     |
| emission factor for local  |                |           | 0.0983 tCO <sub>2</sub> /GJ   |
| (anthracite) coal burning  |                |           |                               |
| <i>EF<sub>el,y</sub></i> ,<br>emission factor of the<br>Ukrainian grid for reducing<br>project | See Annex 4    | tCO2/MWh  | = 0.896 tCO <sub>2</sub> /MWh |

Table 9: Baseline fixed default values

| Data variable   | Source of data                   | Data unit                       | Comment  |
|---|----------------------------------|---------------------------------|--|
| <i>SPNG</i> <sub>tf</sub> ,<br>the baseline ex-ante specific<br>NG consumption of the 26<br>reconstructed furnaces  | Baseline information             | 1000nm <sup>3</sup> /t<br>steel | See PDD, Table A2.1 for<br>more detailed information             |
| $SPH_{VD}$ ,<br>the baseline ex ante specific<br>heat consumption of the old<br>VD                                  | Baseline three years information | MWh/t                           | See PDD, Table A2.2 for<br>more detailed information             |
| <i>SPEL</i> <sub>VD</sub> ,<br>baseline ex ante specific<br>electrical consumption of the<br>old VD                 | Baseline information             | MWh/t                           | =0.000028 MWh/t steel  |
| <i>SPEL</i> <sub>ES</sub> ,<br>baseline ex ante specific<br>consumption of electricity<br>per tone of electro steel | Baseline three years information | MWh/t                           | See PDD, Table A2.3 for<br>more detailed information             |
| <i>EL</i> <sub>MOT</sub> , installed capacity of<br>the press' serving motors<br>before reconstruction              | Project design<br>documentation  | MW                              | It was 24 motors, 500kW each. So, <i>EL</i> <sub>MOT</sub> =12MW |

Table 10: Baseline ex-ante factors

# **B.2.2.** List of variables:

The list of variables was defined in the PDD (Section D) in order to calculate ERs in a proper way. Some of variables could not be monitored directly, so data from the meters should be adjusted by appointed correction factors. The following table establishes the link between data from the meters and corresponding variables.

| Data variable   | Data unit | Method of calculation   | Meters used for calculation   |
|---|-----------|---|---|
| <i>EL<sub>VD</sub></i> ,<br>electricity consumed by the<br>new vacuum system (VD) | MWh       | $EL_{VD} = \frac{EL \times K_{TR}}{1000},$  | EL= (EL5+EL6+EL7+EL8) (see<br>Table 3)                                  |
|   |           | Where:<br>EL = electricity consumption, monitored at VD, kWh;<br>KTR = 600/5 transformation factor, (see Table 4, TR22,,TR29).  |   |
| <i>EL</i> <sub><i>LF</i></sub> ,<br>Electricity consumed by the<br>ladle furnace  | MWh       | $EL_{LF} = \frac{EL \times K_{TR,current} \times K_{TR,voltage}}{1000},$  | EL=EL4 (see Table 3)  |
|   |           | Where:<br>EL = electricity consumption, monitored at LF, kWh;<br>K <sub>TR,current</sub> = 500/5, transformation factor of current transformer, (see Table 4, TR16,<br>TR17, TR18);<br>K <sub>TR,voltage</sub> = 35000/100, transformation factor of voltage transformer, (see Table 4,<br>TR19, TR20, TR21); |   |
| $EL_{EAF}$ ,<br>Electricity consumed by the<br>EAFs                               | MWh       | $EL_{EAF} = EL_{EAF50} + EL_{EAF100\#3} + EL_{EAF100\#5},$  | $EL_{EAF50} = EL1$ (see Table 3)<br>$EL_{EAF100#2} = EL2$ (see Table 3) |
|   |           | $EL_{EAF100\#3} = \frac{EL_{100\#3} \times K_{TR100\#3, current} \times K_{TR100\#3, voltage}}{1000},$  | $EL_{EAF100\#5} = EL3$ (see Table 3)                                    |
|   |           | $EL_{EAF100\#5} = \frac{EL_{100\#5} \times K_{TR100\#5, current} \times K_{TR100\#5, voltage}}{1000},$  |   |
|   |           | where:<br>$EL_{EAF50}$ = electricity consumption, monitored at EAF50, MWh;<br>$EL_{EAF100#3}$ = electricity consumption, monitored at EAF100#3, kWh;<br>$K_{TR100#3,current}$ = 600/5, transformation factor of current transformer, (see Table 4, TR6,   |   |

|  |     | TR7);<br>$K_{TR100\#3,voltage} = 35000/100$ , transformation factor of voltage transformer, (see Table 4,<br>TR8, TR9, TR10);<br>$EL_{EAF100\#5} =$ electricity consumption, monitored at EAF100#3, kWh;<br>$K_{TR100\#5,current} = 600/5$ , transformation factor of current transformer, (see Table 4, TR11,<br>TR12);<br>$K_{TR100\#5,voltage} = 35000/100$ , transformation factor of voltage transformer, (see Table 4,<br>TR13, TR14, TR15); |                        |
|--|-----|--|------------------------|
| <i>EL<sub>PR</sub></i> ,<br>electricity consumed by the<br>new pumps of the 15,000<br>tonnes press | MWh | $EL_{PR} = \frac{EL \times K_{TR,current} \times K_{TR,voltage}}{1000},$<br>Where:<br>EL = electricity consumption, monitored at press, kWh;<br>$K_{TR,current} = 1500/5$ , transformation factor of current transformer, (see Table 4, TR30);<br>$K_{TR,current} = -6000/100$ transformation factor of voltage transformer (see Table 4, TR31)  | EL = EL9 (see Table 3) |
|  |     | $K_{TR,voltage} = 6000/100$ , transformation factor of voltage transformer, (see Table 4, TR31).   |                        |

Table 11: Project variables

Baseline emissions variables to be measured:

| Data variable   | Source of data   | Data unit | Method of calculation  | Meters used for calculation   |
|---|--|-----------|--|-------------------------------|
| $PRST_{tf}$ , the production level of each of the 26 reconstructed thermal and heating furnaces | Measuring devices of the<br>thermal shop and forge and<br>press shop | Tonnes    | $PRST_{tf}$ is a result of direct measurement (weighing) of the of half-finished products proceeded through each furnace | WM1-WM4                       |
| $PRVS_{VD}$ , the production volume of vacuumed steel   | Measuring devices of the VD  | Tonnes    | $PRVS_{VD}$ is a result of direct measurement (weighing) of the steel proceeded through VD                               | WM5                           |
| <i>PRES</i> , the production volume of electro steel  | Measuring devices of the electro steel shop                          | Tonnes    | <i>PRES</i> is a result of direct measurement (weighing) of the steel proceeded through LF                               | WM5                           |
| T <sub>pp</sub> , working hours of press  | Server at energy saving department                                   | hours     | $T_{pp}$ is the sum from registry log book records   | Registry log-book<br>on press |

Table 12: Baseline measurable variables

| Variable              | Description   | Unit                | Value   |
|-----------------------|---|---------------------|---------|
| NG <sub>tf,y,1</sub>  | Natural gas consumption at thermal furnace #9,TS      | 1000Nm <sup>3</sup> | 115.979 |
| NG <sub>tf,v,2</sub>  | Natural gas consumption at thermal furnace #10,TS     | 1000Nm <sup>3</sup> | 116.580 |
| NG <sub>tf,v,3</sub>  | Natural gas consumption at thermal furnace #1,TS      | 1000Nm <sup>3</sup> | 256.941 |
| $NG_{tf,y,4}$         | Natural gas consumption at thermal furnace #2,TS      | $1000 \text{Nm}^3$  | 185.477 |
| $NG_{tf,y,5}$         | Natural gas consumption at heating furnace #10,FPS    | 1000Nm <sup>3</sup> | 443.578 |
| $NG_{tf,y,6}$         | Natural gas consumption at heating furnace #9,FPS     | 1000Nm <sup>3</sup> | 409.415 |
| $NG_{tf,y,7}$         | Natural gas consumption at heating furnace #8,FPS     | 1000Nm <sup>3</sup> | 408.681 |
| $NG_{tf,y,8}$         | Natural gas consumption at heating furnace #7,FPS     | 1000Nm <sup>3</sup> | 662.352 |
| $NG_{tf,y,9}$         | Natural gas consumption at thermal furnace #30,FPS    | 1000Nm <sup>3</sup> | 285.001 |
| $NG_{tf,y,10}$        | Natural gas consumption at thermal furnace #18,FPS    | 1000Nm <sup>3</sup> | 171.125 |
| $NG_{tf,y,11}$        | Natural gas consumption at thermal furnace #19,FPS    | 1000Nm <sup>3</sup> | 215.983 |
| $NG_{tf,y,12}$        | Natural gas consumption at thermal furnace #20,FPS    | 1000Nm <sup>3</sup> | 268.282 |
| $NG_{tf,y,13}$        | Natural gas consumption at thermal furnace #21,FPS    | 1000Nm <sup>3</sup> | 170.631 |
| $NG_{tf,y,14}$        | Natural gas consumption at thermal furnace #32,FPS    | 1000Nm <sup>3</sup> | 189.569 |
| $NG_{tf,y,15}$        | Natural gas consumption at heating furnace #33,FPS    | 1000Nm <sup>3</sup> | 100.578 |
| $NG_{tf,y,16}$        | Natural gas consumption at thermal furnace #37,FPS    | 1000Nm <sup>3</sup> | 53.229  |
| $NG_{tf,y,17}$        | Natural gas consumption at thermal furnace #4,TS      | 1000Nm <sup>3</sup> | 186.376 |
| NG <sub>tf,y,18</sub> | Natural gas consumption at heating furnace #34,FPS    | 1000Nm <sup>3</sup> | 158.048 |
| $NG_{tf,y,19}$        | Natural gas consumption at heating furnace #35,FPS    | 1000Nm <sup>3</sup> | 187.775 |
| $NG_{tf,y,20}$        | Natural gas consumption at heating furnace #36,FPS    | 1000Nm <sup>3</sup> | 165.680 |
| $NG_{tf,y,21}$        | Natural gas consumption at thermal furnace #38,FPS    | 1000Nm <sup>3</sup> | 23.917  |
| $EL_{VD}$             | Electricity consumption by new VD                     | MWh                 | 55.469  |
| $EL_{LF}$             | Electricity consumption by LF                         | MWh                 | 3981    |
| $EL_{EAF}$            | Electricity consumption by EAFs                       | MWh                 | 21606   |
| $EL_{PR}$             | Electricity consumption by the new pumps of the press | MWh                 | 623     |

# **B.2.3.** Data concerning GHG emissions by sources of the project activity:

Table 13: Data collected in the project scenario

# **B.2.4.Data concerning GHG emissions by sources of the baseline:**

| Variable               | Description  | Unit   | Value   |
|------------------------|--|--------|---------|
| $PRST_{tf,1}$          | Half finish products production at thermal furnace #9,TS   | Tonnes | 775.36  |
| $PRST_{tf\cdot 2}$     | Half finish products production at thermal furnace #10,TS  | Tonnes | 631.13  |
| $PRST_{tf,3}$          | Half finish products production at thermal furnace #1,TS   | Tonnes | 1552.73 |
| $PRST_{tf,4}$          | Half finish products production at thermal furnace #2,TS   | Tonnes | 2258.42 |
| $PRST_{tf,5}$          | Half finish products production at heating furnace #10,FPS | Tonnes | 5972.77 |
| $PRST_{tf,6}$          | Half finish products production at heating furnace #9,FPS  | Tonnes | 6247.3  |
| $PRST_{tf,7}$          | Half finish products production at heating furnace #8,FPS  | Tonnes | 3818.2  |
| $PRST_{tf,8}$          | Half finish products production at heating furnace #7,FPS  | Tonnes | 5905.6  |
| $PRST_{tf,9}$          | Half finish products production at thermal furnace #30,FPS | Tonnes | 1167.9  |
| $PRST_{tf}, 10$        | Half finish products production at thermal furnace #18,FPS | Tonnes | 1399.25 |
| $PRST_{tf}, 11$        | Half finish products production at thermal furnace #19,FPS | Tonnes | 1322.79 |
| $PRST_{tf}, 12$        | Half finish products production at thermal furnace #20,FPS | Tonnes | 1129    |
| PRST <sub>tf</sub> ,13 | Half finish products production at thermal furnace #21,FPS | Tonnes | 1258.84 |
| PRST <sub>tf</sub> ,14 | Half finish products production at thermal furnace #32,FPS | Tonnes | 1356.4  |
| PRST <sub>tf</sub> ,15 | Half finish products production at heating furnace #33,FPS | Tonnes | 1222.25 |

| Variable               | Description  | Unit   | Value    |
|------------------------|--|--------|----------|
| PRST <sub>tf</sub> ,16 | Half finish products production at thermal furnace #37,FPS | Tonnes | 436.15   |
| PRST <sub>tf</sub> ,17 | Half finish products production at thermal furnace #4,TS   | Tonnes | 1287.95  |
| $PRST_{tf}, 18$        | Half finish products production at heating furnace #34,FPS | Tonnes | 2219.65  |
| $PRST_{tf,19}$         | Half finish products production at heating furnace #35,FPS | Tonnes | 2145     |
| $PRST_{tf,20}$         | Half finish products production at heating furnace #36,FPS | Tonnes | 1650.37  |
| $PRST_{tf}, 21$        | Half finish products production at thermal furnace #38,FPS | Tonnes | 318.75   |
| PRVS <sub>VD</sub>     | Vacuumed steel production at VD                            | Tonnes | 26859.07 |
| EBDHC                  | efficiency of the steam boilers at the DHC                 | %      | 81.6     |
| PRES                   | Steel production at LF                                     | Tonnes | 29049    |
| T <sub>PP</sub>        | Working time of the motors on press                        | Hours  | 1305.6   |

Table 14: Data collected in the baseline scenario

## **B.2.5.Data concerning leakage:**

PDD did not identify any leakages therefore this section is not applicable.

#### **B.2.6.Data concerning environmental impacts:**

The project improved efficiency of use of natural gas, electricity and heat at the enterprise and thus leaded to decrease of harmful emissions.

#### **B.3.Data processing and archiving (incl. software used):**

**Subproject 1. Reconstruction of thermal and heating furnaces.** Information from flow meters, pressure and temperature sensors are transmitting to the control and monitoring computer system. All information about technological process is saved continuously. The archiving period for the log files is at least one year. Information that corresponds to the natural gas consumption in second quarter 2010 has been burned on CDs. These CDs are stored till the end of the crediting period plus two years.

Every half-finished product that process through the furnaces has its own unique certificate. This certificate reflects all operations performed on the product and the weight on the exit of every workshop. So, the weight of half-finished products that proceed through each furnace could be easily monitored. Information from the certificates is saved in the log books in order to simplify the monitoring process.

A report including natural gas consumption and weight of half finished products is generating on a monthly basis. The report is signed by the Head of Energy Saving Department, Head of corresponding workshop and approved by Chief Engineer.

**Subproject 2. Installation of a new vacuum system.** Information from the meters is passed to the control and monitoring computer system of vacuumator. A computer system records information about every vacuumation session, including melt passport, time and electricity consumption. The archiving period for the log files is at least one year. Information that corresponds to the electricity consumption in second quarter 2010 has been burned on CDs. These CDs are stored till the end of the crediting period plus two years.

**Subproject 3. Installation of an arc ladle furnace.** The data from electricity meters concerning electricity consumption is transmitted to the control and monitoring computer system continuously. The computer system records information about each melt process, including melt certificate. This certificate includes information about the number of the EAF where steel was melted, steel content, amount of electricity consumed during melting and weight of steel. The archiving period for the log files is at least one year. All melt certificates for the second quarter 2010 has been burned to CDs. These CDs are stored till the end of the crediting period plus two years.

#### Subproject 4. Modernization of press equipment.

All data concerning electricity consumption is transmitted to the control and monitoring computer system. The press has a special registry log book, where working time of press is logged, among other data. The following figure presents electricity supplying system of the press with metering points.

The overall data processing presents on the following figure



Figure 7: Data Processing Chart

# **B.4. Special event log:**

Since 04 of February 2010, due to the Ladle Furnace's transformator failure, feeding of the LF as well as metering of the electricity consumption was switched to the EAF100#3 transformator. All supporting documents have been submitted to the AIE during the previous site visit.

### SECTION C. Quality assurance and quality control measures

#### C.1. Documented procedures and management plan:

#### C.1.1. Roles and responsibilities:

The general management of the monitoring team is implemented by the Deputy Chief Engineer of the EMSS through supervising and coordinating activities of his subordinates, such as the head of Energy Saving Department, the head of Steel Making Shop, Press-Forging Shop and Thermal Shop. On-site day-to-day (operational) management is implemented by the heads of corresponding shops. The technological process data is logged into the PCs continuously. The PCs at the reconstructed furnaces, LF, VD, etc., have not only monitoring but control functions. Keeping the PCs in a working condition is a responsibility of the Department of the automated control systems.

All data necessary for the  $CO_2$  emission reductions calculation is collected in the Energy Saving Department. The head of the Energy Saving Department is making calculations on a monthly basis. The general supervision of the monitoring system is executed by the Deputy Chief Engineer.

For this monitoring period the names of the personnel involved is as follows:

- Deputy Chief Engineer: A. Masyuk
- Head of Energy Saving Department: V. Timoshenko
- Head of the Steel Making Shop: A. Gorkusha
- Head of the Press-Forging Shop: N. Bondar
- Head of the Thermal Shop: V. Stankov

# C.1.2. Trainings:

All contracts for the equipment supplying include chapter describing personnel training. Training is providing by equipment producers.

#### C.2. Involvement of Third Parties:

The Ukrainian Centre for Standardization and Metrology is a Third Party involved.

#### C.3. Internal audits and control measures:

 $CO_2$  emission reductions calculations are performing on the monthly basis by the head of the Energy Saving Department. All energy sources flows (such as electricity and natural gas) are logged on the server in the Energy Saving Department. Hence the head of Department checks the correctness of measurements by the indirect calculations.

#### C.4. Troubleshooting procedures:

Every day the Energy Saving Department reports to the Chief Engineer about energy resources consumption by EMSS. That report is the result of analyzing of the data logging on a dedicated server. In case of any meter failure, data discrepancy will be found within one day. The meter will be substituted by working one.  $CO_2$ emissions reduction will be calculated by cross-checking method for the period of malfunctioning.

#### **SECTION D. Calculation of GHG emission reductions**

#### **D.3.1.** Project emissions:

The project emissions are calculated by the equation:

$$PE_{y} = \sum_{i=1}^{i=4} PE_{spi} ; \qquad (Equation 1)$$
Where:

Where:

 $PE_{v}$  - are the project emissions for the monitoring period, [tCO<sub>2</sub>];

 $PE_{spi}$  - are the project emissions from each subproject, from SP1 to SP4;

#### The project emissions [tCO2/y] from SP1 are:

$$PE_{sp1} = \sum_{i=1}^{i=n} \left( \sum_{1}^{26} NG_{f,i} * LCV_{NG,i} * EF_{NG} \right); \qquad (Equation 2)$$

Where:

 $PE_{sp1}$  - is the sum of project emissions of subproject 1 from each month of the monitoring period , [tCO<sub>2</sub>];  $NG_{tf,i}$  - is the volume of NG, used by the 26 reconstructed furnaces in the month i, [1000 nm3];  $LCV_{NG_i}$  - is the lower calorific value of the NG for the month i, [MWh/1000nm3];  $EF_{NG}$  - is the emission factor of the NG burning process, [tCO2/MWh].

#### The project emissions [tCO2/y] from SP2 are:

$$PE_{sp2} = \sum_{i=1}^{n} (EL_{VD,i} * EF_{ei}); \qquad (Equation 3)$$

Where:

 $PE_{sp2}$  - is the sum of project emissions of subproject 2 from each month of the monitoring period, [tCO<sub>2</sub>];  $EL_{VDi}$  - is the electrical consumption of the new VD in the month i, [MWh];  $EF_{al}$  - is the calculated emission factor of the Ukrainian grid, [tCO2/MWh].

# The project emissions [tCO2/y] from SP3 are:

$$PE_{sp3} = \sum_{i=1}^{n} \left( \left( EL_{LF,i} + EL_{EAF,i} \right)^* EF_{el} \right);$$
(Equation 4)
Where:

Where:

 $PE_{sp3}$  - is the sum of project emissions of subproject 3 from each month of the monitoring period, [tCO<sub>2</sub>];  $EL_{IFi}$  - is the electrical consumption of the new ladle furnace in the month i, [MWh];  $EL_{FAF_i}$  - is the electrical consumption of the electric arc furnace in the month i, [MWh];

#### The project emissions [tCO2/y] from SP4 are:

$$PE_{sp4} = \sum_{i=1}^{n} (EL_{PR,i} * EF_{el,y}); \qquad (Equation 5)$$

Where:

 $PE_{sp4}$  - is the sum of project emissions of subproject 4 from each month of the monitoring period, [tCO<sub>2</sub>];  $EL_{PRi}$  - is the electrical consumption of the new pumps of the 15,000 tonnes press in the month i, [MWh].

|  | 2Q 2010              |
|--|----------------------|
| Project emissions  | [tCO <sub>2</sub> e] |
| Subproject 1. Reconstruction of thermal and heating furnaces | 9 066                |
| Subproject 2. Installation of a new vacuum system            | 50                   |
| Subproject 3. Installation of an arc ladle furnace           | 22 926               |
| Subproject 4. Modernization of press equipment               | 558                  |
| Total for second quarter of 2010                             | 32 599               |

Table 15: Project emissions

#### **D.3.2.** Baseline emissions:

$$BE_{y} = \sum_{i=1}^{i=4} BE_{spi};$$
(Equation 6)

Where:

 $BE_{y}$  - are the baseline emissions for the monitoring period, [tCO<sub>2</sub>];

 $BE_{spi}$  - are the baseline emissions from each subproject, from SP1 to SP4.

#### The baseline emissions for SP1 [tCO2/y] are:

$$BE_{sp1} = \sum_{1}^{26} \left( \sum_{i=1}^{n} (SPNG_{tf} * PRST_{tf} * LCV_{NG} * EF_{NG}) \right); \qquad (Equation 7)$$

Where:

 $BE_{sp1}$  - is the sum of baseline emissions of subproject from each month of the monitoring period, [tCO<sub>2</sub>];  $SPNG_{tf}$  - is the baseline ex-ante specific NG consumption of the 26 reconstructed furnaces, [1000nm3/t steel];

 $PRST_{tf}$  - is the production steel level of each of the 26 reconstructed thermal and heating furnaces in the month i, [tonnes].

## The baseline emissions for SP2 [tCO2/y] are:

$$BE_{sp2} = \sum_{i=1}^{n} (SPH_{VD} * PRVS_{VD,i} \div EB_{DHC} * EF_{Coal} + SPEL_{VD} * PRVS_{VD,i} * EF_{el,y}); (Equation 8)$$
  
Where:

 $BE_{sp2}$  - is the sum of baseline emissions of subproject 2 from each month of the monitoring period, [tCO<sub>2</sub>];  $SPH_{VD}$  - is a baseline ex ante specific heat consumption of the old VD, [MWh/t];  $PRVS_{VD,i}$  - is the monthly production volume of vacuumed steel, [t];  $EB_{DHC}$  - is the efficiency of the steam boilers at the DHC;  $EF_{coal}$  - is the emission factor for local (anthracite) coal burning, [tCO2/MWh];  $SPEL_{VD}$  - is a baseline ex ante specific electrical consumption of the old VD, [MWh/t];  $EF_{el_{vD}}$  - is the calculated emission factor of the Ukrainian grid, [tCO2/MWh].

# The baseline emissions for SP3 [tCO2/y] are:

$$BE_{sp3} = \sum_{i=1}^{n} (SPEL_{ES} * PRES_i * EF_{el,y}); \qquad (Equation 9)$$

Where:

 $BE_{sp3}$  - is the sum of baseline emissions of subproject 3 from each month of the monitoring period, [tCO<sub>2</sub>];  $SPEL_{ES}$  - is the baseline ex ante specific consumption of electricity per tone of electro steel, [MWh/t steel];

PRESi – is the monthly production volume of electro steel, [t].

# The annual baseline emissions for SP4 [tCO2/y] are:

$$BE_{sp4} = \sum_{i=1}^{n} (T_{pp} * EL_{MOT} * EF_{el,y});$$
 (Equation 10)

Where:

 $BE_{sp4}$  - is the sum of baseline emissions of subproject 4 from each month of the monitoring period, [tCO<sub>2</sub>];  $T_{pp}$  - is a working hours of the press in the month i, [h];

 $EL_{MOT}$  - is the press' serving motors before reconstruction, [MW].

|  | 2Q 2010              |
|--|----------------------|
| Baseline emissions   | [tCO <sub>2</sub> e] |
| Subproject 1. Reconstruction of thermal and heating furnaces | 59 629               |
| Subproject 2. Installation of a new vacuum system            | 13 513               |
| Subproject 3. Installation of an arc ladle furnace           | 26 774               |
| Subproject 4. Modernization of press equipment               | 14 038               |
| Total for second quarter of 2010                             | 113 953              |

Table 16: Baseline emissions

page 34

# D.3.3. Leakage:

Not Applicable

# **D.3.4.** Summary of the emissions reductions during the monitoring period:

|  | 2Q 2010              |
|--|----------------------|
| Emission Reductions  | [tCO <sub>2</sub> e] |
| Subproject 1. Reconstruction of thermal and heating furnaces | 50 563               |
| Subproject 2. Installation of a new vacuum system            | 13 463               |
| Subproject 3. Installation of an arc ladle furnace           | 3 848                |
| Subproject 4. Modernization of press equipment               | 13 480               |
| Total for second quarter of 2010                             | 81 354               |

Table 17: Emission Reductions