

JI MONITORING REPORT

FOR REPORTING PERIOD 01.01.2011 – 31.05.2011

**Version 1.0
01st of June 2011**

CONTENTS

- A. General project activity and monitoring information
- B. Key monitoring activities
- C. Quality assurance and quality control measures
- D. Calculation of GHG emission reductions

SECTION A. General Project activity information

A.1 Title of the project activity:

“Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko”.

A.2. Registration number at JISC:

UA2000004

A.3. Short description of the project activity:

According to data of the mine, during five months (01.01.2011— 31.05.2011) the following amount of methane has been utilized:

| | |
|---|-------------------|
| For electricity (and heat) m ³ (fuel gas) | 20 233 243 |
| For electricity (and heat) m ³ (ignition gas) | 824 476 |
| For AGFCP m ³ | 669 380 |
| Total | 21 727 099 |

Table 1: Amount of methane utilized during monitoring period.

The project is aimed to prevent methane emission into the atmosphere at Lease Enterprise Coal Mine named after A.F. Zasyadko, further referred to as Zasyadko Mine or simply Mine. CMM extracted and recovered during mine works and because of ventilation of Mine, obtained from surface wells drilled into the gob at Zasyadko Coal Mine, is utilized for:

- Electricity generation;
- Replacement of heat that is now generated by coal and gas boilers;
- Production of gas and its use as motor vehicle fuel.

Mine has four industrial sites: Vostochnaya, Yakovlevskaya, Centralnaya and Grigoryevskaya. During this monitoring period, Vostochnaya industrial site of Structural Unit Combined Heat and Electricity Plant (hereinafter referred to as SU CHP) was in operation. The electricity generated at SU CHP was supplied in Mine's main, for Mine's local consumption. Heat generated by SU CHP was fed for consumption at Vostochnaya site. Double-block automatic gas filling station (AGFCP) at Vostochnaya site supplies car fleet of Mine and other vehicles from neighbouring districts with fuel.

In the future, commissioning of the second SU CHP at Yakovlevskaya site is intended, and heat supply grid as well. This will make Mine able to feed excess electricity to general consumption grid, supply heat to Vostochnaya, Yakovlevskaya, and Centralnaya sites, and municipal heat supply grid. Besides, gas fuelling stations (AGFCP) will be installed at Yakovlevskaya site.

A.4. Monitoring period:

- Monitoring period starting date: 01/01/2011;
- Monitoring period closing date: 31/05/2011¹.

A.5. Methodology applied to the project activity (incl. version number):

A.5.1. Baseline methodology:

The approved consolidated methodology ACM0008/Version 03 “*Consolidated baseline methodology for coal bed methane and coal mine methane capture and use for electricity (electrical or motive) and heat and/or destruction by flaring*”) has been used to identify the baseline scenario of this JI project. This methodology also refers to the “Tool for calculation of emission factor for electricity systems”, the latest version of the “Tool for the demonstration and assessment of additionality” and the latest version of the “Tool to determine project emissions from flaring gases containing methane”.

¹ Both days were included. Monitoring period includes time from 00-00 01/01/11 up to 24-00 31/05/11.

A.5.2. Monitoring methodology:

The approved consolidated methodology ACM0008/Version 03 “*Consolidated baseline methodology for coal bed methane and coal mine methane capture and use for electricity (electrical or motive) and heat and/or destruction by flaring*”) was used to identify the baseline scenario of this JI project.

A.6. Status of implementation including timetable for major project parts:

| Activity | Planned Date of Installation as Specified in PDD | Implementation Status |
|---|---|--|
| Commissioning of two gas filling compressor stations | March 2004 | March 2004 |
| Commissioning of one new gas filling compressor station | March 2005 | March 2005 |
| Commissioning of the 1 st CHP module at Vostochnaya site | January 2006 | January 2006 |
| Commissioning of the 12 CHP modules at Vostochnaya site | April 2006 | April 2006 |
| Heat feeding from CHP modules to Vostochnaya site and shut-down of boilers at Vostochnaya site | September 2006 | September 2006 |
| Commissioning of one new gas filling compressor station | November 2007 | March 2005 |
| Commissioning of one new gas filling compressor station | January 2008 | Delayed because of accident 2007; planned for September 2012 |
| Heat supply from CHP modules to Yakovlevskaya site and shut-down of boilers at Yakovlevskaya site | May 2008 | Delayed because of accident 2007; planned for October 2012 |
| Heat supply from CHP modules to Centralnaya site and shut-down of boilers at Centralnaya site | July 2008 | Delayed because of accident 2007; planned for October 2012 |
| Commissioning of the 1 st CHP module at Yakovlevskaya site | July 2009 | Delayed because of accident 2007; planned for December 2011 |
| Commissioning of the 12 CHP modules at Yakovlevskaya site | December 2009 | Delayed because of accident 2007; planned for March 2012 |
| Heat supply to district heat supply system | September 2009 | Delayed because of accident 2007; planned for December 2012 |

Table 2: Status of implementation (according to PDD version 4.4)

A.7. Intended deviations or revisions to the registered PDD:

There are no deviations from final version of PDD approved by JISC. A delay in the implementation schedule was noted as compared with implementation schedule from PDD as shown above. In view of this, within the monitoring period, following project parts have not been introduced:

- Electricity: Yakovlevskaya SU CHP is not in operation at this moment. At this site, electricity generation is not running; as a result, GEN_{CHP} includes only net electricity generated by Vostochnaya SU CHP;
- Heat: during this monitoring period, infrastructure for heat supply of four sites of Mine and municipal heat supply grid are absent, save heat supply from Vostochnaya SU CHP to Vostochnaya site. In view of this, at this monitoring period, monitoring of following variable data was not performed: HEAT_{deliv,DH,y}; HEAT_{deliv,yak,y}; HEAT_{deliv,centr,y}.

General amount of heat supplied is equal to amount of heat supplied from Vostochnaya SU CHP ($HEAT_{deliv,vost,y}$);

- Coal Mine Methane(CMM), utilized at SU CHP: As Yakovlevskaya SU CHP was not in operation during this monitoring period, CMM was not utilized at this SU CHP. Therefore, $MM_{CHP,y}$ included only CMM, utilized by Vostochnaya SU CHP;
- Coal Mine Methane(CMM) utilized at AGFCP. From four planned fuel stations (one- at Vostochnaya site, one- at Centralnaya site, and two- at Yakovlevskaya site), during this monitoring period, block gas filling station at Vostochnaya site has been operating. Therefore for $MM_{GAS,y}$ monitoring, only measured amount of gas supplied to this gas fueling station was used.

A.8. Intended deviations or revisions to the registered monitoring plan:

There are deviations in the monitoring plan compared to the final monitoring plan dd. 27 March 2008 as described in the PDD version 4.4. Subject to Order Approval of Specific Carbon Dioxide Emission Values in 2011 Nr. 75 dd. May 12, 2011 issued by State Environmental Investment Agency of Ukraine, following changes have been put:

- $EF_{grid, produced, y}$ — emission ratio for power related to substituted power generation of the grid by project activity in the year;
- $EF_{grid, reduced, y}$ — emission ratio for power related to substituted power consumption at the site by project activity in the year.

These figures for carbon dioxide specific emissions will be applied until new figures of carbon dioxide specific emissions will be approved by State Environmental Investment Agency of Ukraine. Other parameters have not been changed and formulae were not changed as well.

Below – mentioned metering devices have been substituted, and additions have been made to provide safety of parameters monitored. Calibration of all these devices has been performed (see below).

From January 1, 2008, primary and secondary metering devices/ meters have been added/ substituted, because SU CHP unit measuring system was updated and improved. In addition, new metering device blocks for high concentration flow metering measurement have been installed:

- "Universal" - Metering system for measuring of ignition gas to be fed to SU CHP unit instead of Gn6 (type Keuter ADM System) at gas treatment facility;
- "Universal" - Metering system for measuring of fuel gas at AGFCP as a motor fuel, additionally to gas fuelling stations equipment;
- BKT.M - Metering system for fuel gas in machine rooms, instead of Gn5 (type Keuter ADM System) at gas treatment facility.

More detailed description of layout and work of metering equipment is shown in Section B.1.2.

A.9. Changes since last verification:

During 01/01/2011-31/05/2011, no changes occurred since last verification.

A.10. Person(s) responsible for the preparation and submission of the monitoring report:

Structural Unit Combined Heat and Electricity Plant (SU CHP) at Lease Enterprise Coal Mine named after A.F. Zasyadko

- Borys Boki, Deputy General Director, Lease Enterprise Coal Mine named after A.F. Zasyadko
- Yevgen Berezovskiy, SU CHP Chief;
- Valeriy Cherednikov, Monitoring Engineer, SU CHP Gas Treatment Lead Engineer;

LLC “Carbon Emissions Partnership Technic”.

- Svitlana Lyubarets, Director.

SECTION B. Key monitoring activities according to the monitoring plan for the monitoring period stated in A.4.

The control and monitoring system can be divided into electrical part, heat part, and gas part.

Electricity measurements

There are no changes since last monitoring period.

Heat measurements

There are no changes since last monitoring period.

B.1. Monitoring equipment

There are no changes since last monitoring period.

1. Electricity meters “Elster-Metronika”;
2. Heat meter SA-94/2 M;
3. Gas Analyzer ABB A02040 (for fuel and ignition gas);
4. DBT equipment. (for fuel and ignition gas);
5. DRG.M -10000 flow meters (for fuel GAS) as a part of BKT.M metering systems;
6. Metering system “Universal”.

B.1.2. Table providing information on metering equipment used (incl. manufacturer, type, serial number, date of installation, Date of calibration, information to specific uncertainty, need for changes and replacements):

The control and monitoring system can be divided into an electrical part, a heat part, and a gas part.

Electricity metering devices

Following parameters shall be measured for emission reduction monitoring²:

- GEN_{CHP} — net electricity generated by SU CHP under project(MWh);
- $El_{consumed}$ — net electricity consumed by Mine (MWh)³.

According to monitoring plan, initially excess or lack of net electricity amount was checked as generated by SU CHP GEN_{CHP} in comparison to net electricity consumed by Mine $El_{consumed}$. Actually, parameters measured are:

- $GEN_{CHP} = 69\,692,321$ MWh;
- $El_{consumed} = 89\,714,880$ MWh.

As net electricity amount generated by SU CHP GEN_{CHP} under project is less than net electricity consumed by Mine $El_{consumed}$, for emission reduction monitoring (see also page 40 of PDD), only amount of net electricity generated under project of SU CHP is required. This electricity is measured with two meters arranged at 110KV Substation and is calculated under the formula:

$$GEN_{CHP} = (E1 + E2) , \tag{1.}$$

Tables below show more detailed information about meters.

Amount of electricity which has been fed into power grid by 110kV Substation from SU CHP is summarized by way of addition of total electricity amount generated by each separate SU CHP unit excluding secondary electricity consumption by SU CHP itself.

This calculation is performed under following formula.

$$TM_{CHP} = \left(\sum_5^{16} E_{mod} - \sum_3 E_{aux} \right) = (E5 + E6 + E7 + E8 + E9 + E10 + E11 + E12 + E13 + E14 + E15 + E16) - (E3 + E4), \tag{2.}$$

Respective description of meters see in the table provided below. Because for check of electricity at high voltage, it is impossible to use data directly from meters, current and voltage transformers are used. In the first table, converted data for calculation of actual data are shown.

² Section D contains respective formulae from Monitoring Plan of PDD.

³ Net electricity consumption of Mine $El_{consumed}$ is demonstrated in the report of Chief Energy Engineer of the Mine according to data of thirteen commercial meters located at other 110 kV substations at LE Mine named after A.F.Zasyadko. Meters E17, E18 are included in thirteen commercial meters and are located at Vostochnaya substation 110 kV.

Cross-checking of EuroALPHA Electricity Meter Reading

Accounting of electricity generated by SU CHP is fixed by automated electricity commercial recording system (AECRS) which included twelve EuroALPHA non-commercial E-meters (E5 — E16), which record generation of each genset, as well as two EuroALPHA non-commercial E-meters (E3 — E4), which record SU CHP electricity consumption.

Each genset cell is provided with universal microprocessor protection and control devices (REF), which allow, among other functions, performance of technical recording of electricity amount. Data from REF are hourly fixed in the database. Upon expiry of the day, hourly generation per each genset is fixed.

SU CHP Chief Dispatcher performs daily comparison of readings of AECRS and REF.

Summary crosschecking results from 01.01.2011 until 31.05.2011 are shown in the table.

| 01.01.2011 - 31.05.2011 | | | |
|--------------------------------|--|--|--|
| Months | Active electricity generation AECRS | Active electricity generation REF | Relative difference in AECRS-REF readings |
| | kWh | kWh | % |
| January | 11 574 939 | 11 560 936 | 0,12 |
| February | 13 541 494 | 13 526 692 | 0,11 |
| March | 16 368 768 | 16 352 108 | 0,10 |
| April | 15 000 249 | 14 988 026 | 0,08 |
| May | 15 432 337 | 15 421 899 | 0,07 |
| Total | 71 917 786 | 71 849 662 | 0,09 |

Table 3. AECRS - REF summary crosschecking results

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 7

Electricity Meters

| Number | Metering instrument | Work parameter kWh, kVA | Manufacturer | Type | Serial Number | Accuracy ⁴ | Date of installation | Date 01.01.2011 | Date 31.05.2011 | Difference | Date of calibration | Date of next calibr. | Remarks |
|--------|---|---|---------------------------|------------|---------------|-----------------------|----------------------|-----------------|-----------------|------------|----------------------------------|----------------------|-----------------------------|
| E1 | Electricity meter at SU CHP system (6 kV) Wireway | Net electricity generated by SU CHP system. P,Q | “Elster-Metronika” Russia | Electronic | № 01116374 | 0.2S ⁵ | N/A | 9 100,0971 | 10 003,3812 | 903,2841 | 14.05.2005 13.05.2011 | 13.05.2017 | Double side. Cubicle No.A21 |
| E2 | Electricity meter at SU CHP system (6 kV) Wireway | Net electricity generated by SU CHP system. P,Q | “Elster-Metronika” Russia | Electronic | № 01116376 | 0.2S | N/A | 9 531,4268 | 10 471,8549 | 940,4281 | 14.05.2005 13.05.2011 | 13.05.2017 | Double side. Cubicle No.B22 |
| E17 | Commercial electricity meter 110 kV | Consumption of electricity from or supply Ukrainian grid with | “Elster-Metronika” Russia | Electronic | № 01194835 | 0.2S | N/A | 226,0750 | 230,6708 | 4,4558 | N/A Belongs to supply company | N/A | Substation 110kV T1 |
| E18 | Commercial electricity meter 110 kV | Consumption of electricity from or supply Ukrainian grid with | “Elster-Metronika” Russia | Electronic | № 01194834 | 0.2S | N/A | 167,2187 | 192,2356 | 25,0169 | N/A Belongs to supply company | N/A | Substation 110kV T2 |

⁴ Accuracy level is a generalized parameter of measurement devices that is defined with limits of allowable main and extra uncertainties, as well as with range of other properties that influence accuracy of measurements performed with them. Accuracy levels are regulated by norms for certain types of measurement devices with use of metrological parameters and methods of their normalization.

⁵ Accuracy levels 0.2S and 0.5S; letter S means that meter accuracy is normalized commencing from lower limit not in 5% of Inom (nominal limit) (as the case is for meters with no letter, e.g. levels 0,2 and 0,5), but from 1% of Inom, according to GOST 30206-94.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 8

| Number | Metering instrument | Work parameter kWh, kVA | Manufacturer | Type | Serial Number | Accuracy | Date of installation | Date 01.01.11 | Date 31.05.11 | Difference | Date of calibration | Date of next calibr. | Remarks |
|--------|---|---|---------------------------|------------|---------------|----------|----------------------|---------------|---------------|------------|---------------------|----------------------|----------------------------|
| E3 | Electricity meter at SU CHP system (6 kV) Auxiliary transformer | Electricity consumed by SU CHP system, P, Q | “Elster-Metronika” Russia | Electronic | № 01103251 | 0.5S | N/A | 4 781,4811 | 5 193,6832 | 412,2021 | 14.04.2010 | 14.04.2016 | Cubicle No.1 |
| E4 | Electricity meter at SU CHP system (6 kV) Auxiliary transformer | Electricity consumed by SU CHP system, P, Q | “Elster-Metronika” Russia | Electronic | № 01103208 | 0.5S | N/A | 4 834,0080 | 5 180,3795 | 346,3715 | 14.04.2010 | 14.04.2016 | Cubicle No.2 |
| E5 | Electricity meters at individual SU CHP modules (6 kV) No.1 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117846 | 0.2S | N/A | 10 821,3317 | 12 015,7114 | 1 194,3797 | 14.04.2010 | 14.04.2016 | Double side. Cubicle No.5 |
| E6 | Electricity meters at individual SU CHP modules (6 kV) No.3 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117849 | 0.2S | N/A | 12 004,3140 | 13 257,1024 | 1 252,7884 | 12.04.2010 | 12.04.2016 | Double side. Cubicle No.7 |
| E7 | Electricity meters at individual SU CHP modules (6 kV) No.5 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117851 | 0.2S | N/A | 11 978,0501 | 13 233,1247 | 1 255,0746 | 07.04.2010 | 07.04.2016 | Double side. Cubicle No.9 |
| E8 | Electricity meters at individual SU CHP modules (6 kV) No.7 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117852 | 0.2S | N/A | 11 452,1590 | 12 667,4530 | 1 215,2940 | 13.04.2010 | 13.04.2016 | Double side. Cubicle No.11 |
| E9 | Electricity meters at individual SU CHP modules (6 kV) No.9 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117855 | 0.2S | N/A | 13 245,6354 | 14 563,6681 | 1 318,0327 | 13.04.2010 | 13.04.2016 | Double side. Cubicle No.13 |
| E10 | Electricity meters at individual SU CHP modules (6 kV) No.11 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117856 | 0.2S | N/A | 12 645,9226 | 13 835,1467 | 1 189,2241 | 07.04.2010 | 07.04.2016 | Double side. Cubicle No.15 |

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 9

| Number | Metering instrument | Work parameter kWh, kVA | Manufacturer | Type | Serial Number | Accuracy | Date of installation | Date 01.01.11 | Date 31.05.11 | Difference | Date of calibration | Date of next calibr. | Remarks |
|--------|--|--|---------------------------|------------|---------------|----------|----------------------|---------------|---------------|------------|---------------------|----------------------|----------------------------|
| E11 | Electricity meters at individual SU CHP modules (6 kV) No.2 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117848 | 0.2S | N/A | 12 847,0514 | 13 021,0771 | 174,0257 | 12.04.2010 | 12.04.2016 | Cubicle No.6 |
| E12 | Electricity meters at individual SU CHP modules (6 kV) No.4 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01122645 | 0.2S | N/A | 8 299,7955 | 9 586,7755 | 1 286,9800 | 12.04.2010 | 12.04.2016 | Cubicle No.8 |
| E13 | Electricity meters at individual SU CHP modules (6 kV) No.6 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01122650 | 0.2S | N/A | 11 996,4435 | 13 456,0563 | 1 459,6128 | 14.04.2010 | 14.04.2016 | Double side. Cubicle No.10 |
| E14 | Electricity meters at individual SU CHP modules (6 kV) No.8 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01117845 | 0.2S | N/A | 14 211,0145 | 15 446,6688 | 1 235,6543 | 07.04.2010 | 07.04.2016 | Double side. Cubicle No.12 |
| E15 | Electricity meters at individual SU CHP modules (6 kV) No.10 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01132765 | 0.2S | N/A | 13 193,2966 | 14 594,1947 | 1 400,8981 | 13.04.2010 | 13.04.2016 | Double side. Cubicle No.14 |
| E16 | Electricity meters at individual SU CHP modules (6 kV) No.12 | Electricity generated by SU CHP system P,Q | “Elster-Metronika” Russia | Electronic | № 01132766 | 0.2S | N/A | 9 821,6752 | 11 109,1123 | 1 287,4371 | 14.04.2010 | 14.04.2016 | Double side. Cubicle No.16 |

Calibration interval for electricity meters is six years.

As it is impossible to use meters data directly to check electricity generated we have to take into account special coefficients which is appears from multiplying of coefficients transformation for current and voltage transformers connected to each meter. Their data are presented in table below.

In view of high voltage and currents, it is impossible to obtain direct data from electricity meters on generation and consumption of electricity without current and voltage transformers, for accounting of equipment operation. The calculation method is following: example for meter No. 01116374: Current $-3000/5= 600$ A; voltage- $6300/100=63$ V (gross factor $-600 \times 63 =37800$ VA). **Date on meter -903,2841. Electricity to be accounted with this meter makes up: $903,2841 \times 600 \times 63=34 144 138,98$ VA = 34 144 138,98 kW**

JI MONITORING REPORT

| Number | Metering instrument | Work parameter kWh, kVA | Type | Serial Number | Current transformer | Voltage transformer | Coefficient for calculations | Electricity Amount |
|--------|---|---|------------|---------------|---------------------|---------------------|------------------------------|--------------------|
| E1 | Electricity meter at SU CHP system (6 kV) Wireway | Net electricity generated by SU CHP system, P,Q | Electronic | № 01116374 | 3000/5 | 6300/100 | 37800 | 34 144 138,98 |
| E2 | Electricity meter at SU CHP system (6 kV) Wireway | Net electricity generated by SU CHP system, P,Q | Electronic | № 01116376 | 3000/5 | 6300/100 | 37800 | 35 548 182,18 |
| E3 | Electricity meter at SU CHP system (6 kV) Auxiliary transformer | Electricity consumed by SU CHP system, P, Q | Electronic | № 01103251 | 200/5 | 6300/100 | 2520 | 1 038 749,29 |
| E4 | Electricity meter at SU CHP system (6 kV) Auxiliary transformer | Electricity consumed by SU CHP system, P, Q | Electronic | № 01103208 | 200/5 | 6300/100 | 2520 | 872 856,18 |
| E5 | Electricity meters at individual SU CHP modules (6 kV) No.1 | Electricity generated by SU CHP system, P,Q | Electronic | № 01117846 | 400/5 | 6300/100 | 5040 | 6 019 673,69 |
| E6 | Electricity meters at individual SU CHP modules (6 kV) No.3 | Electricity generated by SU CHP system P,Q | Electronic | № 01117849 | 400/5 | 6300/100 | 5040 | 6 314 053,54 |
| E7 | Electricity meters at individual SU CHP modules (6 kV) No.5 | Electricity generated by SU CHP system P,Q | Electronic | № 01117851 | 400/5 | 6300/100 | 5040 | 6 325 575,98 |
| E8 | Electricity meters at individual SU CHP modules (6 kV) No.7 | Electricity generated by SU CHP system P,Q | Electronic | № 01117852 | 400/5 | 6300/100 | 5040 | 6 125 081,76 |
| E9 | Electricity meters at individual SU CHP modules (6 kV) No.9 | Electricity generated by SU CHP system P,Q | Electronic | № 01117855 | 400/5 | 6300/100 | 5040 | 6 642 884,81 |
| E10 | Electricity meters at individual SU CHP modules (6 kV) No.11 | Electricity generated by SU CHP system P,Q | Electronic | № 01117856 | 400/5 | 6300/100 | 5040 | 5 993689,46 |
| E11 | Electricity meters at individual SU CHP modules (6 kV) No.2 | Electricity generated by SU CHP system P,Q | Electronic | № 1117848 | 400/5 | 6300/100 | 5040 | 877 089,53 |
| E12 | Electricity meters at individual SU CHP modules (6 kV) No.4 | Electricity generated by SU CHP system P,Q | Electronic | № 01122645 | 400/5 | 6300/100 | 5040 | 6 486 379,20 |

JI MONITORING REPORT

| Number | Metering instrument | Work parameter kWh, kVA | Type | Serial Number | Current transformer | Voltage transformer | Coefficient for calculations | Electricity Amount |
|--------|--|---|------------|---------------|---------------------|---------------------|------------------------------|--------------------|
| E13 | Electricity meters at individual SU CHP modules (6 kV) No.6 | Net electricity generated by SU CHP system, P,Q | Electronic | № 01122650 | 400/5 | 6300/100 | 5040 | 7 356 448,51 |
| E14 | Electricity meters at individual SU CHP modules (6 kV) No.8 | Net electricity generated by SU CHP system, P,Q | Electronic | № 01117845 | 400/5 | 6300/100 | 5040 | 6 227 697,67 |
| E15 | Electricity meters at individual SU CHP modules (6 kV) No.10 | Net electricity generated by SU CHP system, P,Q | Electronic | № 01132765 | 400/5 | 6300/100 | 5040 | 7 060 526,42 |
| E16 | Electricity meters at individual SU CHP modules (6 kV) No.12 | Net electricity generated by SU CHP system, P,Q | Electronic | № 01132766 | 400/5 | 6300/100 | 5040 | 6 488 682,98 |
| E17 | Commercial electricity meter 110 kV | Consumption of electricity from or supply Ukrainian grid with | Electronic | № 01194835 | 150/5 | 110000/100 | 33000 | 151 661,40 |
| E18 | Commercial electricity meter 110 kV | Consumption of electricity from or supply Ukrainian grid with | Electronic | № 01194834 | 150/5 | 110000/100 | 33000 | 825 557,70 |

Electricity Metering Device Arrangement Scheme for Vostochnaya SU CHP Facility and 110 kV Substation




Figure 1: Electricity Metering Device Arrangement Scheme for Vostochnaya SU CHP and 110 kV Substation

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 13

Heat Meter Heat measurements

For this monitoring period, only heat is considered that was directly fed by Vostochnaya SU CHP, as described in paragraph A.7. Therefore, for this monitoring period, only one variable is measured that expresses heat amount fed by SU CHP system to heat supply pipelines, and is equal to heat amount consumed by Vostochnaya site.

| Metering instrument | Work parameter Gcal | Manufacturer | Type | Serial number | accuracy | Date of installation | Date 01.01.2011 Gcal | Date 31.05.2011 Gcal | Difference | Date of calibration | Date of next calibr. | Remarks |
|----------------------------------|---|--------------|-------------|---------------|----------------|----------------------|----------------------|----------------------|------------|----------------------|----------------------|----------------|
| Heat meter SA 94/2M ⁶ | Amount of heat delivered to site system | ASWEGA | Mechatronic | 22903 | Heat- 4 Flow-2 | N/A | 149 138,73 | 165 149,89 | 16 011,16 | 04.06.09 05.05.11 | 05.05.13 | T,V,Q (Total) |

Calibration interval for heat meters is two years

⁶ For meter SA 94/2M DN=300mm; Q=1000m³/h

Heat Metering Scheme for Vostochnaya SU CHP Facility




Figure 2: Heat Metering Scheme for Vostochnaya SU CHP Facility

CMM Meters

Measurement of CMM consumption

According to monitoring plan, two variables are measured:

- MM_{CHP} - measured amount of methane consumed by SU CHP units (tCH₄);
- MM_{GAS} - measured amount of methane fuelled in vehicles at new automotive gas filling stations (tCH₄).

Variable MM_{CHP} has two components: fuel gas consumption and ignition gas consumption. To determine the amount of pure consumed CH₄ (in tonnes) the amount of pure CH₄ (in m³) has to be measured under normal conditions⁷. The amount of pure CH₄ (in m³) can be measured (or more correctly - calculated) based on four parameters:

- Concentration (%) of CH₄ in the air and gas mixture;
- Flow (m³) of air and gas mixture;
- Temperature (°C) of air and gas mixture;
- Pressure (bar) of air and gas mixture.

In the scheme below the different meters and sensors are indicated that are installed at the Vostochnaya site.

We can classify the different meters/sensors:

- Scheme of location of main primary meters/sensors that supply the data for determining the emission reductions as provided in section D of the Monitoring Report;
- General scheme of location of meters/sensors (with addition of secondary meters/ sensors) used for cross-checking the data of the primary meters, as well as meters/sensors used to operated and control the installation.

The secondary meters/sensors are not of interest for monitoring purposes and are not mentioned further. In the table below the primary and secondary meters/sensors are indicated with their numbers which are listed in the scheme.

| | Primary meters/sensors | Secondary meters/sensors |
|--|--|---|
| Fuel gas | | |
| Concentration (%) | ABB AO 2040 (A1) | K1-K6 |
| Flow (V) | G1-G12 | Gn1-Gn6 |
| Temperature (T) | T6-T17 | Gn5 sensor |
| Pressure (P) | P11-P22 | P6(Gn5's sensor) |
| Amount and volumetric gas flow (m ³) | BKT.M ⁸ metering system | DBT equipment |
| Ignition gas | | |
| Concentration (%) | ABB AO 2040 (A2) | ABB AO 2040 (A2) |
| Flow (V) | G13 | |
| Temperature (T) | T2 | |
| Pressure (P) | P10 | |
| Amount and volumetric gas flow (m ³) | "Universal" ⁹ metering system | Pressure sensors on pipeline |
| AGFCP gas | | |
| Concentration (%) | ABB AO 2040 (A2) | ABB AO 2040 (A2) |
| Flow (V) | G14 | Calculations according to pressure difference |
| Temperature (T) | T1 | |
| Pressure (P) | P5 | Manometers at AGFCS |
| Amount and volumetric gas flow (m ³) | "Universal" ⁹ metering system | Calculations |

Table 4: Primary and secondary coal mine methane metering devices

⁷ Normal conditions=273K and 760 mm Hg.

⁸ BKT.M is designed for conversion of input data of gas parameters and calculation on the base thereof of amount and volumetric gas flow brought to standard conditions, in the composition of DRG.M 10000 meter.

⁹ Universal is designed for conversion of input data of gas parameters and calculation on the base thereof of amount and volumetric gas flow brought to standard conditions.

MM_{CHP} – is an amount of fuel gas consumption at each SU CHP unit, including one ignition gas metering device, represented as following:

$$MM_{CHP} = \left(\sum_1^{12} VM_n \times C_1 + V_1 \times C_2 \right) \times 0,7167 \times 0,93, \quad (3.)$$

where:

- VM_n — fuel gas consumption by separated SU CHP unit, brought to standard¹⁰ conditions (m³);
- $C_{1,2}$ — CH₄ concentration sensors (%);
- V_1 — amount of methane consumed as ignition gas (m³);
- 0,7167 — methane density in normal conditions (kg/m³);
- 0,93 — standard conditions to normal conditions conversion ratio

Variable MM_{GAS} to be calculated as following:

$$MM_{GAS} = V_2 \times C_2 \times 0,7167 \times 0,93, \quad (4.)$$

where:

- V_2 — amount of methane fed as fuel for vehicles, in standard conditions (m³);
- C_2 — CH₄ concentration sensor (%);
- 0,7167 — methane density in normal conditions (kg/m³);
- 0,93 — standard conditions to normal conditions conversion ratio.

Sensors represented in tables, shown after general description of methane flow process description and measurement of parameters thereof.

Crosschecking

Amount of methane used as fuel gas for SU CHP units undergoes crosschecking. This operation is performed by way of measurement of total amount of gas consumption (m³), that is defined by flow meter Gn5 (Keuter, ADM Metering system). Data about flow meter are shown in table below. This device has structure as block of velocity, pressure and temperature sensors that measure volumetric flow of gas consumed by SU CHP units and data on methane concentration in point A1 with gas analyzer AO 2040 (ABB). Amount of methane to be calculated on the base of these data, but it is not used for database formation; it is used only together with technological purposes and for crosschecking and control of SU CHP operation systems. This procedure is carried out on regular basis. Summary results of the internal cross checkings from 01.01.2011 until 31.05.2011 are presented in the table below

| 01.01.2011 - 31.05.2011 | | | | |
|-------------------------|--|---|---|---|
| month | Q Fuel Gas Consumption, m ³ /month | F Fuel Gas, Net Consumption, m ³ /month | Q Fuel Gas, Net Consumption, m ³ /month | Relative Difference in Readings Gn5*CH4/100 and \sum БКТ.М1- БКТ.М4, % |
| | Gn5 | Gn5 * CH4/100 | \sum БКТ.М1-БКТ.М4 | |
| January | 11 163 734,84 | 3 189 181,81 | 3 189 151,88 | 0,00 |
| February | 13 220 657,02 | 3 859 439,69 | 3 862 113,94 | -0,07 |
| March | 15 882 921,41 | 4 685 344,10 | 4 686 886,19 | 0,03 |
| April | 14 355 882,00 | 4 210 081,38 | 4 210 634,89 | -0,01 |
| May | 14 296 991,77 | 4 285 881,00 | 4 284 455,76 | 0,03 |
| Total | 68 920 187,04 | 20 229 927,87 | 20 233 242,66 | - 0,02 |

Table 5. Summary results of cross checking

| Measurement System | Manufacturer | Type | Serial Number | Allowable uncertainty | Calibrati on Date | Next Calibration Date |
|--------------------|--------------|------------|---------------|---------------------------------|-------------------|-----------------------|
| ADM | Keuter | Electronic | 167 | heat – 0,25% pressure – 0,5% | 02.07.10 | 02.07.11 |

Table 6. Metering Device Gn5

¹⁰ Standard conditions=293K and 760 mm Hg.

Scheme of location of main meters /sensors at Vostochnaya SU CHP in 2011




Figure 3 Scheme of location of primary meters/ sensors

General scheme of location of meters /sensors at Vostochnaya SU CHP in 2011




Figure 4. General scheme of location of meters/ sensors including secondary meters/sensors

The general flow of CMM and the metering can be described as follows.¹¹

Coal mine gas of degassing and gas-suction is supplied through four lines from two Vacuum Pump Station (VPS) to gas mixing section of the SU CHP gas treatment facility. The concentration of methane in coal mine gas and pressure are different in each pipeline. These parameters are measured by K1...K4 (Monimet) concentration sensors and P1...P4 (Vegabar-17) pressure sensors. Measurements data of these sensors are not used in coal mine gas metering and have technological meaning; these data are channelled to automatic control system of the dispatch and used only for controlling purposes in order to obtain at the output homogeneous fuel methane with necessary concentration.

Concentration of methane that is fed to the gas treatment facility is measured by the sensor K5 (Monimet); temperature, pressure and flow are measured by flow meters Gn6 (Keuter, ADM metering system), a unit of velocity, pressure, and temperature sensors. Surface well methane is mixed with fuel gas, if increase of its concentration is required. Gas methane parameters (flow, temperature, and pressure) to be fed to admix section by flow meter Gn4 (Keuter, ADM metering system). The concentration of methane is measured by gas analyser AO 2040 (ABB) in A2 point (concentrations of methane in admix and ignition gas are equal as these are included in common system of surface degasification- surface well gas methane). Having all this data, the automatic control system of the dispatch can calculate “net” amount of methane in the coal mine gas (or air and mixture as referred hereafter).

At the gas treatment section of facility, methane is distributed between three lines where it is dried, cooled, cleaned and warmed. Acting flow measurements is provided by Gn1 - Gn3 (Keuter) flow meters together with velocity, pressure and temperature sensors. They transmit information to calculation equipment developed by DBT which is installed in separate premise. This unit calculates the values of actual consumption for normal conditions and channelled them to automatic control system of the dispatch computer system for operation and saving in database. For checking and reserve, pressure sensors P7 – P9 (Vegabar-17) and temperature sensors T3 – T5 (Metran) have been installed in pipelines.

At the outflow of gas treatment section the processing discharge valve is installed which levels out e pressure swings at abrupt changes of SU CHP operation regime. Pressure at the outflow of the section is controlled by processing sensor P6 (Vegabar-17).

With the purpose of fuel gas concentration definition, gas testing is made at the outflow of gas treatment section of facility in point A1 which is fed to gas analyzer AO 2040 (ABB) mounted at gas metering unit. Concentration measured is checked for the compliance with sensor K6 (Monimet). Flow meter Gn5 (Keuter) as a unit with velocity, pressure and temperature sensors, measures the gas amount used by SU CHP units. The methane amount is calculated based on the data of methane concentration but is not used for database establishment and metering, it is used only for technological purposes and establishment of crosscheckings.

Further, fuel gas is supplied to the units of SU CHP engine rooms. The flow meters G1- G12, type (DRG.M-10000), temperature sensors T6 - T17 (Metran 274-02), and pressure sensors P11 - P22 (Vegabar -14) are mounted on the line of each 12 units. Their data are transmitted to micro- processing control system BKT.M designed for transformation of input information about gas parameters and for calculation of the base thereof of amount and volumetric amount of gas flow brought to standard conditions to calculate fuel gas amount which is used by each unit, and total amount in each engine room. Fuel gas amount is calculated based on the data of methane concentration in it. Fuel gas amount calculation is performed on the base of data received from control units for gas record BKT.M1-BKT.M4, and concentration of methane therein as received from gas analyzer AO 2040 (ABB) in point A1. Total amount of fuel gas is calculated by way of addition of figures of all gas record units BKT.M, and serves as a figure of CHP gas methane utilized. This information is entered into database and logs.

¹¹ From 2008, DBT equipment is used as equipment for operation and control of stations, as well as for crosschecking. Main meters and sensors which are installed at each SU CHP unit, transmit data to metering systems of the gas record units BKT.M (amount and volumetric flow of gas measurement). This gas record system transmits data to computer. These systems are run with fuel gas. Ignition gas for all SU CHP units is metered with a new metering system Universal. All this data are stored in place, and are transmitted to SU CHP computer system.

Ignition gas is supplied to SU CHP units from gas pipes of surface degasification wells where surface degasification wells are combined. Total ignition gas consumption is metered by system Universal designed for transformation of input information about gas parameters and for calculation of the base thereof of amount and volumetric amount of gas flow brought to standard conditions, which included gas metering device G13 (G 250 LG-K-80-1/30-1,6-1-Ex), temperature sensor T2 (PVT-01-1), and pressure sensor P10 (Vegabar-17). Gas concentration is metered by gas analyzer AO 2040 (ABB) with gas test in the point A2. Based on data received from metering system Universal, ignition gas automatic control system is kept, which gas is supplied to SU CHP units and recorded in database and log.

Gas for vehicle fuelling is also supplied to SU CHP units from gas pipes of surface degasification wells where surface degasification wells are combined. Total vehicle fuelling gas consumption is metered by system Universal designed for transformation of input information about gas parameters and for calculation of the base thereof of amount and volumetric amount of gas flow brought to standard conditions, which included gas metering device G14 (G 400 LG-K-100-1/30-1,6-1-Ex), temperature sensor T1 (PVT-01-1), and pressure sensor P5 (SEN-8601). Because the gas being fed for vehicle fuelling and ignition gas to feed to SU CHP units is a gas of uniform system of surface degasification wells, control of the gas concentration is performed by gas analyzer AO 2040 (ABB) with gas test in the point A2. Based on these data, amount of methane consumed at AGFCP as vehicle fuel is fixed in database and log.

Methane volume which is supplied with fuel gas and ignition gas gives total amount of methane supplied to SU CHP Units.

Methane volume which is supplied with fuel gas and ignition gas, and methane for vehicle filling give total amount of methane consumed by Vostochnaya site of Zasyad’ko Coal Mine.




Figure 5: Gas flow meter DRG.M-10000¹² temperature sensor Metran 274-02 and pressure sensor Vegabar-14 of metering system for gas record BKT.M at fuel gas pipeline of SU CHP unit.

¹² DRG.M – 10000 — gas flow meter designed for transformation of volumetric flow of gas (at operational pressure) into numeric and impulsive signal.

JI MONITORING REPORT

Monitoring Report #10 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko" page 21

In the table below the description of the meters/sensors of metering systems for gas record that are part of monitoring report drawing, are given:

CHP gas metering equipment

| Item No. | Metering instrument design | Work parameter | Manufacturer | Type | Serial number | Uncertainty level of data | Date of installation | Date of calibration | Date of next calibr. | Remarks |
|----------|-------------------------------|----------------|--------------|--------------------|---------------|---------------------------|----------------------|---------------------|----------------------|---------------|
| C1 | Concentration of fuel gas | % | ABB | AO 2040 Electronic | 3.244705.5 | ± 1% | 2005 | 09.07.10 | 09.07.11 | Connection A1 |
| C2 | Concentration of ignition gas | % | ABB | AO 2040 Electronic | 3.244704.5 | ± 1% | 2005 | 09.07.10 | 09.07.11 | Connection A2 |

Calibration interval for gas analyzers is one year.

Ignition gas record system Universal meters/sensors.

| Item No. | Gas to be measured | Metering instrument design | Work parameter | Manufacturer | Type | Serial number | Uncertainty level of data | Date of installation | Date of calibration | Date of next calibr. | Remarks |
|----------|--------------------|--------------------------------------|----------------|-------------------|----------------------------|---------------|-------------------------------------|----------------------|----------------------|----------------------|----------------|
| V1 | Ignition | Ignition gas amount measurement | m ³ | NVP "GREMPIS" ltd | G 250 LGK-80-1/30-1,6-1-Ex | 9771 | ± 1% 60 to 400 m ³ /h | 4 quarter 2007 | 10.03.09 10.03.11 | 10.03.13 | Connection G13 |
| | | Ignition gas temperature measurement | °C | NVP "GREMPIS" ltd | PVT-01-1 | 6480 | ± 0.5% | 4 quarter 2007 | 10.03.09 10.03.11 | 10.03.13 | Connection T2 |
| | | Ignition gas pressure measurement | bar | "VEGA" Germany | Vegabar-17 | 12307278 | ± 0.5% | 4 quarter 2007 | 09.03.10 10.03.11 | 10.03.12 | Connection P10 |

Calibration interval for pressure sensor is one year.

Calibration interval for temperature sensor and gas meter is once in two years.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 22

Motor vehicle filling gas metering system Universal meters/ sensors for recording of amount and volumetric flow of gas consumed as AGFCP fuel

| Item No. | Gas to be measured | Metering instrument design | Work parameter | Manufacturer | Type | Serial number | Uncertainty level of data | Date of installation | Date of calibration | Date of next calibr. | Remarks |
|----------|-------------------------------|---|----------------|-----------------------|-----------------------------|---------------|---------------------------------------|----------------------|---------------------|----------------------|----------------|
| V2 | Gas for motor vehicle filling | Gas for motor vehicle filling amount measurement | m ³ | NVP "GREMPIS" ltd | G 400 LGK-100-1/30-1,6-1-Ex | 9786 | ± 1% 97,5 to 650 m ³ /h | 4 quarter 2007 | 15.07.09 | 15.07.11 | Connection G14 |
| | | Gas for motor vehicle filling temperature measurement | °C | NVP"GREMPIS" " ltd | PVT-01-1 | 211 | ± 0.5% | 4 quarter 2007 | 28.07.10 | 28.07.12 | Connection T1 |
| | | Gas for motor vehicle filling pressure measurement | bar | "COBOLD" Germany | SEN-86 | 45 | ± 0.5% | 4 quarter 2007 | 28.07.10 | 28.07.11 | Connection P5 |

Calibration interval for pressure sensor is one year.

Calibration interval for temperature sensor and gas meter is once in two years.

JI MONITORING REPORT

Monitoring Report #10 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko" page 23

Gas amount and volumetric flow computing block

| Item No. | Metering system | Work parameter: m ³ /h | manufacturer | Type | Serial number | Uncertainty level of data and accuracy | Date of installation | Data as of 01.01.2011 m ³ | Data as of 31.05.2011 m ³ | Difference | Date of calibration | Date of next calibration | Remarks |
|----------------|-----------------|-----------------------------------|------------------|--------------|---------------|--|----------------------|--------------------------------------|--------------------------------------|------------|----------------------|--------------------------|---------------------|
| V ₁ | Universal | Ignition gas amount | NVP"GREMPIS" ltd | Universal -2 | 6023 | ± 0.2 % | 4 quarter 2007 | 5 866 986,6 | 6 753 520,5 | 886 533,9 | 10.03.09 10.03.11 | 10.03.13 | Main metering block |
| V ₂ | Universal | Motor vehicle fuelling gas amount | NVP"GREMPIS" ltd | Universal -2 | 327 | ± 0.2 % | 4 quarter 2007 | 7 457 355 | 8 177 118 | 719 763 | 28.07.10 | 28.07.12 | Main metering block |

Calibration interval-once in two years.

Gas amount and volumetric flow computing blocks BKT.M-1 — BKT.M-4

| Item No. | Metering system | Work parameter: m ³ | Manufacturer | Serial number | Uncertainty level of data and accuracy | Date of installation | Unit No. | Data as of 01.01.2011 m ³ | Data as of 31.05.2011 m ³ | Difference | Date of calibration | Date of next calibration | Remarks |
|----------------|-----------------|--------------------------------|----------------------------|------------------------|--|----------------------|----------|---------------------------------------|--------------------------------------|------------|---------------------|--------------------------|---------------------|
| V ₃ | BKT.M - 1 | Fuel gas amount | Sibnefteavtomatika, Russia | 094 | • Pressure channels, not exceeding ±0.3 %; • Temperature channels, not exceeding ±0.5 %; • Consumption channels, not exceeding ±0.1 %; • Gas consumption definition status brought to standard conditions, not exceeding ±0.35 %; • Gas amount definition status brought to standard conditions, not exceeding ±0.35 %; • Change of running time, not exceeding ±0.1 %. | N/A | M1 | 4 473 476 | 10 630 702 | 6 157 226 | 05.05.09 | 05.05.12 | Main metering block |
| | | | | | | | M3 | 5 395 689 | 11 831 409 | 6 435 720 | | | |
| | | | | | | | M5 | 4 673 455 | 11 208 443 | 6 534 988 | | | |
| V ₄ | BKT.M - 2 | Fuel gas amount | Sibnefteavtomatika, Russia | 095 | | N/A | M2 | 22 198 704 | 23 074 776 | 876 072 | 20.01.09 | 20.01.12 | Main metering block |
| | | | | | | | M4 | 17 171 774 | 23 852 614 | 6 680 840 | | | |
| | | | | | | | M6 | 24 370 534 | 31 962 758 | 7 592 224 | | | |
| V ₅ | BKT.M - 3 | Fuel gas amount | Sibnefteavtomatika, Russia | Before 01.03.11 100 | | N/A | M7 | Data on the testimony BKT.M see below | | | 18.03.08 | 18.03.11 | Main metering block |
| | | | | After 01.03.11 5668 | | | M9 | | | | | | |
| | | | | M11 | | | | | | | | | |
| V ₆ | BKT.M - 4 | Fuel gas amount | Sibnefteavtomatika, Russia | 099 | | N/A | M8 | 31 045 742 | 37 452 000 | 6 406 258 | 05.08.08 | 05.08.11 | Main metering block |
| | | | | | | | M10 | 29 260 138 | 36 585 252 | 7 325 114 | | | |
| | | | | | | | M12 | 18 583 728 | 25 149 112 | 6 565 384 | | | |

Calibration interval-once in three years.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 24

Records of BKT.M-3 (before and after substitution)

| Item No | Metering system | Serial number | Unit No. | Data as of 01.01.2011 m ³ | Data as of 01.03.2011 m ³ | Difference | Serial number | Data as of 01.03.2011 m ³ | Data as of 31.05.2011 m ³ | Difference | ∑ fuel gas |
|----------------|-----------------|---------------|----------|--|--|------------|---------------|--|--|------------|------------|
| V ₅ | BKT.M-3 | 100 | M7 | 29 684 186 | 31 545 786 | 1 861 600 | 5668 | 0 | 4 402 882 | 4 402 882 | 6 264 482 |
| | | | M9 | 38 669 428 | 41 251 468 | 2 582 040 | | 0 | 4 249 490 | 4 249 490 | 6 831 530 |
| | | | M11 | 36 909 120 | 39 030 120 | 2 121 000 | | 0 | 4 000 159 | 4 000 159 | 6 121 159 |

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 25

| Item No. | Gas to be metered | Symbol on scheme | Metering device designation | Work parameter | Manufacturer | Type | Serial number | Allowed uncertainty | Date of installation | Date of calibration | Date of next calibration | Remarks |
|----------|-------------------|------------------|----------------------------------|----------------|---------------------------------|------------------------|---------------|---------------------|----------------------|---------------------|--------------------------|----------------------------------|
| M1 | Fuel | G1 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 102 | ± 1.0% | N/A | 19.08.09 | 19.08.11 | Fuel gas metering system BKT.M-1 |
| | | T6 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510745 | ± 0,5% | N/A | 22.07.10 | 22.07.11 | |
| | | P11 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536534 | ± 0,5% | N/A | 04.06.10 | 04.06.11 | |
| M3 | Fuel | G3 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 109 | ± 1.0% | N/A | 19.08.09 | 19.08.11 | |
| | | T7 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510753 | ± 0,5% | N/A | 02.07.10 | 02.07.11 | |
| | | P12 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536342 | ± 0,5% | N/A | 04.06.10 | 04.06.11 | |
| M5 | Fuel | G5 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 103 | ± 1.0% | N/A | 19.08.09 | 19.08.11 | |
| | | T8 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 509669 | ± 0,5% | N/A | 22.07.10 | 22.07.11 | |
| | | P13 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14447569 | ± 0,5% | N/A | 04.06.10 | 04.06.11 | |

Calibration interval of pressure and temperature sensor is one year.

Calibration interval of gas consumption sensors is once in two years (by calibration of DRG.M - 10000 at Ivano-Frankovsk Scientific and Generation Centre Standardization, Metrology and Certification, calibration interval has been changed from 3 to 2 years).

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 26

Meters/ sensors of fuel gas metering system BKT.M – 2

| Item No. | Gas to be metered | Symbol on scheme | Metering device designation | Work parameter | Manufacturer | Type | Serial number | Allowed uncertainty | Date of installation | Date of calibration | Date of next calibration | Remarks |
|----------|-------------------|------------------|----------------------------------|----------------|---------------------------------|------------------------|---------------|---------------------|----------------------|----------------------|--------------------------|------------------------------------|
| M2 | Fuel | G2 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 108 | ± 1.0% | N/A | 15.06.09 28.04.11 | 28.04.14 | Fuel gas metering system BKT.M - 2 |
| | | T9 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510735 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P14 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14568471 | ± 0.5% | N/A | 02.06.10 | 02.06.11 | |
| M4 | Fuel | G4 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 104 | ± 1.0% | N/A | 15.06.09 28.04.11 | 28.04.14 | |
| | | T10 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 509670 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P15 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536186 | ± 0.5% | N/A | 02.06.10 | 02.06.11 | |
| M6 | Fuel | G6 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 097 | ± 1.0% | N/A | 15.06.09 28.04.11 | 28.04.14 | |
| | | T11 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510733 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P16 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536368 | ± 0.5% | N/A | 02.06.10 | 02.06.11 | |

Calibration interval of pressure and temperature sensor is one year.
Calibration interval of gas consumption sensors is once in three years.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 27

Meters/ sensors of fuel gas metering system BKT.M – 3

| Item No. | Gas to be metered | Symbol on scheme | Metering device designation | Work parameter | Manufacturer | Type | Serial number | Allowed uncertainty | Date of installation | Date of calibration | Date of next calibration | Remarks |
|----------|-------------------|------------------|----------------------------------|----------------|---------------------------------|------------------------|---------------|---------------------|----------------------|---------------------|--------------------------|------------------------------------|
| M7 | Fuel | G7 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 098 | ± 1.0% | N/A | 17.07.09 | 17.07.11 | Fuel gas metering system BKT.M - 3 |
| | | T12 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510744 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P17 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14568573 | ± 0.5% | N/A | 03.06.10 | 03.06.11 | |
| M9 | Fuel | G9 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 099 | ± 1.0% | N/A | 17.07.09 | 17.07.11 | |
| | | T13 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510742 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P18 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536304 | ± 0.5% | N/A | 03.06.10 | 03.06.11 | |
| M11 | Fuel | G11 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 101 | ± 1.0% | N/A | 17.07.09 | 17.07.11 | |
| | | T14 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510738 | ± 0.5% | N/A | 21.07.10 | 21.07.11 | |
| | | P19 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14568610 | ± 0.5% | N/A | 03.06.10 | 03.06.11 | |

Calibration interval of pressure and temperature sensor is one year.
 Calibration interval of gas consumption sensors is once in two years.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 28

Meters/ sensors of fuel gas metering system BKT.M – 4

| Item No. | Gas to be metered | Symbol on scheme | Metering device designation | Work parameter | Manufacturer | Type | Serial number | Allowed uncertainty | Date of installation | Date of calibration | Date of next calibration | Remarks |
|----------|-------------------|------------------|----------------------------------|----------------|---------------------------------|------------------------|---------------|---------------------|----------------------|---------------------|--------------------------|------------------------------------|
| M8 | Fuel | G8 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 105 | ± 1.0% | N/A | 01.07.09 | 01.07.11 | Fuel gas metering system BKT.M - 4 |
| | | T15 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510754 | ± 0.5% | N/A | 23.07.10 | 23.07.11 | |
| | | P120 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14568589 | ± 0.5% | N/A | 04.06.10 | 04.06.11 | |
| M10 | Fuel | G10 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 096 | ± 1.0% | N/A | 01.07.09 | 01.07.11 | |
| | | T16 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510755 | ± 0.5% | N/A | 23.07.10 | 23.07.11 | |
| | | P21 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14536306 | ± 0.5% | N/A | 04.06.10 | 04.06.11 | |
| M12 | Fuel | G12 | Fuel gas consumption measurement | m ³ | Sibnefteavtomatika, Russia | DRG.M-10000 Electronic | 100 | ± 1.0% | N/A | 01.07.09 | 01.07.11 | |
| | | T17 | Fuel gas temperature measurement | °C | Metran Industrial Group, Russia | Metran -274-02 | 510747 | ± 0.5% | N/A | 23.07.10 | 23.07.11 | |
| | | P22 | Fuel gas pressure measurement | bar | "VEGA" Germany | Vegabar 14 | 14568606 | ± 0.5% | N/A | 04.06.10 | 04.06.11 | |

Calibration interval of pressure and temperature sensor is one year.
 Calibration interval of gas consumption sensors is once in two years.

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 29

The monitoring system for the emission reductions achieved in the course of the project implementation has been integrated in the Zasyadko Coal Mine existing controlling and reporting system. That allows for obtaining reliable and easy verifiable data related to the project performance, ensuring thus the quality and efficiency of the monitoring system.

All source information on performance parameters and calculations have been obtained directly on site and after that reported to the Coal Mine dispatching office. The work parameters of CMM flows as well as heat and electricity generated will be crosschecked to provide quality and reliability of monitored data. To ensure reliable and non-stop performance of SU CHP the inputs of natural gas from the natural gas pipeline are envisaged.

CMM gas flow filling stations

Each gas filling station keeps records in the register. Calculations of methane fuelled are executed according to data pressure difference of manometers. Concentration of methane is measured monthly with ABB AO 2040 at SU CHP and surface well gas analysis. Besides, the concentration of methane is measured locally with an interferometer. Temperature and pressure meters are installed too. The amount and volumetric consumption of methane is measured by “Universal” metering system.

B.1.3. Calibration procedures

For Electricity Meters:

| QA/QC (Quality Assurance/ Quality Control) procedures | Body responsible for calibration and certification |
|--|---|
| Calibration interval of such meters is six years. Calibration procedures for meters are implemented in compliance with calibration methodology developed for “Elster-Metronika” meters, Russia. Calibration interval – once per 72 months. | Donetsk Centre for Standardization, Metrology and Certification |

For Heat Meters

| QA/QC (Quality Assurance/ Quality Control) procedures | Body responsible for calibration and certification |
|--|---|
| Calibration interval of such meters is two years. Calibration procedures for meters are implemented in compliance with calibration methodology developed for ASWEGA meters, Russia. Calibration interval – once per 24 months. | Donetsk Centre for Standardization, Metrology and Certification |

For CMM meters:

| QA/QC (Quality Assurance/ Quality Control) procedures | Body responsible for calibration and certification |
|---|---|
| Keuter ADM1 Electronic. Calibration interval of such meters is 12 months ¹³ | Donetsk Centre for Standardization, Metrology and Certification |
| Gas Analyzer A0 2040 (ABB). Calibration interval of such meters is 12 months ¹⁴ . | Donetsk Centre for Standardization, Metrology and Certification |
| Gas Record Unit BKT.M for amount and volumetric flow of gas record. Calibration interval for such meters is once per 36 months. | Tyumen Centre for Standardization, Metrology and Certification |
| «Universal» Metering System for amount and volumetric flow of gas record. Calibration interval for such meters is once per 24 months. | Donetsk Centre for Standardization, Metrology and Certification |

¹³ As there is no state regulation for such kind of equipment there was a decision of Ukrainian Centre for Standardization and Metrology for one year calibration period.

¹⁴ All metering equipment shall be calibrated subject to provisions and methods as defined by regulations of this centre.

B.1.4. Involvement of Third Parties:

- Donetsk Centre for Standardization, Metrology and Certification;
- Ivano-Frankovsk Scientific and Generation Centre Standardization, Metrology and Certification;
- Tyumen Centre for Standardization, Metrology and Certification.

B.2. Date collection (accumulated data for the whole monitoring period):

For the operational and management structure of the project see PDD Version 4.4, Figure 9: *Monitoring and quality control system for Vostochnaya and Yakovlevskaya sites*

B.2.1. List of fixed default values:

| ID number | Date variable | Source of data | Date unit | Comment |
|---------------------------|---|--|-------------------------------------|---|
| P6 CEF _{CH4} | Carbon emission factor for combusted methane | 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2: Energy Chapter 4: Fugitive Emissions | tCO ₂ e/tCH ₄ | Set at 2.75 tCO ₂ e /tCH ₄ See also table CMM meters |
| P12 Eff _{CHP} | Efficiency of methane destruction/oxidation in CHP | 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2: Energy Chapter 4: Fugitive Emissions | % | Set at 99.5% |
| P14 Eff _{GAS} | Overall efficiency of methane destruction/oxidation at the vehicles | 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2: Energy Chapter 4: Fugitive Emissions | % | Set at 98.5% |
| P15 GWP _{CH4} | Global warming potential of methane | 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2: Energy Chapter 4: Fugitive Emissions | tCO ₂ e/tCH ₄ | Set at 21 |

Table 7: Project Default Values

| ID number | Date variable | Source of data | Date unit | Comment |
|--|---|--|-----------------------|--|
| B13 EF _{grid, produced, y} | Emissions factor of electricity of replaced grid electricity generation by the project activity in year | Order Nr. 75 dd. May 12, 2011 issued by State Environmental Investment Agency of Ukraine | tCO ₂ /MWh | Set at 1,227 |
| B14 EF _{grid, reduced, y} | Emissions factor of electricity of replaced on-site electricity consumption by the project activity | Order Nr. 75 dd. May 12, 2011 issued by State Environmental Investment Agency of Ukraine | tCO ₂ /MWh | Set at 1,227 |
| B20 EF _{heat, vost} | Emissions factor for heat at Vostochnaya site in the baseline scenario | See Annex 2 PDD | tCO ₂ /GJ | Boiler efficiency 90% Set at 0,063 |
| B22 EF _{heat, yak} | Emissions factor for heat at Yakovlevskaya site in the baseline scenario | See Annex 2 PDD | tCO ₂ /GJ | Boiler efficiency 90% Set at 0,063 |
| B24 EF _{heat, centr} | Emissions factor for heat at Centralnaya site in the baseline scenario | See Annex 2 PDD | tCO ₂ /GJ | Boiler efficiency 90% Set at 0,143 |
| B25 VFUEL _y | Vehicle fuel provided by the project activity | Fuel Meters | GJ | This value will be calculated based MM _{GAS} of the project scenario multiplied with LHV of methane |
| B26 EF _v | Emissions factor for vehicle operation replaced by the project activity | 2006 IPCC | tCO ₂ /GJ | See annex 2 PDD. Set at 0,072 |

Table 8: Baseline Default Values

B.2.2. List of variables:

Project emissions variables to be measured:

- MM_{CHP} — Methane measured consumed by SU CHP units (tCH₄);
- MM_{GAS} — Methane measured consumed as a fuel at new AGFCPs (tCH₄).

Baseline emissions variables to be measured:

- GEN_{CHP} — Net electricity generated by the project activity by the SU CHP (MW*h);
- $El_{consumed}$ — Net electricity consumed by the mine;
- $HEAT_{consumed, \text{vost. y}}$ — Heat consumed at Vostochnaya site delivered by the project

B.2.3. Date concerning GHG emissions by sources of the project activity:

| Year | MM_{GAS} (tCH ₄) |
|------------------------|--------------------------------|
| 01.01.2011– 31.05.2011 | 480 |

Table 9: Data to be collected in the project scenario

| Year | MM_{CHP} (tCH ₄) |
|------------------------|--------------------------------|
| 01.01.2011– 31.05.2011 | 15 092 |

Table 10: Data to be collected in the project scenario

For Methane analysis data refer please to Annex 1 document.

B.2.4. Date concerning GHG emissions by sources of the baseline:

| Year | GEN_{CHP} (MWh) | El_{Cons} (MWh) | $HEAT_{cons, \text{vost. y}}$ (GJ) |
|------------------------|-------------------|-------------------|------------------------------------|
| 01.01.2011– 31.05.2011 | 69 692,321 | 89 714,880 | 67 035 |

Table 11: Data collected in the baseline scenario

B.2.5. Date concerning leakage:

Not Applicable.

B.2.6. Date concerning environmental impacts:

Activity under the project is performed subject to Ukrainian current environmental law. At construction of SU CHP and AGFCP, Environmental Impact Assessment has been performed. Pursuant to Atmospheric Air Protection Law of Ukraine, as approved by Decree of Ukrainian Board of Ministers on March 13, 2002 # 302 and Order of Ukrainian Ministry of Environmental Protection dd. 09.03.2006 # 108. Mine obtains allowances for emission of contaminating substances. Pollutant emissions inventory conducted with the assistance of third-party certified company that provides screening and analysis of samples contaminants pollutant substance with own standard equipment.

Reporting an monitoring of emissions is performed constantly; all statistical reports are prepared and submitted pursuant to Guide to Filling In the State Statistical Control Statements for Atmospheric Air N #2 - TP (air) (annual) and # 2- TP (air) (quarterly) Atmospheric Air Protection Report issued by Derzhkomstat (State Committee of Statistics) # 674 dd. 30.12.2004.

The impact of the project to the condition of waters is insignificant due tot use of water for domestic needs only. At SU CHP, Grid Water Consumption Metering Device Reading Log is kept; data therefrom are used for preparation of statistical reports. Environmental Impact monitoring for water condition is performed and all statistic report statements are submitted pursuant to the current law of Ukraine.

During project implementation, waste is established that relate to domestic activity only (service and repair of equipment), and household activity. Monitoring of waste is performed, and statistical report statements are submitted: # N 1-VT "Waste and Package and Tare Accounting pursuant to the current law of Ukraine.

B.3. Date processing and archiving (incl. software used):

All dispatchers are responsible for data management. Besides, dispatchers prepare standard daily, weekly, monthly, and annual repots. All appropriate data are collected daily, and archived both in electronic and paper form (see calculation CO₂) All data will be saved in electronic data carriers and in paper form at least two years

after implementation of this project will be completed. Passwords on servers are subject to monthly change, and each server has its own person in charge who has access thereto.

Commissioning of modern computer control system will provide efficient online monitoring and performance efficiency analysis. Data from all controlling equipment are automatically transferred to database with the aid of appropriate software:

1. Checker 8 (integrated software developed and written by the manufacturer; to be supplied with the Universal control unit) – ignition gas and AGFCP gas record -keeping;
2. Alfa- Center measuring and computing complex integrated into ASKUE (common mine automatic system of electricity commercial record -keeping) - electricity record -keeping;
3. DIA.NE.XT (software delivered with CHP units)– control, regulation, indication, setting, and saving of data for CHP unit.

For calculation of Greenhouse Gas (GHG) Emission Reductions, the SU CHP TP ACS Service has developed own Data Gathering and Processing Automated System (ASZPD) which maintains calculation of fuel gas and heat.

B.4. Special event log:

On 01.03.2011, the BKT.M # 100 has been substituted by BKT.M # 5668 because of sending thereof to state calibration at Tyumen Centre for Standardization, Metrology and Certification.

SECTION C. Quality assurance and quality control measures:

C.1. Documented procedures and management plan:

C.1.1. Roles and responsibilities:

General project management is implemented by the Deputy General Director of the Lease Enterprise Zasyadko Coal Mine through supervising and coordinating activities of his subordinates, such as deputy director on surface degasification, chief electricity engineer, chief heating engineer, and chief of safety engineering departments.

On-site day-to-day management is implemented by the manager of cogeneration station who directs two shift operators responsible for cogeneration modules and gas treatment plant performance. An on-duty electrician works at the plant. During the daytime a group of mechanics who are responsible for preventive measures and maintenance of all technological equipment, metering instruments as well as of automation tools and telemechanics are present on-site. On-line information transmitted directly to the head of the shift into the Coal Mine Central Dispatching Office. The cogeneration plant is in 24 hours operation.

At the main objects, the responsibilities are as follows:

- AGFCP operator controls and prepares data and transmits them to SU CHP dispatching office, and performs day-to-day gas record keeping log;
- Two CHP dispatchers control data on CHP unit inputs (gas treatment plant), operational process parameters, and heat and electricity output; they perform daily keeping of logs for consumption of fuel, ignition, and surface degasification well gas consumed by AGFCP.
- 110/6.3/6.6 kV operator controls data about amount of electricity fed into main and received from main and also auxiliary electricity consumption by the mine.

All information is transferred to SU CHP dispatching office, and is controlled in online mode by shift foreman. Based on information provided by dispatching office, monitoring engineer prepares monthly and annual reports about monitoring of electricity, gas, heat and emissions, and provides them to SU CHP Director and Lease Enterprise Mine named after A.F. Zasyadko General Director Deputy. General supervision over monitoring system is carried out by management of Zasyadko Coal Mine according to control and reporting system in place.

Monitoring Dataflow Chart is shown below.




Figure 6: Monitoring Dataflow Chart

*For 2011, this duty is performed by V.V. Cherednikov, Gas Treatment Lead Engineer.

C.1.2. Trainings:

GE Jenbacher (Austria) has delivered SU CHP main equipment being CHP units. As specified in the contract, training of staff that operates these units was performed in Austria. GE Jenbacher technicians have performed extra training during installation and commissioning works. Employees in charge for monitoring control have also passed training during installation of the said system.

Extra training is performed during equipment operation. SU CHP and VPS staff training program, as well as emergency training, are submitted as separate document represented as EMISSION MONITORING MANUAL FOR SU CHP Lease Enterprise Mine named after A.F.Zasyadko (Manual 2), which also includes structural diagram of technical maintenance provision and state calibration of meters of automated metering system. SU CHP Chief Dispatcher is responsible for training program development. Training programs required approval of SU CHP Director.

Safety measure training is performed once every three months, all employees pass an exam in safety measures once a year. Staff and visitors are provided with individual protection devices for protection from harmful factors of activity.

C.2. Involvement of Third Parties:

The Donetsk Centre for Standardization, Metrology and Certification, Ivano-Frankovsk Centre for Standardization, Metrology and Certification, and Tyumen Centre for Centre for Standardization, Metrology and Certification are Third Parties involved.

C.3. Internal audits and control measures:

Introduction of a modern computerized control system allows for efficient on-line monitoring and reviewing work process performance at the Lease Enterprise Mine named after A.F. Zasyadko Central Dispatching office every fifteen minutes. (in particular, for fuel and ignition gas consumption, their parameters and electricity and heat generated, data can be obtained every 10 seconds if requested). Any considerable deviation of monitored data from given work parameters will be promptly noticed and source of such deviation will be easily identified. In turn, this enables the head of shift to coordinate efficiently the adjustment actions of his shift subordinates including on-duty technical staff that eliminates such deviations and repairs equipment. This system improved operational process and eliminated lacks in control of SU CHP gas consumption.

C.4. Troubleshooting procedures¹⁵

See C .1.2

In case of a breakdown of CMM supply system (either of whole system or separate feeding pipe) methane-air mixture will be urgently released into the atmosphere through the emergency gas vent stack. The shut-off valves will automatically close CMM supply pipes, natural gas will be fed into gas treatment plant and consequently into the inlets of engines and into pre-chambers. As the main gas record blocks (figure 3) are after the venting stack, only combusted CMM will be accounted for.

¹⁵ At SU CHP, the equipment of the same type is installed, for substitution of main equipment for short period in case of breakdown or calibration- electricity and heat meters, CMM parameter metering equipment, pressure, temperature sensors, etc. These devices, being connected to or installed, are able to transfer all data to monitoring and control computer system. Equipment is also calibrated in fixed period by Donetsk Centre for Standardization, Metrology and Certification, Ivano-Frankovsk Centre for Standardization, Metrology and Certification, and Tyumen Centre for Centre for Standardization, Metrology and Certification.

SECTION D. Calculation of GHG emission reductions

D.1. Project emissions

The project emissions of the project are given by the following equation. The emissions for the use to capture and use methane PE_{ME} have not been taken as the energy use for the vacuum pumps are outside the project boundary (see section B.3 of PDD) and the annual electricity consumption of the gas filling station results in emission below 2,000 tCO₂e.

$$PE_y = PE_{MD} + PE_{UM}, \quad (5.)$$

where:

- PE_y — project emission in year y (tCO₂e)
- PE_{MD} — project emissions from methane destroyed (tCO₂e);
- PE_{UM} — project emissions from un-combusted methane (tCO₂e)

The project emissions from methane destroyed

The project emissions from methane destroyed are given by the equation below. Methane will be destroyed at SU CHP; thus, MD_{ELEC} and MD_{HEAT} are combined into MD_{CHP} . No flaring takes place so $MD_{FL} = 0$.

$$PE_{MD} = (MD_{CHP} + MD_{GAS}) \times (CEF_{CH4} + r \times CEF_{NMHC}), \quad (6.)$$

At $r = PC_{NMHC} / PC_{CH4}$

where:

- PE_{MD} — project emissions from CMM destroyed (tCO₂e);
- MD_{CHP} — methane destroyed in the SU CHP units by generation of heat and electricity (tCH₄);
- MD_{GAS} — methane destroyed by the vehicles supplied by the new gas filling stations (tCH₄);
- CEF_{CH4} — carbon emission factor for combusted methane (2.75 tCO₂e/tCH₄).
- CEF_{NMHC} — carbon emission factor for combusted non-methane hydrocarbons (the concentration varies, and, therefore, to be obtained through periodical analysis of captured methane) (tCO₂eq/tNMHC)¹⁶;
- r — relative proportion of NMHC compared with methane;
- PC_{CH4} — concentration (in mass) of methane in extracted gas (%);
- PC_{NMHC} — concentration (in mass) of NMHC in extracted gas (%).

The relative proportion of NMHC was monitored, and their concentration is less than 1%. Therefore, NMHC were excluded from calculation. So:

$$PE_{MD} = (MD_{CHP} + MD_{GAS}) \times CEF_{CH4}, \quad (7.)$$

Emissions of SU CHP units

The emissions of SU CHP units are given by following equations:

$$MD_{CHP} = MM_{CHP} \times Eff_{CHP}, \quad (8.)$$

where :

- MD_{CHP} — methane destroyed at heat and electricity generation (tCH₄);
- MM_{CHP} — measured methane consumed by SU CHP units (tCH₄);
- Eff_{CHP} — efficiency of methane destruction/ oxidation at CHP (taken as 99.5% of IPCC).

D.2. Emissions of gas utilization

Some methane will be supplied to the gas filling stations that will supply the vehicles. The emissions as a result are given by the following equations.

$$MD_{GAS} = MM_{GAS} \times Eff_{GAS}, \quad (9.)$$

where:

- MD_{GAS} — methane destroyed by the vehicles supplied by the new AGFCPs (tCH₄);

¹⁶ At the moment, non-methane hydrocarbons are not included in calculation because of concentration less than 1%. Their concentration is checked quarterly with laboratory analyses. In case of concentration more than 1%, it will be considered in calculations.

- MM_{GAS} — methane measured supplied to vehicles supplied by new AGFCPs (tCH₄);
- Eff_{GAS} — overall efficiency of methane destruction/ oxidation through gas grid to various combustion end uses, combining fugitive emissions from the gas grid and combustion efficiency at end user (taken as 98.5% of IPCC).

Emissions from un-combusted methane.

$$PE_{UM} = GWP_{CH4} \times (MM_{CHP} \times (1 - Eff_{CHP}) + MM_{GAS} \times (1 - Eff_{GAS})), \quad (10.)$$

where:

- PE_{UM} — project emissions from un-combusted methane (tCO₂e);
- GWP_{CH4} — global warming potential of methane (21 tCO₂e/tCH₄);
- MM_{CHP} — methane consumed by SU CHP units (tCH₄);
- Eff_{CHP} — efficiency of methane destruction in SU CHP (taken as 99.5% of IPCC);
- MM_{GAS} — methane measured consumed as a fuel for vehicle fuelling at new AGFCPs (tCH₄);
- Eff_{GAS} — efficiency of methane destruction in vehicle usage (taken as 98.5% of IPCC).

D.3.1. Project emissions:

| Year | [tCO ₂ e/year] | |
|-------------------------------|---------------------------|--------|
| Total: 01.01.2011– 31.05.2011 | [tCO ₂ e] | 44 331 |

Table 12: Project emissions

D.3.2. Baseline emissions:

The baseline emissions are given by following equation. There is no destruction of methane in baseline scenario at the mine, $BE_{MD,y} = 0$

$$BE_y = BE_{MR,y} + BE_{Use,y}, \quad (11.)$$

where:

- BE_y — baseline emissions in year y (tCO₂e);
- $BE_{MR,y}$ — baseline emissions from release of methane into the atmosphere that are avoided by the project activity in year y (tCO₂e);
- $BE_{Use,y}$ — baseline emissions from the generation of electricity, heat replaced by the project activity in year y (tCO₂e).

Baseline emissions of methane avoided by the project activity.

As there is neither CBM (coal bed methane) nor CMM (coal mine methane) at the mine, the emissions equal the amount of post-mining CMM captured in the project activity that is sent to SU CHP and AGFCPs.

$$BE_{MR,y} = GWP_{CH4} \times (CMM_{PJ,CHP,y} + CMM_{PJ,GAS,y}), \quad (12.)$$

where :

- $CMM_{PJ,CHP,y}$ — post-mining CMM captured, sent to and destroyed in the SU CHP in the project activity in year y (tCH₄);
- $CMM_{PJ,GAS,y}$ — pre-mining CMM captured, supplied to the net gas filling stations and destroyed by the vehicles in the project activity in year y (tCH₄);
- GWP_{CH4} — global warming potential for methane (= 21 tCO₂e/tCH₄).

Baseline emissions as result of electricity and heat generation, and vehicle fuel by the project activity

As there is only post-mining CMM involved the baseline emissions are given in the following equation:

$$B_{Use,y} = BE_{Use,el,y} + BE_{Use,heat,y} + BE_{Use,gas}, \quad (13.)$$

where:

- $BE_{Use,y}$ — potential total baseline emissions from the generation of electricity, heat, and vehicle fuels replaced by the project activity in year y (tCO₂);
- $BE_{Use,el,y}$ — total baseline emissions from the generation of electricity, replaced by the project activity in year y (tCO₂);

- $BE_{Use,heat,y}$ — total baseline emissions from the generation of heat, replaced by the project activity in year y (tCO₂);
- $BE_{Use,gas}$ — total baseline emissions of vehicle fuels, replaced by the project activity in year y (tCO₂e).

Baseline emissions of replacement of electricity generation

Baseline emissions of replacement of electricity generation by the project activity are given by two equations. If net electricity amount supplied under project by SU CHP is less than total amount of electricity consumed by the mine for the year, the baseline emissions will be following:

$$BE_{Use,el,y} = GEN_{CHP,y} \times EF_{grid,reduced,y} \quad (14.)$$

If net electricity amount supplied under project by SU CHP is greater than total amount of electricity consumed by the mine for the year (i.e. the electricity will be fed into grid), the baseline emissions will be following:

$$BE_{Use,el,y} = (GEN_{CHP,y} - EL_{Consumed,y}) \times EF_{grid,produced,y} + EL_{Consumed,y} \times EF_{grid,reduced,y} \quad (15.)$$

where:

- $BE_{Use,el,y}$ — total baseline emissions from the generation of electricity, replaced by the project activity in year y (tCO₂);
- $GEN_{CHP,y}$ — net electricity supplied by the project activity of the SU CHP units (MWh);
- $EF_{grid,produced,y}$ — emission factor of electricity of replaced grid electricity generation by the project activity in year y (tCO₂/MWh);
- $EL_{Consumed,y}$ — net electricity consumed by mine on-site in year y (MWh);
- $EF_{grid,reduced,y}$ — emissions factor for electricity of replaced on-site electricity consumption by the project activity (tCO₂/MWh)

For this monitoring period, the net electricity supplied under project by SU CHP is less than net electricity consumed (see section B.1.2). Therefore, formula 14 was used.

Baseline emission of replacement of heat

Heat produced by CHP supplies Vostochnaya site. Baseline emissions are given by following equation:

$$BE_{Use,Heat,y} = HEAT_{cons,vost,y} \times EF_{Heat,vost,y} \quad (16.)$$

where:

- $HEAT_{cons,vost,y}$ — heat consumed at Vostochnaya site, supplied by the project activity in year y (GJ);
- $EF_{Heat,vost,y}$ — emission factor for heat at Vostochnaya site in the baseline scenario (tCO₂/GJ).

Baseline emissions of replacement of vehicle fuels

The baseline emissions of the replacement of vehicle fuel by the project activity are given by the following equation:

$$BE_{Use,Gas} = VFUEL_y \times EF_v \quad (17.)$$

where:

- $VFUEL_y$ — vehicle fuel provided by the project activity (GJ);
- EF_v — emission factor for vehicle operation replaced by the project activity (tCO₂/GJ).

Emission factor for vehicle fuels

Emission factor for vehicle fuel is given by following equation:

$$EF_V = \frac{EF_{cos\lambda}}{Eff_V} \times \frac{44}{12} \times \frac{1TJ}{1000GJ} \quad (18.)$$

where:

- EF_v — emission factor for vehicle fuel replaced by the project activity (tCO₂/GJ);

- $EF_{cos\lambda}$ — emission factors for CO₂ four fuels used for vehicle operation replaced by the project activity (tCO₂/GJ);
- Eff_v — efficiency of vehicle motors (%);
- $44/12$ — carbon to Carbon Dioxide conversion factor;
- $1/1000$ — TJ to GJ conversion factor.

| Year | [tCO ₂ e/year] | |
|-------------------------------|---------------------------|---------|
| Total: 01.01.2011– 31.05.2011 | [tCO ₂ e] | 418 470 |

Table 13: Baseline emissions

D.3.3. Leakages:

Not Applicable

D.3.4. Emission reductions summary in monitoring period:

| Year | [tCO ₂ e/year] | |
|-------------------------------|---------------------------|---------|
| Total: 01.01.2011– 31.05.2011 | [tCO ₂ e] | 374 139 |

Table 14: Emission reductions

JI MONITORING REPORT

Monitoring Report #10 “Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko” page 39

ANNEX I

Gas sample analysis – 1st quarter 2011¹⁷

APPROVED

P.S.Pashkovskiy
First Director Deputy
Science Activity
Dr. Sc.
Respirator Mining Rescue
Scientific and Production
Enterprise,
< signature >
Seal
March 03, 2011

Percentage of matters in samples of gas taken on 02.03.11 at Lease Enterprise Mine named after A.F. Zasyadko

| Main Components | Sampling Point | | | |
|--|-----------------------|--------------|------------------------|--------------|
| | Vacuum Pump Station-1 | | Vacuum Pump Station -2 | |
| | First group | Second group | First group | Second group |
| | Concentration, % | | Concentration, % | |
| Methane CH ₄ | 15,3 | 15,7 | 29,3 | 15,3 |
| Ethan C ₂ H ₆ | 0,08 | 0,04 | 0,7 | 0,08 |
| Propane C ₃ H ₈ | 0,04 | 0,06 | 0,06 | 0,04 |
| Butane C ₄ H ₁₀ | 0,008 | 0,005 | 0,005 | 0,008 |
| Pentane C ₅ H ₁₂ | 0,006 | n/a | 0,004 | 0,006 |
| Hexane C ₆ H ₁₄ | n/a | n/a | n/a | n/a |
| Carbon Oxide CO | n/a | n/a | n/a | n/a |
| Hydrogen H ₂ | n/a | n/a | n/a | n/a |
| Carbon Dioxide CO ₂ | 0,06 | 0,05 | 0,06 | 0,06 |
| Nitrogen N ₂ | 66,8 | 67,1 | 55,3 | 66,8 |
| Oxygen O ₂ | 16,9 | 16,1 | 13,1 | 16,9 |
| Argon Ar | 0,07 | 0,08 | 0,42 | 0,07 |
| Micro-Components | mg/Nm ³ | | | |
| Ammonia NH ₃ | 0,004 | 0,005 | n/a | 0,004 |
| Chlorine Cl ₂ | n/a | n/a | n/a | n/a |
| Fluorine F ₂ | n/a | n/a | n/a | n/a |
| hydrogen sulfide H ₂ S | 0,006 | 0,007 | n/a | 0,006 |
| Sulfide dioxide SO ₂ | n/a | n/a | n/a | n/a |
| Dust, mg/m ³ | <1 | <1 | <1 | <1 |
| Moisture, % | 100 | 100 | 100 | 100 |

VPS 1 (first group) includes first and VPS 2(second group) set combined in common degasification line.

* re-calculated per dry gas

Analysis person in charge

signed

V.K. Sokolov

¹⁷ Gas sampling analysis is performed by RESPIRATOR Scientific Research Institute for Mining Rescue and Fire Safety

JI MONITORING REPORT

APPROVED

P.S.Pashkovskiy
 First Director Deputy
 Science Activity
 Dr. Sc.
 Respirator Mining Rescue
 Scientific and Production
 Enterprise,
 < signature >
 Seal
 March 03, 2011

**Percentage of matters in fuel gas and ignition gas samples taken on 02.03.11
 at Lease Enterprise Mine named after A.F. Zasyadko**

| Main components | Fuel Gas, Concentration, % | Ignition Gas, Concentration, % |
|--|-------------------------------|-----------------------------------|
| Methane CH ₄ | 31,5 | 96,8 |
| Ethan C ₂ H ₆ | 0,25 | 0,53 |
| Propane C ₃ H ₈ | 0,07 | 0,08 |
| Butane C ₄ H ₁₀ | 0,04 | 0,006 |
| Pentane C ₅ H ₁₂ | 0,006 | 0,004 |
| Hexane C ₆ H ₁₄ | 0,0008 | 0,0008 |
| Carbon Oxide CO | 0,0005 | 0,006 |
| Hydrogen H ₂ | 0,06 | 0,05 |
| Carbon Dioxide CO ₂ | 0,05 | n/a |
| Nitrogen N ₂ | 53,5 | 1,6 |
| Oxygen O ₂ | 14,1 | 0,8 |
| Argon Ar | 0,28 | 0,11 |
| Micro-Components | mg/Nm³ | |
| Ammonia NH ₃ | 0,006 | n/a |
| Chlorine Cl ₂ | n/a | n/a |
| Fluorine F ₂ | n/a | n/a |
| Hydrogen sulfide H ₂ S | 0,004 | n/a |
| Sulfide dioxide SO ₂ | n/a | n/a |
| Dust, mg/m ³ | <1 | <1 |
| Moisture, % | 100 | 100 |

* re-calculated per dry gas

Analysis person in charge

signed

V.K. Sokolov

JI MONITORING REPORT

Gas sample analysis – 2nd quarter 2011

APPROVED

P.S.Pashkovskiy
 First Director Deputy
 Science Activity
 Dr. Sc.
 Respirator Mining Rescue
 Scientific and Production
 Enterprise,
 < signature >
 Seal
 May 16, 2011

**Percentage of matters in samples of gas taken on 10.05.11
 at Lease Enterprise Mine named after A.F.Zasyadko**

| Main Components | Sampling Point | | | |
|--|--------------------------|--------------|------------------------|--------------|
| | Vacuum Pump Station-1 | | Vacuum Pump Station -2 | |
| | First group | Second group | First group | Second group |
| | Concentration, % | | Concentration, % | |
| Methane CH ₄ | 14,7 | 19,3 | 40,3 | 14,7 |
| Ethan C ₂ H ₆ | 0,07 | 0,05 | 0,6 | 0,07 |
| Propane C ₃ H ₈ | 0,06 | 0,04 | 0,05 | 0,06 |
| Butane C ₄ H ₁₀ | 0,007 | 0,006 | 0,006 | 0,007 |
| Pentane C ₅ H ₁₂ | 0,005 | n/a | 0,005 | 0,005 |
| Hexane C ₆ H ₁₄ | n/a | n/a | n/a | n/a |
| Carbon Oxide CO | n/a | n/a | n/a | n/a |
| Hydrogen H ₂ | n/a | n/a | n/a | n/a |
| Carbon Dioxide CO ₂ | 0,07 | 0,06 | 0,05 | 0,07 |
| Nitrogen N ₂ | 67,8 | 64,8 | 46,6 | 67,8 |
| Oxygen O ₂ | 17,3 | 13,8 | 11,2 | 17,3 |
| Argon Ar | 0,08 | 0,07 | 0,32 | 0,08 |
| Micro-Components | mg/Nm³ | | | |
| Ammonia NH ₃ | 0,005 | 0,004 | n/a | 0,005 |
| Chlorine Cl ₂ | n/a | n/a | n/a | n/a |
| Fluorine F ₂ | n/a | n/a | n/a | n/a |
| hydrogen sulfide H ₂ S | 0,007 | 0,006 | n/a | 0,007 |
| Sulfide dioxide SO ₂ | n/a | n/a | n/a | n/a |
| Dust, mg/m ³ | <1 | <1 | <1 | <1 |
| Moisture, % | 100 | 100 | 100 | 100 |

VPS 1 (first group) includes first and VPS 2(second group) set combined in common degasification line.

* re-calculated per dry gas

Analysis person in charge

signed

V.K. Sokolov

JI MONITORING REPORT

APPROVED

P.S.Pashkovskiy
 First Director Deputy
 Science Activity
 Dr. Sc.
 Respirator Mining Rescue
 Scientific and Production
 Enterprise,
 < signature >
 Seal
 May 16, 2011

**Percentage of matters in samples of gas taken on 10.05.11
 at Lease Enterprise Mine named after A.F.Zasyadko**

| Main components | Fuel Gas, Concentration, % | Ignition Gas, Concentration, % |
|--|-------------------------------|-----------------------------------|
| Methane CH ₄ | 32,6 | 97,2 |
| Ethan C ₂ H ₆ | 0,22 | 0,49 |
| Propane C ₃ H ₈ | 0,06 | 0,07 |
| Butane C ₄ H ₁₀ | 0,04 | 0,005 |
| Pentane C ₅ H ₁₂ | 0,005 | 0,005 |
| Hexane C ₆ H ₁₄ | 0,0007 | 0,0007 |
| Carbon Oxide CO | 0,0005 | 0,007 |
| Hydrogen H ₂ | 0,08 | 0,06 |
| Carbon Dioxide CO ₂ | 0,08 | n/a |
| Nitrogen N ₂ | 52,2 | 1,3 |
| Oxygen O ₂ | 12,6 | 0,3 |
| Argon Ar | 0,24 | 0,7 |
| Micro-Components | mg/Nm³ | |
| Ammonia NH ₃ | 0,007 | n/a |
| Chlorine Cl ₂ | n/a | n/a |
| Fluorine F ₂ | n/a | n/a |
| Hydrogen sulfide H ₂ S | 0,006 | n/a |
| Sulfide dioxide SO ₂ | n/a | n/a |
| Dust, mg/m ³ | <1 | <1 |
| Moisture, % | 100 | 100 |

* re-calculated per dry gas

Analysis person in charge

signed

V.K. Sokolov