

## **THIRD PERIODIC ANNUAL JI MONITORING REPORT**

---

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”  
Page 1

## **THIRD PERIODIC ANNUAL JI MONITORING REPORT**

### **CONTENTS**

- A. General project activity and monitoring information
- B. Key monitoring activities
- C. Quality assurance and quality control measures
- D. Calculation of GHG emission reductions

Annex 1: Definitions and acronyms

### SECTION A. General Project activity information

#### A.1 Title of the project activity:

Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox” Plant”

Sectoral scope: 1. Energy industries (renewable / non-renewable sources)

Date: 14 September 2012

Version: 1.0

#### A.2. JI registration number:

ITL number: UA2000026

#### A.3. Short description of the project activity:

The concept of the project is generation of electricity onsite to partially cover own needs; as well as to use COG in a more efficient way. For this purpose, energy of steam which, in the absence of the project, was desuperheated in PRDS (pressure-reducing and desuperheating stations) which were used for correction of parameters of steam. The project foresees using of this superheated steam in the two 6 MWe turbines instead of PRDS. Therefore, additional electricity will be generated and consumed onsite.

#### A.4. Monitoring period:

- Monitoring period starting date: 01/04/2011.
- Monitoring period closing date .31/08/2012<sup>1</sup>.

#### A.5. Methodology applied to the project activity (incl. version number):

The JI specific approach is used for the monitoring of emission reductions.

##### A.5.1. Baseline methodology:

The main principles of the JI specific approach can be described by the following:

1. Setting of the baseline should be based on real data (project scenario), obtained during the years before and after the project realization.
2. Estimated values of the key parameters under the project activity should be based on the project owner’s forecasts.
3. The proposed project should concern electricity generation only as a part of combined heat and power production cycle.
4. The proposed project should have no influence on the COG production level. Therefore, amount of COG for the project scenario and for the baseline scenario can be assumed to be the same for each year.
5. In general, proposed project should have no influence on technological heat/steam demand level. Both turbines under the project can be considered as substitutions of the PRDS units that were

---

<sup>1</sup> Both days are included.

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 3

used for the steam parameters correction. However, some differences can be considered in heat generation level due to principle of operation of the condensing turbine, as appropriate.

6. All significant leakages should be taken into consideration.
7. The project implementation can result in an increase in electricity consumption due to the installation of the new equipment or modernization of the existing one. However, this electricity can be considered as carbon neutral because it is generated from the waste heat.

### A.5.2. Monitoring methodology:

The reduction of GHG emissions due to additional electricity should be generated with the same level of heat production with respect to the baseline scenario. Therefore, the amount of emission reductions can be calculated based on the monitoring data for the electricity generated by the project.

The baseline emissions will be calculated based on the following inputs:

1. All electricity generated by the project from the COG is carbon neutral;
2. Electricity generated by the project from the COG and consumed by ZCP’s auxiliaries applies an Emission Factor (EF) of:

*CO<sub>2</sub> emission factor for electricity consumed by the project activity in period y* is accepted by the DFP and is based on actual power plants data according with *Calculation methodology for specific carbon dioxide emissions from electric energy production at thermal power plants and its consumption, National Environmental Investment Agency of Ukraine (NEIA), 2011*<sup>11</sup>. This methodology and the resulting specific carbon dioxide emissions have been developed by the DFP of Ukraine for the application in JI projects. Estimated specific carbon dioxide emissions for the years 2011 and 2012 are available<sup>12</sup>. It is approved that actual ex-post emission factors will be calculated and published every year for the previous year before the 1<sup>st</sup> of March. For ex-ante estimations in this project design document the most recent available value of specific carbon dioxide emissions is used for the whole estimation period. Ex-ante value of specific carbon dioxide emissions will be used if available for the calculation of emission reductions. In case this value is not available the most recent available value will be used instead.

The proposed CHP does not require any additional COG cleaning before fuelling the boiler, so there is no consumption of electricity for cleaning of COG. Additional electricity will be consumed by new equipment installed within the limits of the proposed CHP during operation (generator). This electricity is carbon neutral, because CHP will be fuelled by COG, which is flared and burnt in the existing boiler houses at the moment. However, auxiliary electricity consumption would not occur in the absence of the proposed project, so it needs to be substituted from the amount of electricity generated by new CHP.

In accordance with the PDD the only leakage that can take place is the additional consumption of fuel at site of the external consumers, to cover the lack of COG which had been delivered, and now is used for condensing turbine.

Taking into account the information given above, The following parameters are monitored:

1. Amount of electricity, generated by new turbines under the project activity
2. Amount of electricity consumed by project equipment

---

<sup>11</sup> <http://www.neia.gov.ua/nature/doccatalog/document?id=125381>

<sup>12</sup> <http://www.neia.gov.ua/nature/doccatalog/document?id=127498>

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”  
Page 4

3. Amount of COG, which would not be supplied to external consumers due to the project activity. This value can be calculated by the difference between steam input and steam output amounts of condensing turbine, in accordance with the project conditions.
4. Amount of other fossil fuel have been combusted during the monitoring period, if any. This parameter was not included into the tables D.1.2.1 and D.1.3.1 as well as there is no reflection of this parameter in any formulas of the MR, because everything depends on fossil fuel type. For every monitoring period AIE have to find out if any fossil fuel have been combusted in mixture with COG. In this case relevant emissions have to be calculated using IPCC default factors and relevant NCV.

### A.6. Status of implementation including time table for major project parts:

As it was planned, the first turbine was installed on the 14<sup>th</sup> of February 2008. Installation of the second turbine was postponed from the planned date (March 2010) due to lack of financing. Now all assembling works are finished and turbine was put into operation in June 2010.

| Activity                            | Commissioning date in accordance with PDD | Actual commissioning date |
|-------------------------------------|---|---------------------------|
| Commissioning of the first turbine  | 2008                                      | March 2008                |
| Commissioning of the second turbine | March 2010                                | June 2010                 |

*Table 1: Implementation plan*

### A.7. Intended deviations or revisions to the determined PDD:

As it was mentioned above, implementation of the second turbine was postponed from the planned date (March 2010) due to lack of financing. Now all assembling works are finished and turbine was completely put into operation in June 2010.

Monitored amount of emissions reductions (ER) differs from the one expected in PDD for the respective period stated in A.4. As shown in the table below:

| Parameter  | 2011*  | 2012** |
|--|--------|--------|
| ER in this report in tonnes of CO <sub>2</sub> equivalent        | 43481  | 39172  |
| ER in determined PDD in tonnes of CO <sub>2</sub> equivalent *** | 48 611 | 48 611 |

*Table 1: Monitored amount of ERUs and expected in PDD*

\* Period from 01.04.2011 till 31.12.2011. Hereinafter in this report in tables values for 2011 are referring to this period

\*\* Period from 01.01.2012 till 31.08.2012. Hereinafter in this report in tables values for 2012 are referring to this period

\*\*\* Recalculated for respective monitoring period in this report.

The differences are considered significant and can be explained by the following:

- The estimates in the PDD were based on forecasted data for amount of COG which is burn in boiler for steam production. Production of COG depends on level production of cokes, which in turn depends on demand in the energy market.

### A.8. Intended deviations or revisions to the determined monitoring plan:

According to the PDD electricity generated by the project from the COG and consumed by ZCP's auxiliaries apply an Emission Factor (EF) of 0.896 tCO<sub>2</sub>/MWh as a project reducing electricity consumption from the grid. The emission factor for the Ukrainian electricity grid, developed by Global Carbon B.V., determined by

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

---

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”  
Page 5

TUV SUD and final determined by the JISC, will be used for the baseline emissions calculation. At the time of determination, it was the most accurate Emission Factor for electricity production in Ukraine.

In 2011 the National Environmental Investment Agency of Ukraine issued Order #75<sup>2</sup>, which had set new Emission Factors for electricity production. New emission factor based on recent studies of fuel consumption for electricity production in Ukraine. Therefore, in this monitoring report is used new Emission Factor.

### **A.9. Changes since last verification:**

Since the last inspection has been established the condensing turbine #2. According to the approved monitoring plan, leakages are a result of this unit. For more information see Section B.

### **A.10. Person(s) responsible for the preparation and submission of the monitoring report:**

OJSC “ZaporozhCox”

- Dmytro Morozov, Head of investment department  
Global Carbon B.V.
- Dmytro Kosolukin, JI Consultant

### **A.11. Person(s) responsible for the checking and approval of the monitoring report:**

OJSC “ZaporozhCox”

- Musa Magomedov, General Director  
Global Carbon B.V.
- Denis Prusakov, Team Leader JI Consultants

---

<sup>2</sup> <http://document.ua/pro-zatverdzhennja-pokaznikiv-pitomih-vikidiv-dvookisu-vugle-doc65115.html> (last reference - 14.09.2012)

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

---

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 6

### **SECTION B. Key monitoring activities according to the monitoring plan for the monitoring period stated in A.4.**

For the monitoring period stated in A.4. the following parameters have to be collected and registered:

#### **1. Electricity generated by the new turbines № 1 and № 2.**

This parameter is metered with a specialized meters “Alpha A1140” (for more information please see Table B.1.2). The meter is situated next to current transformers. Readings are registered automatically and the results are going to the control panel. After that these results are loaded to the database. Moreover, once per shift the electrician writes the meter readings into the log book. These data are forwarded to the head of energy department to be recalculated (summarized). A summary for each calendar month is sent to the Chief Electrician. The annual reports are based on these monthly reports.

#### **2. Electricity consumed by the project equipment.**

For metering of this parameter separate meters “Energiya-9” and “Alpha A1140” are used (for more information please see Table B.1.2). These meters can work in parallel or sequentially, depending on situation. The devices are located on several current inputs, next to current transformers. Readings are registering automatically and results are transmitted to the control panel. After that they are sent to the database. Moreover, once per shift the electrician writes down the meter readings into the log book. These data are going to the head of energy department to be recalculated (summarized). Summary for the month is sent to the Chief Electrician. Monthly and annual reports are based on these data.

#### **3. Amount of COG, which would not be supplied to external consumers due to the project activity.**

This value can be calculated, subject to project conditions. There is a difference between steam input and steam output amounts of condensing turbine #2 calculated using the thermal equivalent of steam. Special device in the Automatic system for technological process control (ASTPC) will measure temperature, pressure and flow of steam. ASTPC is used for registering, transforming into heat equivalent and storing the data simultaneously. The operator prints the daily technical reports and sends them to the superintendent of the boiler-turbine shop. At the same time, these data are fed to chief power engineering specialist, which are summed up and form the monthly and annual reports.

Also, in accordance with determined monitoring plan, it have to be checked if other fossil fuel source was used simultaneously with COG during monitoring period.

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

---

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 7

### **B.1. Monitoring equipment types**

1. Electricity meters “Alpha A1140” and “Alpha A1800”
2. Electricity meters “Energiya-9” ver. STK3
3. Temperature sensors “THK-1-1”
4. Pressure sensors “Metran 100”
5. Flow of steam sensors “Metran 100”

### THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 8

**B.1.2. Table providing information on the equipment used (incl. manufacturer, type, serial number, date of installation, date of last calibration, information to specific uncertainty, need for changes and replacements):**

| Meter ID number | Parameter name                                  | Units | Meter name           | Serial number | Accuracy index | Date of installation | The last check date | The next check date | Notes   |
|-----------------|---|-------|----------------------|---------------|----------------|----------------------|---------------------|---------------------|---|
| 1               | Electricity generated by the new turbine No 1   | kWh   | Alpha A1140          | 05002014      | 1              | 2008                 | 14.04.2008          | 14.04.2014          | 10.11.08 this meter was installed instead of “Energiya -9”, serial number 37017 |
| 2               | Electricity consumed by the new turbine № 1     | kWh   | Energiya-9 ver. STK3 | 26711         | 0.2%           | 2007                 | September 2009      | September 2015      |   |
| 3               | Electricity consumed by the new turbine №1      | kWh   | Alpha A1140          | 05002024      | 1              | 2008                 | 14/04/2008          | 14/04/2014          |   |
| 4               | Electricity generated by the new turbine № 2    | kWh   | Alpha A1800          | 01191079      | 1              | 2008                 | 12/11/2008          | 12/11/2014          |   |
| 5               | Electricity consumed by the new turbine № 2     | kWh   | Energiya-9 ver. STK3 | 50111         | 0.2%           | 2008                 | 10/07/2009          | 10/07/2015          |   |
| 6               | Electricity consumed by the new turbine № 2     | kWh   | Energiya-9 ver. STK3 | 19467         | 0.2%           | 2009                 | 23/02/2009          | 23/02/2015          |   |
| 7               | Input steam temperature in the new turbine № 2  | °C    | THK-1-1              | 336           | 0.5%           | 2010                 | 05/04/2011          | 05/04/2012          | It needs checking up  |
| 8               | Output steam temperature in the new turbine № 2 | °C    | THK-1-1              | 2688          | 0.5%           | 2010                 | 05/04/2011          | 05/04/2012          | It needs checking up  |
| 9               | Input steam pressure in the new turbine № 2     | kPa   | Metran 100           | 459619        | 0.5%           | 2010                 | 21/04/2011          | 21/04/2012          | It needs checking up  |
| 10              | Output steam pressure in the new turbine № 2    | kPa   | Metran 100           | 460897        | 0.5%           | 2010                 | 21/04/2011          | 21/04/2012          | It needs checking up  |
| 11              | Input flow of steam in the new turbine № 2      | t/h   | Metran 100           | 173372        | 0.5%           | 2010                 | 21/04/2011          | 21/04/2012          | It needs checking up  |
| 12              | Output flow of steam in                         | t/h   | Metran 100           | 412710        | 0.5%           | 2010                 | 21/04/2011          | 21/04/2012          | It needs checking up  |



### THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 9

| Meter ID number | Parameter name      | Units | Meter name | Serial number | Accuracy index | Date of installation | The last check date | The next check date | Notes |
|-----------------|---------------------|-------|------------|---------------|----------------|----------------------|---------------------|---------------------|-------|
|                 | the new turbine № 2 |       |            |               |                |                      |                     |                     |       |

*Table 3: Equipment used for monitoring activities*

#### B.1.3. Calibration procedures

The calibration interval for all types of electricity meters used at the plant is set by Ukrainian state committee for technical regulation and customer policy and cannot exceed 6 years.

For the meters:

| QA/QC procedures  | The body responsible to calibration and certification |
|---|---|
| Maximum calibration interval for the Alpha A1140 meter is equal to 16 years | State company „Zaporozhstandartmetrologiya”           |
| Maximum calibration interval for the Alpha A1800meter is equal to 12 years  | State company „Zaporozhstandartmetrologiya”           |
| Maximum calibration interval for the Energiya-9 meter is equal to 6 years   | State company „Zaporozhstandartmetrologiya”           |
| Maximum calibration interval for the THK-1-1 sensor is equal to 1 year      | State company „Zaporozhstandartmetrologiya”           |
| Maximum calibration interval for the Metran 100 sensor is equal to 1 year   | State company „Zaporozhstandartmetrologiya”           |
| Maximum calibration interval for the Metran 100 sensor is equal to 1 year   | State company „Zaporozhstandartmetrologiya”           |

*Table 4: Calibration procedure for project equipment*

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 10

### B.1.4. Involvement of Third Parties:

Checking and calibration of meters is usually performed by state company „Zaporozhstandartmetrologiya” or other company which possess necessary qualification, knowledge and equipment, if this is agreed with state company „Zaporozhstandartmetrologiya”.

### B.2. Data collection (accumulated data for the whole monitoring period):

Operational and management structure in accordance with Section D.3. in PDD:




Figure 1: Data collection

### THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 11

#### B.2.1. List of fixed default values and fixed ex-ante emission factors:

| <i>Data / Parameter</i> | <i>Data unit</i>      | <i>Description</i>   | <i>Data Source</i>  | <i>Value</i> | <i>Uncertainty level of data</i> |
|-------------------------|-----------------------|--|---|--------------|----------------------------------|
| $EF_{grid,y}$           | tCO <sub>2</sub> /MWh | Specific CO <sub>2</sub> emission factor for power generation at Ukrainian grid connected thermal power plants in 2011 and after | Order of the National Environmental Investment Agency of Ukraine № 75 from 12.05.2011                                     | 1.063        | Low                              |
| $EF_{NG}$               | kgCO <sub>2</sub> /GJ | Emission factor for natural gas  | 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Volume 2: Energy, Chapter 4: Fugitive Emissions, table. 1.4 | 56.1         | Low                              |

Table 5: Fixed parameters

|  |  |
|--|--|
| <b>Data/Parameter</b>  | $EF_{grid,y}$  |
| Data unit  | kgCO <sub>2</sub> /kWh = tCO <sub>2</sub> /MWh   |
| Description  | Specific CO <sub>2</sub> emission factor for power generation at Ukrainian grid connected thermal power plants   |
| Time of <u>determination/monitoring</u>  | Ex-ante according to the publicly available data   |
| Source of data (to be) used  | For 2011: <a href="http://www.neia.gov.ua/nature/doccatalog/document?id=127498">http://www.neia.gov.ua/nature/doccatalog/document?id=127498</a><br>For 2012: <a href="http://www.neia.gov.ua/nature/doccatalog/document?id=127498">http://www.neia.gov.ua/nature/doccatalog/document?id=127498</a> |
| Value of data applied  | 1.063 (for 2011)<br>1.063 (for 2012)   |
| Justification of the choice of data or description of measurement methods and procedures (to be) applied | This emission factors for Ukrainian electricity grid approved by the DFP of Ukraine.   |
| QA/QC procedures (to be) applied   | Check on the updates of the emission factor.   |
| Any comment  | In case this value is not available the most recent available value will be used instead   |

#### B.2.2. List of variables:

Baseline emissions variables to be monitored:

| ID (from PDD) | Parameter | Calculation method (Measured/Calculated/Estimated) | Unit | Comment | Meters used (as per B.1.2) | Data aggregation frequency |
|---------------|-----------|--|------|---------|----------------------------|----------------------------|
|---------------|-----------|--|------|---------|----------------------------|----------------------------|

### THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”  
Page 12

|            |   |  |     |  |            |   |
|------------|---|--|-----|--|------------|---|
| D.1.2.1.-1 | $EG_{CHP,Pr,y}$<br>Electricity generated under the project activity               | This value is obtained by direct measurement of electricity by the meter   | kWh | The data will be archived and kept for two years after the last transfer of ERUs from the project. | 1, 4       | Data are aggregated monthly and annual reports are prepared |
| D.1.2.1.-2 | $EC_{equip,Pr,y}$<br>Electricity consumed by the project equipment                | This value is obtained by direct measurement of electricity by the meter   | kWh | The data will be archived and kept for two years after the last transfer of ERUs from the project. | 2, 3, 5, 6 | Data are aggregated monthly and annual reports are prepared |
| D.1.3.1.-3 | $SG_{input}$<br>Heat equivalent of steam at the input of condensing turbine №2    | This value is obtained by automatically recalculating the values of temperature, flow and pressure of steam in heat equivalent of steam through Automatic system for technological process control (ASTPC) | GJ  | The data will be archived and kept for two years after the last transfer of ERUs from the project. | 7,9,11     | Data are aggregated monthly and annual reports are prepared |
| D.1.3.1.-4 | $SG_{output}$<br>Heat equivalent of steam at the output of condensing turbine № 2 | This value is obtained by automatically recalculating the values of temperature, flow and pressure of steam in heat equivalent of steam through Automatic system for technological process control (ASTPC) | GJ  | The data will be archived and kept for two years after the last transfer of ERUs from the project. | 8,10,12    | Data are aggregated monthly and annual reports are prepared |

Table 6: Monitored baseline emissions variables

#### B.2.3. Data concerning GHG emissions by sources of the project activity:

Not applicable.

#### B.2.4. Data concerning GHG emissions by sources of the baseline:

| Variable          | Description                                      | Units | Period   |          |           |
|-------------------|--|-------|----------|----------|-----------|
|                   |  |       | 2011     | 2012     | Total     |
| $EG_{CHP,Pr,y}$   | Electricity generated under the project activity | kWh   | 72432513 | 66086767 | 138519280 |
| $EC_{equip,Pr,y}$ | Electricity consumed by the project equipment    | kWh   | 3096000  | 2885787  | 5981787   |

|               |   |    |        |        |         |
|---------------|---|----|--------|--------|---------|
| $SG_{input}$  | Heat equivalent of steam at the input of condensing turbine № 2 | GJ | 538753 | 499298 | 1038051 |
| $SG_{output}$ | Heat equivalent of steam at the output of condensing turbine №2 | GJ | 0      | 0      | 0       |

Table 7: Data that were collected in the baseline scenario

### B.2.5.Data concerning leakage:

In accordance with the PDD the only leakage that can take place is the additional consumption of fuel at site of the external consumers, to cover the lack of COG which had been delivered, and now is used for condensing turbine. Formulas which describe these leakages are given in PDD, please see formulas B.1.6 – B.1.11.

Due to the principles of work of condensing turbine, there is a difference between steam input and steam output amounts. This difference describes the lack of fuel due to the leakages and can be calculated the following way:

$$Lack_{fuel,i,y} = SG_{input} - SG_{output} \text{ where} \quad (D.1.3)$$

$Lack_{fuel,i,y}$  - Difference between heat equivalents of steam input and steam output amounts, in the monitoring period  $y$ , GJ.;

$SG_{input}$  - Heat equivalent of steam before the condensing turbine, GJ;

$SG_{output}$  - Heat equivalent of steam after the condensing turbine, GJ;

Leakages due to extra natural gas combustion at site of external consumers can be calculated using following formula (in accordance with formula B.1.4):

$$LE_{CHP,y} = \frac{Lack_{fuel,i,y} \times EF_{NG}}{1000}, \text{ where} \quad (D.1.4)$$

$EF_{NG}$  - Emission factor for natural gas. In accordance with IPCC 2006<sup>3</sup>, this value is equal to 56.1 kg CO<sub>2</sub>/GJ.

1000 - Conversion factor needed to convert kg CO<sub>2</sub> in tCO<sub>2</sub>.

$y$  – monitoring period

### B.2.6.Data concerning environmental impacts:

Proposed project foresees the increase of COG combustion efficiency and, therefore, will improve the environmental conditions in the region. Proposed project does not create additional sources of emissions but can be considered to be a reason of some additional negative effects, such as noise and vibration. These effects can negatively influence working conditions of the staff. Certification of jobs held once every 5 years according to the procedure for attestation of working places on working conditions. As a result of these measurements the working condition cards for relevant workplaces are issued. Last certification was at 2008 year. To investigate this influence the district sanitation and epidemiological service (SES) makes the measurement periodically. If some parameters exceed the nominal permitted level, it is required to use means of individual protection by staff.

The following working condition cards were issued for turbine shop:

- Card No 30-11 “Head of turbine shop”;
- Card No 30-08 “Turbine operator”;

<sup>3</sup> [http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/2\\_Volume2/V2\\_1\\_Ch1\\_Introduction.pdf](http://www.ipcc-nggip.iges.or.jp/public/2006gl/pdf/2_Volume2/V2_1_Ch1_Introduction.pdf)

- Card No 30-09 “Turbine operator/man-on-foot”

### **B.3.Data processing and archiving (incl. software used):**

In normal regime the instant data concerning generation/consumption of electricity is displayed on the LCD display of electricity meters in cyclical order (in succession, one by one) with holding time equal to 6-8 sec.

Measurement data are registered by PCS (process control system). Electricity generation level measures by the PCS (feeder 114 «generator 1» and feeder 12 «generator 1» in the database of «Alpha CENTER<sup>4</sup>» software. Also log book is used to register these values manually as well as values concerning electricity consumption by project equipment.

During the process of collecting the data from the meter “Alpha CENTER” software makes the following calculations:

- Converting the interval values read from the meters (telemetric pulses) into the named (physical) units of electricity (kWh);
- Calculation of interval rate of electricity (in kWh).

All data achieved by “Alpha CENTER” software are collected and archived in the data base. There exists an IT department to proceed general maintenance of the IT equipment used on the plant. Monthly all data go through the archiving and backup procedures. This activity takes place with help of special organization “TRAFIC” which has a relevant contract with “ZaporozhCox”. “TRAFIC” company is also responsible for adjusting and correcting of the “Alpha CENTER” software on demand of ZaporoxhCox.

Accounting of electricity consumption for own needs is metered by four meters (Energiya-9 and Alfa1140) installed on the feeders No1, No9, No15, No16 . In normal regime these meters work in parallel, and their readings have to be summarized to get a total value.

In the frame of QMS (Quality Management System) ISO 9001 implemented at “ZaporozhCox”, the report “Report of the processes performance” is developed on monthly base. Among the parameter of this report is “Provision electricity generated onsite”. Therefore, data for the electricity production by the turbine are subject to internal auditing under ISO 9001.

Department of Chief Power Engineer provides all data needed to the working group by filling in the form 8.2.ZK01 “Measurement of the QMS processes”. Monthly reports are composed on the base of this form are transferred to the First Deputy General Director for revision. This procedure named “Analysis from the managing party”. If some parameters are considered as not satisfactory, the correction is prescribed under the procedure 8.5.2.ZK01 “Correction and preventative actions”. Annual reports which are based on the monthly reports have to be saved for at least 3 years.

### **B.4. Special event log:**

No special events have taken place during the current monitoring period.

Only the following fact requires attention. On 10 November 2008 the electricity meter relevant to electricity generation measurement was replaced. The meter “Energiya-9”, serial number 37017 was replaced with a

---

<sup>4</sup> Complex “Alpha CENTER” for measurement and calculations designed to measure electricity and power, as well as automatic collection, processing and storing collected information. The complex includes communication server, communication modules, installation DB core, modules of controlling system, client’s software (screen forms, diagrams, reports). For more information see <http://www.alphacenter.ru> .

## THIRD PERIODIC ANNUAL JI MONITORING REPORT

---

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”

Page 15

modern meter Alpha A1140, serial number 05002014. Before the replacement, readings were registered only in the log books. Due to this there is no possibility for artificial increase of electricity generation level. During the replacement works the turbine continued operation and generated electricity. This amount of electricity was not included in the ER calculation; that is conservative.

### SECTION C. Quality assurance and quality control measures

#### C.1. Documented procedures and management plan:

##### C.1.1. Roles and responsibilities:

In the framework of this project electricians and process engineers are responsible for the data registration from the relevant meters.

Electricians are responsible for the data registration from the electricity meters.

Process engineers are responsible for the data registration from the ASTPC.

Duty of Chief of the Heat and Power Department in the framework of this project lies in data processing and preparation of reports which are the main source for Monitoring Reports.

##### C.1.2. Trainings:

Existing staff got used for working in the turbine workshop after the relevant education provided in case of lack of qualification. Education was provided by equipment producers and specialized organizations.

#### C.2. Involvement of Third Parties:

Energogavtomatizatsiya ltd. was involved to provide trainings.

#### C.3. Internal audits and control measures:

Data relevant to the emission reduction calculation are registered daily in the log books. During the operation, there are minor variations in the electricity generation level that can be observed. Therefore, any measurement error can be easily identified, in case of values that significantly differ from the common (in case of equal conditions) are received.

Independently data is submitted and processed in the manufacturing department and the the heat and power department. These units submit the results to the department of planning. In case of differences data is checked and found out the cause.

#### C.4. Troubleshooting procedures:

In case of failure of any equipment which leads to impossibility to generate electricity, the turbine will be stopped until the malfunction is fixed. The turbines' work is under control of modern automatic systems. Any variation in electricity generation level will be registered by relevant meters.

If the main metering device fails, and there is no reserve metering device available, the monitoring report will use indirect data and evidence, but only if their applicability (data and evidence) is justifiably proven. Likely, a conservative approach will be used.



**SECTION D. Calculation of GHG emission reductions**

**D.1. Tables of formulas used:**

| Formula number from PDD | Formula  | Formula description  |
|-------------------------|--|--|
| (D.1.1)                 | $BE_y = EG_{net,Pr,y} \times EF_{grid,y}$                  | Baseline emissions calculation   |
| (D.1.2)                 | $EG_{net,Pr,y} = EG_{CHP,Pr,y} - EC_{equip,Pr,y}$          | Calculation of the net amount of electricity in the year y, generated by turbines under the project activity |
| (D.1.3)                 | $Lack_{fuel,i,y} = SG_{input} - SG_{output}$               | Calculation of difference between steam input and steam output amounts                                       |
| (D.1.4)                 | $LE_{CHP,y} = \frac{Lack_{fuel,i,y} \times EF_{NG}}{1000}$ | Calculation of leakages due to extra natural gas combustion at site of external consumers                    |
| (D.1.5)                 | $ER_y = BE_y - LE_{CHP,y}$                                 | Calculation of emission reductions   |

Table 8: Calculation formulas

Results of the emissions calculations above are presented in metric tons of carbon dioxide equivalent (t CO<sub>2</sub> equivalent). The metric ton of carbon dioxide equivalent is equal to the metric ton of carbon dioxide (tCO<sub>2</sub>). Therefore 1 t CO<sub>2</sub> equivalent = 1 t CO<sub>2</sub>.

**D.2. Description and justification of the uncertainties of measurements:**

Accuracy index of all meters used allows making measurements with sufficient level of uncertainty.

**D.3. GHG emissions reduction (in accordance with Section B.2 of this document):**

**D.3.1. Project emissions:**

In accordance with PDD there are no project emissions,

**D.3.2. Baseline emissions:**

Baseline Emissions can be calculated by the following formulas:

$$BE_y = EG_{net,Pr,y} \times EF_{grid,y} \quad \text{(Equation 1)}$$

$BE_y$  - Baseline emissions in the year y due to grid electricity consumption, t CO<sub>2</sub> equivalent;

$EG_{net,Pr,y}$  - Net amount of electricity in the year y, generated by turbines under the project activity (without electricity consumed by the project equipment), kWh.

$EF_{grid,y}$  - Emission factor for the electricity consumption from the grid in the monitoring period y.

$$EG_{net,Pr,y} = EG_{CHP,Pr,y} - EC_{equip,Pr,y} \quad \text{(Equation 2)}$$

$EG_{CHP,Pr,y}$  - Amount of electricity in the year y, generated by turbines under the project activity, kWh;

### THIRD PERIODIC ANNUAL JI MONITORING REPORT

“Utilization of coke gas with electricity generation by two 6 MWe CHP at “ZaporozhCox Plant”  
Page 18

$EC_{equip.Pr,y}$  - Amount of electricity consumed by equipment in the monitoring period  $y$ , installed under the project activity, kWh.

| Parameter          | Unit                                 | 2011  | 2012  | Total  |
|--------------------|--------------------------------------|-------|-------|--------|
| Baseline emissions | tonnes of CO <sub>2</sub> equivalent | 73705 | 67183 | 140888 |

Table 9: Baseline emissions

#### D.3.3. Leakage:

In accordance with the PDD the only leakage that can take place is the additional consumption of fuel at site of the external consumers, to cover the lack of COG supplied due to the principle of work of condensing turbine. In accordance with technical report turbine №2 was working in condensing mode of heating without selection during all monitoring period.

| Parameter | Unit                                 | 2011  | 2012  | Total |
|-----------|--------------------------------------|-------|-------|-------|
| Leakages  | tonnes of CO <sub>2</sub> equivalent | 30224 | 28011 | 58235 |

Table 10: Leakage

#### D.3.4. Summary of the emissions reductions during the monitoring period:

The annual emission reductions are calculated as follows:

$$ER_y = BE_y - LE_{CHP,y} \quad \text{(Equation 3)}$$

$ER_y$  - The annual emission reductions, t CO<sub>2</sub> equivalent.;

$BE_y$  - Baseline emissions in the monitoring period  $y$  due to grid electricity consumption, t CO<sub>2</sub> equivalent;

$LE_{CHP,y}$  - Leakages due to the project realization in the monitoring period  $y$ , t CO<sub>2</sub> equivalent.

| Parameter           | Unit                                 | 2011  | 2012  | Total |
|---------------------|--------------------------------------|-------|-------|-------|
| Emission reductions | tonnes of CO <sub>2</sub> equivalent | 43481 | 39172 | 82653 |

Table 11: Emission reductions

Annex 1

**Definitions and acronyms**

**Abbreviations and acronyms:**

|                 |   |
|-----------------|---|
| COG             | Coke oven gas                             |
| CO <sub>2</sub> | Carbon Dioxide                            |
| GHG             | Greenhouse gases                          |
| IPCC            | Intergovernmental panel on climate change |
| PDD             | Project design document                   |
| ERU             | Emission reduction units                  |

**Definitions:**

|                           |   |
|---------------------------|---|
| Baseline                  | The scenario that reasonably represents what would have happened to greenhouse gases in the absence of the proposed project, and covers emissions from all gases, sectors and source categories listed in Annex A of the Protocol and anthropogenic Removals by sinks, within the project boundary. |
| Emissions reductions      | Emissions reductions generated by a JI project that have not undergone a verification or determination process as specified under the JI guidelines, but are contracted for purchase.   |
| Greenhouse gas (GHG)      | A gas that contributes to climate change. The greenhouse gases included in the Kyoto Protocol are: carbon dioxide (CO <sub>2</sub> ), Methane (CH <sub>4</sub> ), Nitrous Oxide (N <sub>2</sub> O), Hydrofluorcarbons (HFCs), Perfluorcarbons (PFCs) and Sulphurhexafluoride (SF <sub>6</sub> ).    |
| Joint Implementation (JI) | Mechanism established under Article 6 of the Kyoto Protocol. JI provides Annex I countries or their companies the ability to jointly implement greenhouse gas emissions reduction or sequestration projects that generate Emissions Reduction Units.  |
| Monitoring plan           | Plan describing how monitoring of emission reductions will be undertaken. The monitoring plan forms a part of the Project Design Document (PDD).  |