

Benaiciai Wind Power Park Project

4th Monitoring Report

Monitoring period: 1 January 2010 to 31 December 2010

Version 2

02 August, 2011

Prepared by:



UAB RENERGA

KONCERNO „ACHEMOS GRUPĖ“ NARĖ

Table of contents

Introduction.....3

1. General project activity information.....3

2. Monitoring activities implemented.....4

3. Quality assurance and quality control measures.....7

4. Calculation of GHG emission reductions.....8

Annex I. Data on electricity supply to the grid.....10

Introduction

The purpose of this monitoring report is to calculate Greenhouse gas (GHG) emission reductions achieved by the Joint Implementation (JI) project Benaiciai Wind Power Project during the period from the 1st of January, 2010 to the 31st of December, 2010.

1. General project activity information

1.1. Title of the project activity

Benaiciai Wind Power Project

UNFCCC Joint Implementation (JI) reference number 0034

1.2. Short description of the project

The Project included installation of 6 wind power plants, each having a maximum capacity of 2.75 MW, and a transformer substation, at the Benaiciai wind power park, which is located in Kretinga district of Lithuania near villages Benaiciai and Zineliai. The total installed capacity is 16.5 MW. The wind power plants installed are of V-100 type, produced by Danish company Vestas.

The project generates electricity and supplies it to the national grid. The project reduces greenhouse gas emissions by partially substituting power production in other power plants in Lithuania that run on fossil fuel. The project also reduces emissions of other pollutants arising from burning of fossil fuel, such as SO₂ and NO_x. In addition, implementation of this project helps promoting renewable energy resources and stimulates their use.



Figure 1. Location of Benaiciai Wind Power Park

Benaiciai wind power park project is developed by:

UAB Renerga

Address: Jonalaukio k., Ruklos sen., LT-55296 Jonavos raj. Lithuania

Tel: +370 349 56575

Fax: +370 349 56046

Email: info@renerga.lt

Monitoring report prepared by:

UAB Renerga

Address: Jonalaukio k., Ruklos sen., LT-55296 Jonavos raj. Lithuania

Tel: +370 349 56575

Fax: +370 349 56046

Email: info@renerga.lt

1.3. Monitoring period

1st of January 2010 – 31st of December 2010

1.4. Implementation of the project

Table 1. Main milestones in project implementation

Milestone	Date
<i>UNFCCC JI procedures:</i>	
Project Design Document submitted to Accredited Independent Entity	27 October 2006
Letter of Approval from the Lithuanian Ministry of Environment as a legal and authorized representative of the Government of Lithuania received	4 July 2007
Final determination of the JI project	2 June 2008
<i>Construction and operation of wind power park:</i>	
Wind power park starts operating	11 December 2006

Benaiciai wind power project was developed by UAB Achema Hidrostotys. In April 2008, UAB Achema Hidrostotys was renamed into UAB Renerga. A letter from the Lithuanian Ministry of Environment was issued on 29 April 2008, which confirms that all the statements of the Letter of Approval concerning the Benaiciai wind power JI project are applicable to UAB Renerga.

1.5. Monitoring methodology applied

Monitoring plan for the Benaiciai wind power project was developed based on the PDD section D.

2. Monitoring activities implemented

2.1. Monitoring equipment and calibration procedures

Automatic energy meters were installed by AB Lietuvos Energija, national grid operator which buys electricity from the wind power park. The meters belong to AB Lietuvos Energija. They were manufactured by UAB Elgama, which also maintains them. They are calibrated once every 8 years.

Table 2. Monitoring equipment technical data

Position No.	T-101D	T-101
Meter type	EPQM 312.01.534	EPQS 113.09.04
Product No.	109160	379419
Check date	5 June 2006	21 July 2009
Breakdowns and other events	No	No

2.2. Data collection

2.2.1. Fixed values

Parameter	Default value	Description
EF _{LE}	0.626 tCO ₂ /MWh	Emission factor for power production at Lietuvos Elektrine

Emission factor for electricity production at AB Lietuvos Elektrine (Lithuanian Power Plant) (EF_{LE}) was estimated ex-ante, based on production of electric and thermal power, fuel consumption and production efficiency in AB Lietuvos Elektrine during a 4-year period from 2002 to 2005. In the integrated power network in Lithuania, AB Lietuvos Elektrine is the marginal plant: when the generators of electric power supply all quota and over-quota power to the integrated grid, the rest of the power demand is covered by the power produced at AB Lietuvos Elektrine. Therefore any additional power supply to the grid that comes from other sources displaces electricity generated at AB Lietuvos Elektrine.

The emission factor calculated based on fuel consumption from 2002 to 2005 is considered conservative, as AB Lietuvos Elektrine has been preparing to use higher share of orimulsion and decrease the share of natural gas, in an attempt to reduce dependence on single supplier of gas, Russia. An environmental upgrading project has been implemented at the power plant so that emissions of SO₂ and NO_x from burning of orimulsion would comply with the EU regulations. Lithuanian National Allocation Plan for 2008-2012 prepared under the EU Emissions Trading Scheme (http://ec.europa.eu/environment/climat/pdf/nap_lithuania_final.pdf, in Lithuanian language) states that it is anticipated that the average share of orimulsion will rise from 16.0% during 2002-2005 to 60.1% during 2008-2012. Even if a high share of 60.1% is not achieved, there is a definite trend of increase. As orimulsion has a higher CO₂ emission factor than natural gas, its higher share in the fuel mix drives up the combined emission factor for AB Lietuvos Elektrine.

2.2.2. Data on GHG emissions by sources of the project activity

The Project activity does not result in greenhouse gas emissions. Energy taken from the grid for the operation of the wind power park is subtracted from the energy supplied to the grid for the estimation of emission reductions (see data on the baseline below and Annex I).

2.2.3. Data on GHG emissions by sources of the baseline

Table 3. Information on key parameter monitored

Data / Parameter:	P_{WPP}
Data unit	MWh
Value of data	See Table 4 and Annex I
Description	Annual net power supply to the grid from Benaiciai ¹ wind power park
Source of data	Onsite power metering device and monthly power dispatch confirmation documents
Description of measurement methods and procedures applied	<p>A commercial onsite power metering device measures power supplied to the grid and power taken from the grid for the park’s internal purposes. Recorded data is stored in the memory of the metering device. The data is also automatically transferred via internet to AB Lietuvos Energija, which keeps records in their databases. Once a month, power dispatch confirmation documents, which list electricity bought from UAB Renerga and AB Lietuvos Energija, are signed between UAB Renerga and AB Lietuvos Energija.</p> <p>Energy for on-site use is taken from the grid when the park is not operational, i.e. UAB Renerga buys electricity from AB Lietuvos Energija</p> <p>Energy taken from the grid has to be subtracted from the energy supplied to the grid to get net electricity supplied to the grid, which will displace power production in AB Lietuvos Elektrine.</p> <p>Monthly values of net hourly electricity supply to the grid are given in the table below, and data, that it is based on, is given in Annex I.</p> <p>Benaiciai park substation during the shutdown period June - July has been extended an additional transformer and an additional Benaiciai-1 commercial accounting unit. It is noted that the successive connection of the park's accounting system and devices Benaiciai project remained without changes.</p>

Table 4. Data on net hourly electricity supplied by Benaiciai Wind Power Park to the grid in 2010:

Month	Net hourly electricity supplied to the grid, MWh
January	3.183,923
February	2.153,159
March	3.660,273
April	2.313,494
May	1.850,022
June	0,0
July	50,752
August	2.160,898
September	3.945,578
October	3.794,537
November	3.458,029
December	2.468,155
Total over the monitoring period	29.038,820

2.2.4. Data on leakage

¹ Laukzemes wind power-station – as a power producer in the integrated power network in Lithuania

No sources of leakage have been identified.


2.3. Special event log

No special events other than milestones listed in Table 1 occurred during 2010 that would affect monitoring activities or monitored data.

3. Quality assurance and quality control measures

Power supplied to the grid and taken from the grid is monitored by a commercial power metering device. The power metering device is calibrated. It is sealed and therefore operator of the wind power park is not able to intervene in the measurements. Once a month, an inspector from AB Lietuvos Energija together with the representative from UAB Renerga checks the readings of the power metering device and writes down supplied power and taken power quantity on the dispatch confirmation document which is then signed by both parties. Data for the purpose of calculating emission reductions is taken from these documents. As electricity supplied to the grid is the main parameter for both UAB Renerga and the buyer of electricity, additional quality assurance and quality control procedures are not necessary. The entire processes from raw data to report are given in the process flow diagram below.

Diagram 1. An information/Process flow diagram



4. Calculation of GHG emission reductions

4.1. Formulae used

The general equation for calculating emission reductions is as follows:

$$ER = BE - (PE + L) \tag{1}$$

Where:

- ER – Emission reductions, tCO₂e
- BE – Baseline emissions, tCO₂e
- PE – Project activity emissions, tCO₂e
- L – Leakage, tCO₂e

Baseline emissions are calculated using the following formula:

$$BE = P_{WPP} * EF_{LE} \tag{2}$$

Where:

- BE – project's baseline emissions, tCO₂e
- P_{WPP} – net hourly power supplied to the grid from Benaiciai wind power park, MWh
- EF_{LE} – emission factor for power production at AB Lietuvos Elektrine, determined ex ante (0.626 tCO₂/MWh)

Net hourly power supplied to the grid from Benaiciai wind power park are calculated using the following formula:

$$P_{WPP} = A - B \tag{3}$$

Where:

- P_{WPP} – net hourly power supplied to the grid from Benaiciai wind power park, MWh
- A – produced power, which bought from UAB Renerga, MWh
- B – consumed power, which bought from AB Lietuvos Energija, MWh

Project emissions are considered to be equal 0. Mostly renewable electricity generated on-site is used for on-site energy demand. When wind power plant does not work it uses energy from the grid but this electricity is taken into account in monitoring net hourly electricity supply to the grid and is reflected in the values of monthly net power supply to the grid. Therefore:

$$PE = 0 \tag{4}$$

No sources of leakage are identified:

$$L = 0 \tag{5}$$

Therefore emission reductions are calculated as baseline emissions:

$$ER = BE \tag{6}$$

4.2. GHG emission reductions

4.2.1. Project activity emissions

$$PE = 0$$

4.2.2. Baseline emissions

Baseline emissions are calculated using formula (2), based on monitored values on monthly net hourly electricity supply to the grid:

Month	Net hourly electricity supply to the grid, MWh	Emission reductions, tCO₂e
January	3.183,923	1.993,136
February	2.153,159	1.347,877
March	3.660,273	2.291,331
April	2.313,494	1.448,247
May	1.850,022	1.158,114
June	0,0	0
July	50,752	31,771
August	2.160,898	1.352,722
September	3.945,578	2.469,932
October	3.794,537	2.375,380
November	3.458,029	2.164,726
December	2.468,155	1.545,065
Total over the monitoring period	29.038,820	18.178,301

4.2.3. Leakage emissions

L = 0

4.2.4. Summary of emission reductions over the monitoring period

Variable	Value, tCO₂e
Project emissions	0
Baseline emissions	18,178
Leakage	0
Emission reductions	18,178

Annex I

Data on net hourly electricity supply to the grid, in MWh:

Month	Electricity bought from UAB Renerga, MWh	Electricity bought from AB Lietuvos Energija, MWh	Net hourly electricity supplied to the grid, MWh
	A	B	A-B*
January	3.196,291	12,368	3.183,923
February	2.163,068	9,909	2.153,159
March	3.664,682	4,409	3.660,273
April	2.325,151	11,657	2.313,494
May	1.859,463	9,441	1.850,022
June	0,0	0,0	0,0
July	55,362	4,610	50,752
August	2.171,186	10,288	2.160,898
September	3.976,202	30,624	3.945,578
October	3.820,970	26,433	3.794,537
November	3.484,958	26,929	3.458,029
December	2.478,465	10,310	2.468,155
Total over the monitoring period	29.195,798	156,978	29.038,820

* - Energy taken from the grid for on-site use has to be subtracted from the energy supplied to the grid in order to get net electricity supplied to the grid, which replaces electricity generated in AB Lietuvos Elektrine.