

MONITORING REPORT

JI0105 - CMM utilisation on the Joint Stock Company “Coal Company Krasnoarmeyskaya Zapadnaya № 1 Mine”

Monitoring Report 02

Monitoring period
01/01/2008 to 31/03/2010

Version 1a
7 April 2010

CONTENTS

- A. General project activity and monitoring information
- B. Key monitoring activities
- C. Quality assurance and quality control measures
- D. Calculation of GHG emission reductions

Annexes

Annex 1: Definitions and acronyms

Annex 2: Technical drawing

Annex 3: Energy and material flowchart including metering positions

SECTION A. General project activity information

A.1 Title of the project activity:

CMM utilisation on the Joint Stock Company "Coal Company Krasnoarmeyskaya Zapadnaya № 1 Mine"

A.2. JI registration number:

JI0105

A.3. Short description of the project activity:

In this project CMM, which has been sucked out of the active coal mine "Krasnoarmeyskaya-Zapadnaya № 1", has been utilised in a previous coal boiler, which has been upgraded with a CMM burning system. The methane has been burned to less harmful CO₂.

In this monitoring the gained emission reductions should be monitored for the purpose of the verification as Emission Reductions Units (ERU).

Table-1 Amount of methane utilised for heat generation

period	CH ₄ [m ³ /period]	Heat generated [MWh]
01/01/2008-31/12/2008	3.877.684	34.605
01/01/2009-31/12/2009	4.609.202	37.777
01/01/2010-31/03/2010	3.320.095	17.297
Total 2008-2010	11.806.981	89.679

A.4. Monitoring period:

Start date 01/01/2008

End date 31/03/2010

Start day and end day included.

A.5. Methodology applied to the project activity (incl. version number):

A.5.1. Baseline methodology:

The approved consolidated methodology ACM0008 / Version 03 "Consolidated baseline methodology for coal bed methane and coal mine methane capture and use for power (electrical or motive) and heat and/or destruction by flaring") has been used to identify the baseline scenario of the proposed JI project [ACM0008].

A.5.2. Monitoring methodology:

A monitoring plan provided by the "Approved consolidated baseline methodology ACM0008", Version 03, Sectoral Scope: 8 and 10, EB28 is applied to the project [ACM0008].

MONITORING REPORT FORM

Applicability requirements for the monitoring plan of the ACM008 methodology are identical to respective requirements of the baseline setting.

A.6. Status of implementation including time table for major project parts:

The project is approved as JI-project since 09/11/2009.
http://ji.unfccc.int/JI_Projects/DeterAndVerif/Verification/FinDet.html

Table-2 Status of Implementation

Unit: upgraded previously coal fired steam boiler at central shaft	
Manufacturer: Biysk Boiler Plant	
Type: KE-25-14KC	
Serial Number: 6827 (not visible)	
Inventar Number: 4022 (visible)	
Capacity: 25 t/h steam (approx. 25 MW)	
Activity	Status
year of construction	06/05/1986
last major overhaul	22/12/2002 - Ukrteploservis
Last inspection	12/09/2006 - Derzhpromnaglyad
Commission of upgrade	20/03/2003
Official completion of upgrade	31/03/2003
Start of initial operation, first tests	summer 2003
Start of operation	October 2003
Planned installation date [PDD]	October 2003

Ukrteploservice is a private company, which has been commissioned by the coal mine for service and maintenance of the boilers.
 Derzhpromnaglyad is a state owned controlling and supervising institute.

The installation of further units as stated in the PDD is delayed due to the Global Financial Crisis and should follow in 2010 and 2011.

Table-3 Installation plan [PDD]

unit	installation date	firing capacity	product
Central Shaft			
upgraded boiler	Oct 2003	25 MW	hot water
flare No: 1	Jan 2008	5 MW	methane destruction
flare No: 3	Mar 2008	5 MW	methane destruction
cogeneration units	Jul 2008	total of 48.8 MW	power and hot water
Degassing wells			
flare/pump No: 2	Jan 2008	5 MW	methane destruction
flare/pump No: 7	Apr 2008	5 MW	methane destruction
Air Shaft № 2			

MONITORING REPORT FORM

flares No: 4-6	Apr 2008	total of 15 MW	methane destruction
cogeneration units	Jun-Oct 2008	total of 67.5 MW	power and hot water
cogeneration units	Jan 2009	total of 30 MW	power and hot water

A.7. Intended deviations or revisions to the registered PDD:

In the PDD the start of operation of the boiler in October 2003 is given instead of the installation date. See Table-1 in A.6 for details.

A.8. Intended deviations or revisions to the registered monitoring plan:

The electronically measuring and data storing monitoring system has been implemented first in 2009 and started operation beginning with 12/09/2009, 8:00 AM. Before this date only handwritten data (journals) are available.

Method 1 – Handwritten data

All boiler data are recorded manually in a 15 min. cycle in a boiler operation journal. The journals are stored only for the last six months, so that the data are not available for the monitoring period. The available data have been recorded manually by the coal mine personnel in a separate CMM journal. The recording cycle is 12h (one time per shift). Since 01/09/2008 the CMM journal data are transferred regularly to Excel-sheets by Eco Alliance OOO.

The CMM flow has been recorded at operating conditions and has not been transferred to standard state conditions. The corrections can not be applied subsequently, because the necessary data for gas temperature and pressure have not been recorded. The resulting deviations are discussed in the <Possible sources of error> document. The heat produced by the project has not been measured but calculated using the utilised methane amount.

Method 2 –Electronically data

The electronically measuring and data storing monitoring system has been implemented as described in the PDD.

The monitoring procedures applied during the monitoring period are described in Annex 3.

A.9. Changes since last verification:

An electronically measuring and data storing monitoring system has been installed in September 2009 and started operation at 12/09/2009, 8:00 AM.

A.10. Person(s) responsible for the preparation and submission of the monitoring report:

Coal Company Krasnoarmeyskaya-Zapadnaya Nr.1 mine

- Anatoly Demchenko, Technical director

Carbon-TF B.V

- Adam Hadulla
- Karl Wöste, Senior Consultant

MONITORING REPORT FORM

SECTION B. Key monitoring activities according to the monitoring plan for the monitoring period stated in A.4.

B.1. Monitoring equipment:

B.1.2. Table providing information on the equipment used (incl. manufacturer, type, serial number, date of installation, date of last calibration, information to specific uncertainty, need for changes and replacements):

Table-4 Monitoring equipment

ID	Data	Method	Manufacturer	Classification	Serial number	Uncertainty level of data	Frequency of Measurement	Installation
1	CMM amount to boiler Method 1	Orifice (diaphragm) with pressure difference meter and continuous chart recorder				low	Continuous record period in journals 12 h	2003
1a		Orifice / diaphragm	Krasnoarmeysk Engineering Plant	(no documents)	none	Low	continuous	2003
1b		Pressure difference meter	VO "Promprylad" Ivano-Frankovsk	DM-3583M	26244	Low	continuous	2003
1c		Chart recorder		RP160-33	2034000	Low	continuous	2003
2a	CH ₄ concentration	Infrared measurement	POLITRON - Drager,	Gasanalizador	ARSK 0191	medium	Continuous record period in journals 12 h	2002
2b	CH ₄ concentration	interferometer	Azov optic-mechanics plant	SHI-12	*)	low	Control measurement	
2c	CH ₄ concentration	Infrared measurement	Woelke	Annovex System		low	for plausibility check only	
3	NMHC concentration	lab analysis				low	yearly	-

MONITORING REPORT FORM

4	CMM amount to boiler Method 2	Vortex flow meter	"Sibnefteavtomatika" IJSC, Tyumen, Russia	DRG.MZ-300	06136	low	continuous	Sep 2009
5	CMM pressure	Ceramic pressure pick-up	Siemens	SITRANS P Serie Z	AZB/W 5132862	low	continuous	Sep 2009
6	CMM temperature	PT-100	JSC "Tera", Chernigov	ТСПУ 1-3H Pt-100 0,5% 80Φ8	09124	low	continuous	Sep 2009
7	Steam amount to boiler Method 2	Vortex flow meter	"Sibnefteavtomatika" IJSC, Tyumen, Russia	DRG.MZ-200	06135	low	continuous	Sep 2009
8	Steam pressure	Ceramic pressure pick-up	Siemens	SITRANS P Serie Z	AZB/W 4124010	low	continuous	Sep 2009
9	Steam Temperature	PT-100	JSC "Tera", Chernigov	ТСПУ 1-3H Pt-100 0,5% 80Φ8	09125	low	continuous	Sep 2009

*) the coal mine posses more than 3000 units of the SHI-12 meter, which are mainly used as personal safety units; the units are handed over to the personnel at the beginning of the shift and taken back at the end of the shift, so that usually different units are used every shift

MONITORING REPORT FORM

B.1.3. Calibration procedures:

Table-5 Monitoring equipment

ID	Data	Uncertainty level of data (high/medium/low)	Calibration procedure	Last calibration	Calibrator
1a	Orifice / diaphragm	Unknown Set to 2.5% of FSV*)	none	none	none
1b	Pressure difference meter	1.5 % of FSV*)	Calibration made using procedures of Ukrkotloservice	yearly	Ukrkotloservice Donetsk
1c	Chart recorder	0.5% of FSV*) analog input 1.5% of FSV*) analog root extraction	Calibration made using procedures of Ukrkotloservice	yearly	Ukrkotloservice Donetsk
2a	Methane concentration Draeger Politron ***)	4% absolute error in the range below 40% LEL**) 10% relative error in the range above 40% LEL**)	Calibration made using procedures of Donetskderzhstandartmetrologiya.	07.08.2008	Donetsk-derzhstandartmetrologiya
2b	Methane concentration SHI-12	2.5 % of FSV*)	Calibration made using procedures of Donetskderzhstandartmetrologiya	yearly	Donetsk-derzhstandartmetrologiya
3	NMHC concentration	unknown	The approved laboratory is responsible for regular recalibrations of the system.	unknown	unknown
4	CMM amount to boiler Method 2	1.5% in the range: 0.1 V _{max} to 0.9 V _{max} *****)	Calibration made using procedures of the manufacturer.		Manufacturer
5	CMM pressure	0.5% of FSV*)	Calibration made using procedures of the manufacturer.		Manufacturer
6	CMM temperature	2.5% of FSV*)	Calibration made using procedures of the manufacturer.		Manufacturer
7	Steam amount to boiler Method 2	1.5% in the range: 0.1 V _{max} to 0.9 V _{max} *****)	Calibration made using procedures of the manufacturer.		Manufacturer
8	Steam pressure	0.5% of FSV*)	Calibration made using procedures of the manufacturer.		Manufacturer

MONITORING REPORT FORM

9	Steam Temperature	2.5% of FSV*)	Calibration made using procedures of the manufacturer.		Manufacturer
---	-------------------	---------------	--	--	--------------

*) FSV – full scale value, maximum range

***) LEL - lower explosion limit; LEL is equivalent to 5% methane in air; 40% LEL is equivalent to a concentration of 2% CH₄ in air.

****) The Draeger Politron is mainly a CH₄ detection and warning system, which is normally utilised for the determination of dangerous methane concentrations up to the lower explosion limit LEL, for the avoidance of explosions. The analyser is designed and optimized for the exact determination of low methane concentrations. Despite that the range of the meter can be extended to the range of 0-100% CH₄ according to the Draeger manual.

The conversion of the errors from LEL to % CH₄ in the gas mixture gives the following values:

Range	Range	Error	Error
< 40% LEL	< 2% CH ₄	4% absolute of LEL	0.2 % CH ₄ absolute
> 40% LEL	> 2% CH ₄	10% relative	Linear error increase starting with 0.2 % CH ₄ abs at 2% CH ₄ concentration Ending with 10% CH ₄ abs at 100% CH ₄

*****) The velocity is always in the specified range

B.1.4. Involvement of Third Parties:

- The lab analysis for the determination of the NMHC concentration has been done by the MakNII Institute
- The calibration of the flow meter has been done by Ukrkotloservice
- Eco-Alliance OOO supported the coal mine with the collecting of the monitoring data.
- Emissions-Trader ET GmbH has supervised the data for plausibility and completeness.

B.2. Data collection (accumulated data for the whole monitoring period):

B.2.1. List of fixed default values:

Table-6 List of ex-ante fixed values

ID number	Data variable	Source of data	Data unit	Comment
P19 Eff _{HEAT}	Efficiency of methane destruction / oxidation in heat plant	ACM0008 / IPCC	%	set at 99.5% (IPCC)
P23, B19 CEF _{CH4}	Carbon emission factor for combusted methane	ACM0008 / IPCC	t CO ₂ eq/t CH ₄	set at 2.75 t CO ₂ eq/t CH ₄
P28, B18 GWP _{CH4}	Global warming potential of methane	ACM0008 / IPCC	t CO ₂ eq/t CH ₄	set at 21

MONITORING REPORT FORM

B55 EF _{CO₂,Coal}	CO2 emission factor of fuel used for captive power or heat	IPCC 2006 1 Introduction Table 1.2	tCO ₂ /MWh	Set to 0.3406 tCO ₂ /MWh Using the value for "Other Bituminous Coal" of 94,600 kg CO ₂ /TJ
B57 Eff _{heat}	Energy efficiency of heat plant	Boiler pass	%	73.5 % old coal boiler 86 % upgraded boiler

B.2.2. List of variables:

Table-7 List of variables

ID number	Data variable	Source of data	Data unit	Comment
P1 PE _y	Project emissions in year y	monitored data	t CO _{2eq}	calculated using formulae from the PDD
P3 PE _{MD}	Project emissions from methane destroyed	monitored data	t CO _{2eq}	calculated using formulae from the PDD
P4 PE _{UM}	Project emissions from uncombusted methane	monitored data	t CO _{2eq}	calculated using formulae from the PDD
P17 MD _{HEAT}	Methane destroyed by heat generation	monitored data	t CH ₄	calculated using formulae from the PDD
P18 MM _{HEAT}	Methane sent to boiler	flow meter	t CH ₄	handwritten journals / electronically data
P24 CEF _{NMHC}	Carbon emission factor for combusted non methane hydrocarbons (various)	lab analysis	-	calculated if applicable
P25 PC _{CH4}	Concentration of methane in extracted gas	IR measurement	%	handwritten journals / electronically data
P26 PC _{NMHC}	NMHC concentration in coal mine gas	lab analysis	%	used to check if more than 1% of emissions and to calculate r
P27 r	Relative proportion of NMHC compared to methane	lab analysis	%	calculated if applicable, based on the lab analysis.
B1 BE _y	Baseline emissions in year y	monitored data	t CO _{2eq}	calculated using formulae from the PDD
B3 BE _{MR,y}	Baseline emissions from release of methane into the atmosphere in year y that is avoided by the project activity	monitored data	t CO _{2eq}	calculated using formulae from the PDD
B4 BE _{Use,y}	Baseline emissions from the production of power, heat or supply to gas grid replaced by the project activity in year y	monitored data	t CO _{2eq}	calculated using formulae from the PDD
B14 CMM _{PJ,y}	CMM captured and destroyed in the project activity in year y	flow meter	t CH ₄	equal to P17,MD _{HEAT}

MONITORING REPORT FORM

B47 HEAT _y	Heat generation by project	monitored data	MWh	calculated using P17 and B57 (method 1) measured using steam flow data (method 2)
--------------------------	----------------------------	----------------	-----	--

B.2.3. Data concerning GHG emissions by sources of the project activity

Table-8 GHG emissions by sources of the project activity

ID number	Data variable	Source of data	Data unit	Comment
P18 MM _{HEAT}	Methane sent to boiler	flow meters	t CH ₄	handwritten journals / electronically data
P25 PC _{CH4}	Concentration of methane in extracted gas	IR measurement	%	handwritten journals / electronically data

B.2.4. Data concerning GHG emissions by sources of the baseline

Table-9 GHG emissions by sources of the baseline

ID number	Data variable	Source of data	Data unit	Comment
B14 CMM _{PJ,y}	CMM captured and destroyed in the project activity in year y	flow meter	t CH ₄	equal to P17,MD _{HEAT}
B47 HEAT _y	Heat generation by project	calculation	MWh	calculated using P17 and B57 (Method 1) measured using steam flow data (Method 2)

B.2.5. Data concerning leakage

Not applicable.

B.2.6. Data concerning environmental impacts

Not applicable.

B.3. Data processing and archiving (incl. software used):

Method 1

Hand written journals as data record only. Excel sheets since 01/09/2008.

Method 2

The data are collected, processed and stored using a Siemens SIMATIC PLC S7 system and Siemens WINCC programming software. All data is stored in the internal memory about 2 GB. One time per hour the data are sent via GPS to an Internet-based Server data base. The server provider ensures regular back ups and archiving. Further on the data is stored and archived by Eco-Alliance OOO.

MONITORING REPORT FORM

The data can be read any time from the internet data base by authorised personnel. The utilised methane amount is automatically calculated and stored in the PLC. As all input data are stored, the automatically calculation can be checked in retrospect any time.

For plausibility checks and potential data back up the data logged in the hand written journals of the suction system can be taken.

B.4. Special event log:

No special events.

SECTION C. Quality assurance and quality control measures

C.1. Documented procedures and management plan:

C.1.1. Roles and responsibilities:

The general project management is implemented by the Technical Director of the Krasnoarmeyskaya-Zapadnaya Nr.1 Coal Mine through supervising and coordinating activities of his subordinates, such as the degasification engineer, heating technician, and safety engineering departments. Daily a group of mechanics and electricians who are responsible for the measures and maintenance of all technological equipment and measuring instruments are present on-site. There are two shifts, 12 h each. For every shift there is one person on-duty responsible for the proper operation and keeping of the journals. Overview calculations about the methane amount utilised are made on a monthly and yearly basis and notified in the journal. The general supervision of the monitoring system is executed by the administration of the coal mine under the existing control and reporting system.




Figure 1 – Organigram

C.1.2. Trainings:

The employees responsible for the monitoring control have been trained on-the-job during the installation of the system.

C.2. Involvement of Third Parties:

- Donetskderzhstandartmetrologiya, a is a subsidiary of the “Ukrainian Ukrainian Centre for Standardisation and Metrology”, which is part of the “State Committee for Matters of Technical Regulations and Consumer Politics”, which is part of the government, has been involved for the regular calibration of the on-line gas analysers.
- MakNII Institute, the “State Makeyevka Institute for Research and Education for Safe Work in the Coal Mining Industry”, a subsidiary of the “Ukrainian Ministry for Fuel and Energy”, has been involved for the lab analysis (NHMHC) of the CMM.
- Ukrteploservis has been involved for the service of the boiler and calibration of the CMM flow meter.

C.3. Internal audits and control measures:

The results of the upgraded boiler have been compared with the coal boilers. The data are plausible, no major deviations have been found. The efficiency of the upgraded boiler has been measured and has been found to be better than that for the coal boilers.

During the efficiency measurements the heat produced by the boiler has been measured and verified. The measurements confirm the plausibility of the flow and concentration measurement units and the calculation method for the produced heat amount (see Section D, Table-10, B47).

C.4. Troubleshooting procedures:

The general troubleshooting for the steam boiler hasn't changed. In case of disturbance the gas supply to the boiler is shut down by a quick acting valve and the CMM supplied by the degasification system of the coal mine is blown to the atmosphere.

SECTION D. Calculation of GHG emission reductions

D.1. Table providing the formulas used:

Table-10 Formulae used taken from the PDD, symbols marked grey are not used in this monitoring report.

ID number	Data variable	Formula
P1 PE _y	Project emissions in year y	$PE_y = PE_{ME} + PE_{MD} + PE_{UM}$
P3 PE _{MD}	Project emissions from methane destroyed	$PE_{MD} = (MD_{FL} + MD_{ELEC} + MD_{HEAT}) \times (CEF_{CH4} + \tau \times CEF_{NMHC})$
P4 PE _{UM}	Project emissions from uncombusted methane	$PE_{UM} = GWP_{CH4} \times [(MM_{FL} \times (1 - Eff_{FL}) + MM_{ELEC} \times (1 - Eff_{ELEC}) + MM_{HEAT} \times (1 - Eff_{HEAT})]$
P27 τ	Relative proportion of NMHC compared to methane	$\tau = PC_{NMHC} / PC_{CH4}$
B1 BE _y	Baseline emissions in year y	$BE_y = BE_{MR,y} + BE_{Use,y}$
B3 BE _{MR,y}	Baseline emissions from release of methane into the atmosphere in year y that is avoided by the project activity	$BE_{MR,y} = CMM_{PJ,y} \times GWP_{CH4}$
B4 BE _{Use,y}	Baseline emissions from the production of power, heat or supply to gas grid replaced by the project activity in year y	$BE_{Use,y} = GEN_y * EF_{ELEC} + (HEAT_y / Eff_{HEAT,coal}) * EF_{HEAT}$
B14 CMM _{PJ,y}	CMM captured and destroyed in the project activity in year y	$CMM_{PJ,y} = (MD_{FL} + MD_{ELEC} + MD_{HEAT})$
ER	Emission reductions	$ER_y = BE_y - PE_y$

D.2. Description and consideration of measurement uncertainties and error propagation:

In addition to the uncertainty of the measuring meters, the hand reading of the meters cause additional uncertainties, see <Possible sources of error> for detailed information. Obvious errors in the journals have been corrected by Emission-Trader ET GmbH during the supervision of the documents. Corrected data are marked red.

D.3. GHG emission reductions (referring to B.2. of this document):**D.3.1. Project emissions:**

period	project emissions [t CO _{2eq}]
01/01/2008-31/12/2008	7.900
01/01/2009-31/12/2009	9.390
01/01/2010-28/02/2010	6.764
Total 2008-2010	24.053

D.3.2. Baseline emissions:

period	baseline emissions [t CO _{2eq}]
01/01/2008-31/12/2008	74.422
01/01/2009-31/12/2009	86.907
01/01/2010-28/02/2010	58.006
Total 2008-2010	219.335

D.3.3. Leakage:

Not applicable.

D.3.4. Summary of the emissions reductions during the monitoring period:

period	Emission reductions [t CO _{2eq}]
01/01/2008-31/12/2008	66.523
01/01/2009-31/12/2009	77.517
01/01/2010-28/02/2010	51.242
Total 2008-2010	195.282


MONITORING REPORT FORM

Monitoring Report Nr. 01 - Krasnoarmeyskaya Zapadnaya № 1

page 16

**The total GHG emission reduction for the monitoring period 01/01/2008-31/03/2010 is
195.282 t CO_{2eq}.**

This monitoring report has been prepared by Carbon-TF B.V.
Responsible person: Adam Hadulla



Venlo, 07/04/2010

Annex 1

REFERENCES

- Project Design Document; Version 04, dated 2008-10-22
- Final Determination Report for the project: JI0105 “CMM utilisation on the Joint Stock Company “Coal Company Krasnoarmeyskaya Zapadnaya № 1 Mine””; Report No: 2008-1279 Rev 01, by DNV Det Norske Veritas, dated 2008-08-30
- Letter of Approval, Nr. M000013, issued on 2008-02-22 by the Ukraine (host party)
- Letter of Approval, Nr. 2008JI02, issued on 2008-04-22 by the Kingdom of the Netherlands (investor party)
- supporting evidence documents provided by the coal mine


Annex 2**Technical drawing**

Figure-2 Location Plan – Coal Mine Krasnoarmeyskaya-Zapadnaya Nr.1, Central Shaft
P – gas pump station
Котельная – Boiler house
Piping

Annex 3**Energy and material flowchart including metering positions****A3.1 Monitoring plan applied**

The monitoring plan applied during the monitoring period provides mainly handwritten data. Although the electronic equipment is installed since the beginning of the project, no electronic storage of the data took place in the beginning of the project. The data have been manually read from the electronic devices and hand written in journals. This method is the most common practice in Ukraine.

The electronically data storage system has been put in operation in September 2009.

So there are two monitoring procedures:

- 1) manual record of the monitored data from 01/01/2008
- 2) electronically record of the monitored data from 12/09/2010

Method 1 is still used by the coal mine and can be taken for backup.

A3.2 Monitoring procedure 1:

The first procedure concerns the monitoring of the boiler operation data and is relevant for safety and proper operation of the boiler. The boiler data (temperatures, pressures etc.) are recorded manually in a 15 min. cycle in a boiler operation journal. These journals are stored only for the last six month, so that the data are not available for the monitoring period.

All data concerning the CMM, which is fed into the boiler, are stored in a separate hand written journal. The recording cycle is 12h (one time per shift). The journals consist of six columns:



1	2	3	4	5	6
Дата, смена, Фамилия, И. О. мастера	Средний расход метановоздушной смеси за 1 час, м ³ /ч	Средний расход метановоздушной смеси за смену, м ³ /см	Средняя концентрация МВС за смену, %	Давление МВС перед горелками, кгс/см ²	Подпись
1.07.05 I смена Фоминенко В.А.	1600	9600	30%	0.06	
1.07.05 II см Харбекова И.А.	1500	8000	30%	0.06	

Figure-3 Excerpt from the CMM Journal

- 1) date + first (I) or second shift (II) (both 12 hours long), name of the master (mechanic)
- 2) average CMM flow [m³/h] during the operation hours
- 3) total CMM amount per shift [m³/shift]
- 4) methane concentration [%]
- 5) CMM pressure before burners [kp/cm²]
- 6) signature

The data in the CMM journal are prepared using the recorded data of the boiler journal. The data in columns 2, 4 and 5 are average values, the data in column 3 – the total CMM amount per shift - are cumulated values.

MONITORING REPORT FORM

As stated above the recording period in the boiler journal is 15 min., so that 48 values from the boiler journal are condensed into one value of the CMM journal.

The data from column 2 and 3 are not matching at first glance. The CMM flow from column 2 in [m³/h] multiplied with 12 hours does not obviously give the value recorded for the total CMM amount in [m³ per shift] from column 3. This is because the boiler is producing heat on demand. The heat production of the boiler can be lowered down to 30%. During periods with lower heat demand the boiler is periodically switched on and off. In the example above the boiler was 6 hours in operation during the first shift and 5.33 hours during the second shift. The value in column 2 is not the average value for 12 hours but an average value for those time periods in whose gas has been supplied to the boiler. If the boiler was only 6 or 5.33 hours in operation, like in the example above, only this 6 or 5.33 hours are taken for the calculation of the average value.

The sum value of CMM utilised during the shift (column 3) is calculated by the coal mine personnel using the actual CMM flow and the actual operating hours from the boiler journal. The operating hours are recorded in the boiler journal only and not available in the CMM journal.

A3.3 Measurement unit installation, method 1

The gas installation scheme is shown in Figure-4.




Figure-4 Gas installation scheme
 1) gas input
 2) concentration measurement – Draeger Politron
 3) dryer
 4) pressure regulation

- 5) fire arrester
- 6) orifice / diaphragm
- 7) pressure difference meter
- 8) gas collector
- 9-10) gas distributors
- 11-14) gas burners with manometers

A3.4 Measurement units

The measurements relevant for the monitoring of emissions reduction units are the concentration measurement (2) and the flow measurement (6-7).

Concentration measurement

The CH₄ concentration is measured by a Draeger Politron meter which is fixed installed in the gas inlet pipe and a SHI-12 hand meter, which is manually connected to the system using one of the small nozzles in the gas inlet pipes to the boiler short before the burners. Further on a third measurement unit by "Woelke" is installed in the central suction system.

The Draeger Politron is mainly a CH₄ detection and warning system, which is normally utilised for the determination of dangerous methane concentrations up to the lower explosion limit LEL, for the avoidance of explosions. The analyser is designed and optimized for the exact determination of low methane concentrations. Despite that the range of the meter can be extended to the range of 0-100% CH₄ according to the Draeger manual.

The SHI-12 meters are mainly used as a personal safety unit; the units are handed over to the personnel at the beginning of the shift and taken back at the end of the shift, so that usually different units are used. The coal mine posses more than 3,000 of the units.

According to the manufacturer data, which are confirmed by the calibration protocols by Donetskstandart-metrologiya, the Draeger unit has a relative error of 10%, corresponding to an absolute error of 2.5% at 25% CH₄ and 5% at 50% CH₄; the SHI-12 unit has an absolute error of 2.5%. So the SHI-12 units are more accurate in the relevant CH₄ concentration range.

In the CMM journal it is not stated which of the two concentration meters is taken, so the higher error of the Draeger Politron has been taken into account.

The general plausibility of the concentration measurement is verified from time to time using the CH₄ measurement of the central suction system (Woelke-measurement unit). The plausibility measurement is not recorded in the journals.

Flow measurement

The CMM flow is measured using an orifice; the pressure difference at the orifice is transferred to a 4-20 mA signal using a pressure difference transmitter and visualised on a chart recorder, see Figure-7. The momentary flow is read every 15 min from the personnel and recorded manually in the boiler journal.

The calculation of the shift sum values in the CMM journal has been described above.

MONITORING REPORT FORM




Figure-5 – Data flow sheet

A3.6 Monitoring procedure 2:

The measurement procedure 2, applied since 12/09/2009, is according to the monitoring plan as described in the PDD. A Vortex flow meter instead of a standard orifice has been used for the measurement of the CMM amount; the flow meters are on par.

The CH₄ concentration is further on measured by the same Draeger Polatron meter used for method 1.

A3.6 Measurement unit installation, method 2




Figure-6 – Installation scheme for method 2