



JOINT IMPLEMENTATION PROJECT DESIGN DOCUMENT FORM
Version 01 - in effect as of: 15 June 2006

CONTENTS

- A. General description of the project
- B. Baseline
- C. Duration of the project / crediting period
- D. Monitoring plan
- E. Estimation of greenhouse gas emission reductions
- F. Environmental impacts
- G. Stakeholders' comments

Annexes

- Annex 1: Contact information on project participants
- Annex 2: Baseline information
- Annex 3: Monitoring plan

**SECTION A. General description of the project****A.1. Title of the project:**

Wood waste-to-energy project at Sawmill-25 (Arkhangelsk)

Report version number: 2.0

Date: 18 May 2007

A.2. Description of the project:**Purpose of the project**

The project is aimed at increasing the amount and efficiency of bark and wood waste (BWW) use as a fuel for generating heat and power, thus reducing consumption of expensive and environmentally dirtier fossil fuel, the amount of dumped BWW and GHG emissions into the atmosphere.

Concept of the project

The project is implemented at the JSC "Sawmill 25", Arkhangelsk, Russia. Manufacturing facilities of the mill comprise two sites named after the places of their location, Tsiglomen site and Maimaksa site.

With reference to the project, BWW includes:

- bark;
- sawdust;
- shavings.

The bulk of BWW is formed at the stage of wood debarking and sawing.

The project provides for implementation of the following solutions:

Stage I:

- Construction of a new BWW boiler-house at Tsiglomen production site (2005).

Stage II:

- Construction of a new BWW combined heat power (CHP) plant at Maimaksa production site (2006-2007).

Expected results of the project:

- Renovation of the farm of utilizing boilers with modern highly efficient boiler units with total rated power 20 MW, which will give a growth of steam generation and ensure increasing amounts of BWW combustion in the boilers by 45.1 thousand tons per year (on average for the period of 2008-2012);
- Reduction of the amount of dumped BWW up to complete stop;
- Reducing fuel oil consumption by 6.4 thousand tons per year;
- Generating about 20 thousand MWh per year of its own power from BWW with reducing fossil fuel consumption at electric power plants of electric grid;
- Reducing pollutant emissions into the atmosphere;
- Reducing CO₂ emissions resulting from burning fossil fuel by 34.1 thousand tons per year;
- Reducing methane emissions resulting from anaerobic decomposition of biomass waste at the landfills by about 9.0 thousand tons of CO₂-equivalent per year (on the average over 2008-2012);



- Cutting costs spent on fossil fuel, reducing payments charged for environment pollution;
- Possible revenues from sale of Emission Reduction Units (ERU) of greenhouse gases (GHG);
- Increasing working places;
- Raising production standards.

Implementation schedule and costs of the project

| Parameters | Tsiglomen production site (BWW boiler-house) | Maimaksa production site (BWW CHP plant) |
|---------------------------------------|---|---|
| Amount of investments, '000 euro | 1 915 | 9 500 |
| General implementation period, months | 12 | 14 |

Grounds for the project implementation

JSC "Sawmill 25" has all the required permits and licenses for carrying out its current activities and the project implementation, which are executed in accordance with legislation of the Russian Federation.

The feasibility study and detail designing have been fulfilled by the JSC "Arkhgiprodev" specialized developer. The technological processes to be implemented in the project meet the world state-of-art standards accepted in the industry. All the technological parameters meet the environment protection normative requirements.

The project implementation will result in substantial reduction of the fossil fuel consumption and in mitigation of the negative impact on the environment, including reduction of greenhouse gas (GHG) emissions.

The project implementation is subject to direct obligations of the Russian Federation under:

- Convention of long-distance transboundary air pollution of 1979 and the related Protocols on step-by-step limitation and reduction of sulfur and nitrogen oxide emissions or their transboundary flows;
- Convention on climate change of 1992 and the related Kyoto Protocol of 1997, their requirements aimed at raising efficiency of power use and reduction of greenhouse gas emissions.

The project implementation is related to overcoming a whole range of serious legislative, technological, commercial and financial barriers. The decision of implementation of the project was largely made with taking into account potential possibility to cover costs and offset risks owing to sales of the achieved values of ERUs within the mechanisms provided by the Kyoto Protocol (see letter #120-A of 03.04.2002. Annex 2.9). The Sawmill-25 management has considered NEFCO as one of the most probable buyers of ERUs (see letter of 07.06.2006 Annex 2.10).

**A.3. Project participants:**

| Party involved | Legal entity project participant (as applicable) | Please indicate if the Party involved wishes to be considered as project participant (Yes/No) |
|--|--|--|
| Party A: Russian Federation (host Party) | Legal entity A1: Joint Stock Company "Sawmill 25" | No |
| Party B: EU countries | Legal entity B1: Private company "CAMCO International GmbH" | No |
| Party B: EU countries | Legal entity B2: Private company "Camco Carbon Russia Limited" | No |

JSC "Sawmill 25" is a legal entity in the form of a closed joint stock company. JSC "Sawmill 25" is operating on the basis of the acting legislation of the Russian Federation and its Articles of associations (the Charter).

After having taken over Tsiglomen timber mill Co. Ltd in 2003, JSC "Sawmill 25" has become the biggest sawmill company in the North-West Russia.

JSC "Sawmill 25" is a part of Titan group, founded in 1990. Titan group is one of the biggest timber industry companies in Russia, integrating on the upstream basis various production units (enterprises) starting from timber logging, up to the final products manufacturing.

JSC "Sawmill 25" is focused on production of saw-timber products and pulp chips. The mill specialises on sawing fir and pine breeds. The products manufactured by the mill are supplied to Germany, Holland, Ireland, Egypt, Great Britain, France and Algeria as well as to the domestic Russian market. At present, the total sawing capacity of the mill is 700 000 m³/year.

Main production facilities of JSC "Sawmill 25" are located in the Maimaksa district of Arkhangelsk on the right bank of the Maimaksa River (one of the navigation branches of the Northern Dvina) in the western part of Povrakula peninsula, 20 km far from the city. The length of the site along the coastline is 2.5 km.

Processing the northern wood of special ecological value JSC "Sawmill 25" understands its responsibility for environmental protection and rational use of natural resources. The company takes into account the opinion of Greenpeace and WWF and cooperates with them in its activities and identification of priorities. JSC "Sawmill 25" is a member of Association of Responsible Timber Companies of Russia.

The company pays special attention to the issues of stable forest exploitation and voluntary production certification in accordance with the international standards to exclude the use of illegal timber.

It should be noticed that JSC "Sawmill 25" management pays much attention to the issues of climate change mitigation in accordance with the UN FCCC and the Kyoto protocol.

Camco International GmbH is a subsidiary of Camco International Ltd., a Jersey based public company listed at AIM in London. Camco International is the world leading carbon asset developer and projects promoter under both joint implementation and clean development mechanism of the Kyoto Protocol. Camco's project portfolio consists of more than 70 projects, generating altogether over 100 MT CO₂e of GHG reductions all over the world. Camco operates in Eastern Europe, Africa, China, and Southeast Asia. The company has been actively cooperating with Russia since 2005.

Camco Carbon Russia Limited is a subsidiary of Camco International Ltd., a Jersey based public limited liability company listed at AIM in London (index CAO). Camco Carbon Russia has been established with the purpose of investing in projects implemented in the Russian Federation under Article 6 of the Kyoto Protocol to United Nations Framework Convention on Climate Change.

A.4. Technical description of the project:

A.4.1. Location of the project:

The project activity is located at the JSC “Sawmill-25”, Arkhangelsk, Russia.



Fig. A.4-1. Location of the city of Arkhangelsk




Fig. A.4-2. Location of Maimaksa and Tsiglomen districts




Fig. A.4-3. Tsiglomen production site



Fig. A.4-4. Maimaksa production site

**A.4.1.1. Host Party(ies):**

Russian Federation

A.4.1.2. Region/State/Province etc.:

Arkhangelsk Region

A.4.1.3. City/Town/Community etc.:

City of Arkhangelsk

A.4.1.4. Detail of physical location, including information allowing the unique identification of the project (maximum one page):

Arkhangelsk is the administrative center of the Arkhangelsk Region (Oblast).

The population of Arkhangelsk is 349.8 thousand (as per 2006 official data).

Position data: geographic latitude: 64°34', geographic longitude: 40°49'

Time zone: GMT +3:00

The city is situated in the mouth of the Northern Dvina, 40-45 km away from the place where it flows into the White Sea, 1133 km to the north from Moscow.

The city's climate is subarctic and maritime with long winter and short and cool summer. It is formed under the influence of the northern seas and transportation of air masses from the Atlantic in the conditions of the small amount of solar radiation. The average January temperature is -13 °C, that of July is +17 °C. The annual precipitation is 529 mm.

A.4.2. Technology(ies) to be employed, or measures, operations or actions to be implemented by the project:

The project is implemented in 2 stages.

Stage I. Construction of the BWW boiler-house at Tsiglomen production site (2005)

The first stage of the JI project stipulated construction of the sawmill's own BWW boiler-house with the installed capacity 5 MW in order to fully cover the needs of the Tsiglomen production site. In 2005, the boiler-house was built and set into operation (Fig. A.4-5).

There are two hot-water boilers PR-2500 of the Austrian firm "Polytechnic" with the capacity of 2.5 MW each installed in the new boiler-house. (Fig. A.4-6, Fig. A.4-7).

The boilers are equipped with a furnace with a tilt-and-shearing grate for wood waste combustion. The water output temperature is 110 °C and pressure is 0.3 MPa. The boilers work at two-loop circuit.

The maximum calculated load in the winter period is 5 MW;

The maximum calculated load in the summer period is 3.8 MW;

The calculated load including heat loss is:

- for saw-timber drying – 3.8 MW;

- for heating – 1.2 MW.



Fig. A.4-5. The new BWW boiler-house at the Tsiglomen production site




Fig A.4-6. Symbolic circuit of the utilizing boiler "Polytechnik"

+



Fig. A.4-7. Utilizing boilers “Polytechnik”

The boiler’s fuel is wood waste (bark and sawdust, mainly) which comes from the wood processing at the Tsiglomen site (Fig. A.4-8).



Fig. A.4-8. Bark and wood waste for the new boiler-house in Tsiglomen



Traditionally (without the project), the Tsiglomen production site has been supplied with heat by an outside provider, i.e. a municipal boiler-house which used fuel oil and BWW while supplying heat both to the sawmill and to the residence sector of “Tsiglomen” district¹. Annual heat supply to the sawmill constituted about 1/3 of the total annual output of the boiler-house.

The boiler-house consists of 4 oil-fired steam boilers DE-25-14-GM and 2 BWW-fired steam boilers KE-10-14 MT with total installed capacity 80 MW. Actually required capacity of the boiler-house is several times smaller. The maximum amount of wood waste ever utilized in the municipal boiler-house was 50.3 thou m³ a year. During the last decade, the amount of wood waste utilized in the boiler-house has been steadily decreasing.

In 2006, the municipal authorities handed the boiler-house over to the JSC “Arkhangelsk generating company” for rent. The boiler-house has been operating using fuel oil and practically stopped using wood waste as a fuel. Consumption of fuel oil instead of wood waste is connected with the development strategy of “Arkhangelsk generating company” according to which it is more rational to burn fuel oil to increase the reliability of heat supply of “Tsiglomen” housing estate. This way the company avoids the risk of BWW incomplete delivery from outside.

This situation is also largely explained by imperfection of state tariff policy which does not stimulate using local kinds of fuel. More complex technologies are necessary to use local kinds of fuel. At present conditions it is technologically easier and economically more profitable to burn fuel oil shifting its cost on consumers' shoulders through tariffs.

After the project has been implemented, the municipal boiler-house continued its operation supplying heat to the residence sector only.

Stage II. Construction of a new BWW combined heat power (CHP) plant at Maimaksa production site (2006-2007)

Maimaksa production site is supplied with heat from its own boiler-house consisting of 1 oil-fired steam boiler DE-25-14 GM and 3 BWW utilizing steam boilers KE-10-14 MT. Total installed capacity is 30 MW. This capacity is enough to cover the heat load at sawing 600 000 m³/year stipulated that fuel oil is added.

There is also a coal boiler-house of small capacity for heating of the sawmill’s own motor transport shop (MTS). This boiler-house has been working mostly on firewood for the last years. The coal consumption has not been considerable (15 tons only, in 2006).

¹ Heat supply to the residence sector includes also supply of heat to some other enterprises located in the area.



Fig. A.4-9. The old boiler-house at the Maimaksa production site

At present, the new BWW CHP plant is being built under the project's second stage (Fig. A.4-10, A.4-11). The planned date of setting it into operation is June, 2007. Taking into account the enterprise's plans to increase the drying capacities and to set into operation the dry-end production separation line together with the increase of sawing volume up to 600 thousand m³/year, the construction of CHP plant will allow to refuse using outside power and cover the heat load.



Fig. A.4-10. Construction of the new BWW CHP plant




Fig. A.4-11. Basic flow chart of CHP plant

The new plant will be equipped with two steam boilers with the rated capacity 7.5 MW each supplied by the Austrian company “Polytechnik” (Fig. A.4-12) and one turbogenerator with the rated power 2.2 MW and the backpressure 0.18 MPa (Fig. A.4-13).




Fig. A.4-12. The scheme of the boiler installation




Fig. A.4-13. The general view of the turbine

The heat for the residence sector will be supplied from the old boiler-house owing to burning BWW. As the boiler-house's load will decrease more than four times, the real left service life of its equipment is supposed to be extended essentially. The coal boiler-house will be closed.

A.4.3. Brief explanation of how the anthropogenic emissions of greenhouse gases by sources are to be reduced by the proposed JI project, including why the emission reductions would not occur in the absence of the proposed project, taking into account national and/or sectoral policies and circumstances:

On the whole, reduction of GHG emissions under the project will take place due to:

- 1) reduction of fuel oil consumption at the old boiler-houses;
- 2) reduction of the amount of fossil fuel combustion at grid-connected electric power plants;
- 3) stop of bark dumping and reduction of methane emissions due to anaerobic decomposition of bark.

As a result of the project's first stage, CO₂ emissions from burning fuel oil at the Tsiglomen municipal boiler-house as well as CH₄ emissions from decomposition of bark at the landfill will be reduced. Without the project, heat energy for the enterprise's technological and heating needs would be supplied by the municipal boiler-house using fuel oil. After the sawmill has finished the construction of the new BWW boiler-house, the municipal boiler-house will continue heat supply for the residence sector only. The decrease of the heat load on the municipal boiler-house will lead to proportional reduction of fuel oil consumption. Hence, the aggregate fuel balance in Tsiglomen area (including the old municipal boiler-house and the new boiler-house installed under the project) will change. Fuel oil will be partially substituted by BWW which otherwise has to be dumped.

As a result of the project's second stage implementation, CO₂ emissions from burning fuel oil at the Maimaksa old boiler-house and fossil fuel at the outside grid-connected electric power plants as well as CH₄ emissions from decomposition of bark at the landfill will be reduced. Without the project, both heat used by the sawmill itself and supplied to the residence sector of Srednyaya Maimaksa district would be generated at the sawmill's boiler-houses by burning BWW and fuel oil (coal is actually substituted by firewood). The power for the enterprise and for the residence sector would be provided from the outside power grid. After the new CHP plant is set into operation, the enterprise will be able to provide the Maimaksa production site with its own power and heat generated by burning biomass and



practically stop power consumption from the grid. The old boiler-house will continue supply heat to the residence sector burning BWW only. The boiler-house of motor transport shop will be closed. Power supply to the residence sector will be provided according to the existing scheme (i.e., from the power grid). Bark dumping will be stopped.

N₂O and CH₄ emissions from burning are not taken into account as they are negligibly small compared to CO₂ emissions. CO₂ emissions from biomass burning are climatically neutral, and therefore are considered to be zero.

Without the project, the specified reductions of GHG emissions would not have been achieved, since the mill would have kept operating and developing with use of the existing energy equipment, and without serious obstacles for its operation in the current mode at least up to 2012, in view of the situation on the national and/or sectoral level:

- Technical condition of the old boilers, in principle, allows maintaining operation at the previous level for another ten to twenty years;
- An increasing demand for steam could have been covered through burning of additional amount of fuel oil and coal at the old boiler-houses;
- All the required permissions for operating the equipment and the landfill, including environmental authorizations approved by the relevant supervisory bodies, are available;
- Russian nature conservation legislation is unlikely to be changed in a way, which would force the enterprise to abandon operating the equipment in use prior to the project;
- No restrictions on the GHG emissions is set up or expected for Russia-based enterprises prior 2012;
- Without the project, it would have been possible to avoid additional (and rather risky) own financial investments and bank loans;
- Without the project, it would have been possible to avoid the risks related to the absence of the experience in electric power generation at the enterprise.

A.4.3.1. Estimated amount of emission reductions over the crediting period:

| Length of the crediting period | Years |
|--|--|
| 5 years | 2008-2012 |
| Year | Estimate of annual emission reductions in tonnes of CO ₂ equivalent |
| 2008 | 35 715 |
| 2009 | 41 624 |
| 2010 | 43 883 |
| 2011 | 46 040 |
| 2012 | 48 100 |
| Total estimated emission reductions over the crediting period (tonnes of CO ₂ equivalent) | 215 362 |
| Annual average of estimated emission reductions over the crediting period (tonnes of CO ₂ equivalent) | 43 072 |

A.5. Project approval by the Parties involved:

The Parties' Approval Letters will be received later.

**SECTION B. Baseline****B.1. Description and justification of the baseline chosen:**

The baselines of “Maimaska” and “Tsiglomen” production sites were chosen based on critical analysis of alternatives of the enterprise’s energy supply (see Section B.2).

The baseline scenario stipulates further use of existing energy facilities. Technical condition of the old boilers enables to maintain their operation at the previously achieved level, while doing scheduled repair works with no significant expenses required. Electric power would be supplied from the grid only.

Heat supply of the sawmill and the residence sector at Tsiglomen area would be provided through fuel oil combustion by the old boiler house rented by JSC “Arkhangelsk generating company”. This company now operates both large (CHP plants) and small sources of energy (heating boiler houses) using coal and fuel oil as the main fuels. The company is not interested in using BWW, therefore the Tsiglomen boiler house operates on fuel oil only. The company sees the perspectives of the regional energy development with coal share increase; therefore the boiler house’s operation may be supposed to be changed to coal in some future. However, following the conservative approach, it is assumed that fuel oil would continue to be burnt in the boiler house at least until 2012.

The enterprise would try to cover all its heat demand at Maimaksa site through BWW burning (which hardly can be done at present). However, the utilizing boilers capacities would be insufficient taking into account the planned increase of sawing and wood drying volumes, therefore shortage of heat energy would have to be covered through fuel oil combustion.

This baseline scenario represents SM-25’s business-as-usual operations under existing Russian laws and regulations. These laws and regulations do not impose limits or restrictions on using fossil fuels, dumping waste in landfills, and/or operating existing boilers and other installed equipment at both SM-25 and JSC “Arkhangelsk generating company”. Further, no limits or restrictions on GHG emissions have placed on Russian enterprises and they are not expected to be introduced before 2012. There are no special requirements on the utilization of BWW except for the requirement to have the landfill designed, constructed and maintained in compliance with the established rules and standards which are not too strict and/or cost intensive at all. Environmental fees for both harmful emissions into the atmosphere and dumping of BWW in the landfill are quite low and do not impact SM-25’s financial condition, which is sound and stable. And finally, this scenario does not require from SM-25 any investment and additional operational costs associated with construction and running of new energy facilities thus enabling SM-25 to use available investment resources (both equity and loans) for improving and increasing of its main production capacities, including implementation of energy saving technologies at sawing and drying, as envisaged in the mill’s corporate development and investment plan adopted in 2002.

The methodological approach for choosing the baseline may be described as follows.

Methodology ACM0006 “Consolidated methodology for electricity generation from biomass residues” [R1] is the most suitable of the methodologies approved for Clean Development Mechanism (CDM) projects.

On the whole, while working out the baseline, the developer suggests his own approach with the use of some elements of the mentioned method and the basis on methodological developments of IPCC, common sense and competence, without coordinating it specifically with any of the approved CDM methodologies; yet, he should obviously coordinate it with requirements laid out in *Decision 9/CMP.1, Annex B* [R2]. Everything concerning assessment of emissions is sufficiently described and justified.

The project is distinguished by the fact that at present, part of the construction-and-assembly works is completed, with the project being already an actually existing development bringing about physical reduction of GHG emissions. The baseline and the project scenarios have been developed on a project-specific basis taking into account the actual available material.

The key factors determining GHG emissions both in the baseline and in the project scenarios have been

singled out. These factors are as follows:

- volume of charge stock and BWW formation;
- power consumption;
- heat consumption;
- fossil fuel burning;
- BWW burning;
- BWW dumping.

Below each factor is addressed in details.

TSIGLOMEN PRODUCTION SITE

Volumes of charge stock and BWW formation

According to the SM-25 strategy, the further growth of production shall be achieved mainly at Maimaksa production site while at the Tsiglomen production site, the volumes of wood sawing will be kept at the current level, i.e. 240 000 m³/year, at least till 2012

Since the above strategy is not effected by the project, the wood sawing at Tsiglomen production site is considered constant and equal to **240 000** m³/year both in the baseline and in the project scenarios.

The enterprise's specific factors for BWW output as the result of wood sawing were used to determine the amount of BWW formed (Table B.1-1).

Table. B.1-1. BWW formation at the Tsiglomen production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|-------------------|------------------------|----------------------|---|---------------|
| Wood sawing | $P_{saw,1,y}$ | m ³ /year | The enterprise's plan | 240 000 |
| Bark share | $\alpha_{bark,1,y}$ | - | The enterprise's specific factor | 0.10 |
| Sawdust share | $\alpha_{sawdust,1,y}$ | - | The enterprise's specific factor | 0.17 |
| Bark formation | $P_{bark,1,y}$ | m ³ /year | $P_{bark,1,y} = P_{saw,1,y} \times \alpha_{bark,1,y}$ | 24 000 |
| Sawdust formation | $P_{sawdust,1,y}$ | m ³ /year | $P_{sawdust,1,y} = P_{saw,1,y} \times \alpha_{sawdust,1,y}$ | 40 800 |
| BWW formation | $P_{BWW,1,y}$ | m ³ /year | $P_{BWW,1,y} = P_{bark,1,y} + P_{sawdust,1,y}$ | 64 800 |

As the wood sawing volume according to the enterprise's plans for 2008-2012 neither changes nor depends on the project, the baseline and project volumes of the formed BWW do not change as well and make **64 800** m³ per year.

Electric power consumption

At present, power for the Tsiglomen production site and for the residence sector is supplied from the power grid.

The project does not stipulate construction of power generating facilities at Tsiglomen production site.

Power consumption by the new boiler-house is compensated by the reduction of power consumption by the old municipal boiler-house and therefore power consumption with and without the project can be supposed to stay at about the same level.

Thus, the power consumption was viewed neither in the baseline nor in the project scenarios.

Heat energy consumption

Heat energy is used for:

1. technological needs of the sawmill;
2. heating of the sawmill;
3. heating of the residence sector (including a number of other enterprises).

Heat consumption for the technology and heating needs does not depend on the project. However, it is advisable to view this factor as it determines absolute volumes of fuel consumption and therefore, GHG emissions.

The necessary amount of heat energy required for the work of the enterprise and for the heating of the residence sector is determined below (Table B.1-2).

Table B.1-2. Heat consumption at the Tsiglomen production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|---|--------------------------|----------------------|--|----------------|
| Wood sawing | $P_{saw,1,y}$ | m ³ /year | The enterprise's plan | 240 000 |
| Wood share for drying | $\beta_{dry,1,y}$ | - | Average value for the last three years (2003-2005) | 0.544 |
| Wood volume for drying | $P_{dry,1,y}$ | m ³ /year | $P_{dry,1,y} = P_{saw,1,y} \times \beta_{dry,1,y}$ | 130 572 |
| Number of working days of drying facilities | $d_{dry,1,y}$ | days/year | The enterprise's norm | 330 |
| Number of days of heating season | $d_{winter,1,y}$ | days/year | Climate norm [R3] | 253 |
| Summer heat rate for drying | $SEC_{dry,1,y}^{summer}$ | GJ/m ³ | The enterprise's norm | 0.888 |
| Winter heat rate for drying | $SEC_{dry,1,y}^{winter}$ | GJ/m ³ | The enterprise's norm | 1.027 |
| Average annual heat rate for drying | $SEC_{dry,1,y}$ | GJ/m ³ | $SEC_{dry,1,y} = \left(\begin{array}{l} SEC_{dry,1,y}^{winter} \times d_{winter,1,y} + \\ + SEC_{dry,1,y}^{summer} \times \\ \times (d_{dry,1,y} - d_{winter,1,y}) \end{array} \right) / d_{dry,1,y}$ | 0.995 |
| Heat consumption for drying | $HC_{dry,1,y}$ | GJ/year | $HC_{dry,1,y} = P_{dry,1,y} \times SEC_{dry,1,y}$ | 129 863 |
| Heat consumption for the heating of shops and office buildings of the sawmill | $HC_{heating,1,y}$ | GJ/year | Average value for the last three years (2003-2005) | 11 732 |
| Heat consumption for the technology and heating of the sawmill | $HC_{sawmill,1,y}$ | GJ/year | $HC_{sawmill,1,y} = HC_{heating,1,y} + HC_{dry,1,y}$ | 141 595 |
| Heat consumption for the heating of the residence sector | $HC_{housing,1,y}$ | GJ/year | Average rounded value for the number of several last years | 251 400 |
| Total heat consumption (useful output) | $HC_{1,y}$ | GJ/year | $HC_{1,y} = HC_{sawmill,1,y} + HC_{housing,1,y}$ | 392 995 |

Basing on the above calculations, the necessary amount of heat energy is **392 995** GJ/year. This number is considered both in the baseline and in the project scenarios.

Bark and wood waste (BWW) burning

Under the baseline scenario, BWW burning is absent at Tsiglomen site as the old boiler house handed over for rent to JSC "Arkhangelsk generating company" in 2006 and has been burning fuel oil with probable further change to coal combustion. Following the conservative approach it is assumed further that this boiler house will use fuel oil at least until 2012.

The necessary BWW amount for the new boiler-house is determined below (Table B.1-3).

Table B.1-3. BWW consumption by the new boiler-house at the Tsiglomen production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|--|----------------------|----------------------|---|---------------|
| Heat consumption for the technology and heating of the sawmill | $HC_{sawmill,1,y}$ | GJ/year | See Table. B.1-2 | 141 595 |
| BWW net calorific value | $NCV_{BWW,1,y}$ | GJ/t | Thermotechnical fuel analysis [R4] | 7.3744 |
| Efficiency of boilers | $\eta_{BWW,1,new,y}$ | - | Boilers tests data [R4] | 0.85 |
| Heat share for auxiliary needs | $HA_{BWW,1,new,y}$ | - | Assumed | 0.07 |
| BWW density | ρ_{BWW} | t/m ³ | The enterprise's norm | 0.8 |
| BWW consumption | $FC_{BWW,1,new,y}$ | m ³ /year | $FC_{BWW,1,new,y} = \frac{HC_{sawmill,1,y}}{\eta_{BWW,1,new,y} \times (1 - HA_{BWW,1,new,y}) \times NCV_{BWW,1,y} \times \rho_{BWW}}$ | 30 362 |

As per the above calculations, the BWW amount of **30 362** m³/year is necessary for full load of the new boiler-house.

Fossil fuel (fuel oil) consumption

Fossil fuel, namely fuel oil, is used by the old municipal boiler-house both in the baseline and in the project scenarios. The only difference is that under the baseline, the boiler-house supplies heat to the residence sector and to the sawmill, while under the project, it only supplies heat to the residence sector. Calculations are provided below in Table B.1-4.

Table B.1-4. Fuel oil consumption by the old boiler-house at the Tsiglomen production site (calculation)

| Name | Symbol | Unit | Justification | Base Line | Project |
|---|----------------------|---------|---|---------------|--------------|
| Heat energy supply from the old boiler-house | $HS_{1,old,y}$ | GJ/year | See Table B.1-2 | 392 995 | 251 400 |
| Fuel oil net calorific value | $NCV_{oil,1,y}$ | GJ/t | Reference data [R5] | 39.81 | 39.81 |
| Efficiency of oil-fired boilers | $\eta_{oil,1,old,y}$ | - | Boilers test data [R7, R8] | 0.753 | 0.753 |
| Heat share for auxiliary needs of oil-fired boilers | $HA_{oil,1,old,y}$ | - | Assumed | 0.07 | 0.07 |
| Fuel oil consumption | $FC_{oil,1,old,y}$ | t/year | $FC_{oil,1,old,y} = \frac{HS_{1,old,y}}{NCV_{oil,1,y} \times \eta_{oil,1,old,y} \times (1 - HA_{oil,1,old,y})}$ | 14 098 | 9 019 |

Thus, with the project the fuel oil consumption will reduce from 14 098 t/year to 9 019 t/year, that is by **5 080** t/year.

BWW dumping

As a result of the project, the amount of BWW dumped will decrease by the amount of BWW utilized in the new boiler house, i.e. by **30 362** m³/year. The relevant calculations of avoided methane emissions since 2006 are provided in Section E.

The results of the calculations for the whole reporting period 2008-2012 at the Tsiglomen site are provided in Annex 2.1-2.4.

MAIMAKSA PRODUCTION SITE

Volumes of charge stock and BWW formation

Irrespective of the project, the enterprise plans to bring the sawing level up to 600 000 m³/year during the next 2-3 years (Table B.1-5).

Table B.1-5. Wood sawing at Maimaksa production site

| Year | Volume of wood sawing, $P_{saw,2,y}$, m ³ |
|------|--|
| 2003 | 344 909 |
| 2004 | 414 258 |
| 2005 | 452 722 |
| 2006 | 467 468 |
| 2007 | 500 000 |
| 2008 | 550 000 |
| 2009 | 600 000 |
| 2010 | 600 000 |
| 2011 | 600 000 |
| 2012 | 600 000 |

At sawing 600 000 m³/year, the amount of BWW will be 174 000 m³/year (Table B.1-6). This amount does not depend upon the project and therefore will be considered the same in the baseline and in the project line.

Table B.1-6. BWW formation¹ at the Maimaksa production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|-------------------|------------------------|----------------------|---|----------------|
| Wood sawing | $P_{saw,2,y}$ | m ³ /year | The enterprise's plan | 600 000 |
| Bark share | $\alpha_{bark,2,y}$ | - | The enterprise's norm | 0.10 |
| Sawdust share | $\alpha_{sawdust,2,y}$ | - | The enterprise's norm | 0.19 |
| Bark formation | $P_{bark,2,y}$ | m ³ /year | $P_{bark,2,y} = P_{saw,2,y} \times \alpha_{bark,2,y}$ | 60 000 |
| Sawdust formation | $P_{sawdust,2,y}$ | m ³ /year | $P_{sawdust,2,y} = P_{saw,2,y} \times \alpha_{sawdust,2,y}$ | 114 000 |
| BWW formation | $P_{BWW,2,y}$ | m ³ /year | $P_{BWW,2,y} = P_{bark,2,y} + P_{sawdust,2,y}$ | 174 000 |

Heat energy consumption

Heat energy is used for:

1. technological needs of the sawmill;
2. heating of the sawmill;
3. heating of the residence sector.

The amount of heat used for technological and heating needs does not depend on the project. However, like in the Tsiglomen case, it is reasonable to address this factor in some more details since it determines absolute volumes of fuel consumption.

¹ Tables B.1-6 – B.1-11 represent calculations for the sawing amount 600 000 m³/year which is the case for 2009-2012, that is four of the five reporting years. Calculations for the whole reporting period 2008-2012 are provided in Annexes 2.5-2.8.

The table below contains the relevant data (Table B.1-7).

Table. B.1-7. Heat energy consumption at the Maimaksa production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|---|--------------------|----------------------|--|----------------|
| Wood sawing | $P_{saw,2,y}$ | m ³ /year | The development plan of the enterprise | 600 000 |
| Wood share for drying | $\beta_{dry,2,y}$ | - | Average value for the last three years (2003-2005) | 0.539 |
| Volume of wood for drying | $P_{dry,2,y}$ | m ³ /year | $P_{dry,2,y} = P_{saw,2,y} \times \beta_{dry,2,y}$ | 323 542 |
| Average heat rate for drying | $SEC_{dry,2,y}$ | GJ/m ³ | See Table B.1-2 | 0.995 |
| Heat consumption for drying | $HC_{dry,2,y}$ | GJ/year | $HC_{dry,2,y} = P_{dry,2,y} \times SEC_{dry,2,y}$ | 321 785 |
| Heat consumption for heating of shops and office buildings of the sawmill | $HC_{heating,2,y}$ | GJ/year | Average value for the last three years (2003-2005) | 20 041 |
| Heat consumption for heat supply of motor transport shop | $HC_{auto,2,y}$ | GJ/year | Average value for the last three years (2003-2005) | 14 346 |
| Heat consumption for technology and heating of the sawmill | $HC_{sawmill,2,y}$ | GJ/year | $HC_{sawmill,2,y} = HC_{heating,2,y} + HC_{dry,2,y} + HC_{auto,2,y}$ | 356 171 |
| Heat consumption for heating of the residence sector | $HC_{housing,2,y}$ | GJ/year | Average value for the last three years (2003-2005) | 109 937 |
| Total heat consumption (useful output) | $HC_{2,y}$ | GJ/year | $HC_{2,y} = HC_{sawmill,2,y} + HC_{housing,2,y}$ | 466 108 |

As per the calculations above, the total estimated consumption of heat at the Maimaksa production site at 600 000 m³/year sawing capacity will be **466 108** GJ/year.

Electric power consumption

Power consumption at the Maimaksa production site will be **21 655** MWh/year (see Table B.1-8 below). Under the baseline scenario, this power is supplied totally by the public power grid, while with the project it is generated by the sawmill's own BWW CHP plant.

Table. B.1-8. Power consumption at the Maimaksa production site (calculation)

| Name | Symbol | Unit | Justification | Value |
|---|-----------------|--------------------|--|-------|
| Power rate for sawing | $SEC_{saw,2,y}$ | kWh/m ³ | Actual data for 2006 | 9.89 |
| Power consumption at sawing | $EC_{saw,2,y}$ | MWh/year | $EC_{saw,2,y} = P_{saw,2,y} \times SEC_{saw,2,y} \times 10^{-3}$ | 5 934 |
| Power rate for drying chambers and packaging line | $SEC_{dry,2,y}$ | kWh/m ³ | Actual data for 2006 | 35.82 |



| Name | Symbol | Unit | Justification | Value |
|---|------------------|----------|--|---------------|
| Power consumption by drying chambers and packaging line | $EC_{dry,2,y}$ | MWh/year | $EC_{dry,2,y} = P_{dry,2,y} \times SEC_{dry,2,y} \times 10^{-3}$ | 11 589 |
| Power rate for the auxiliary needs of the on-site energy suppliers ¹ | $SEC_{aux,2,y}$ | kWh/GJ | Actual data for 2006. It is assumed identical for the baseline and the project scenarios | 6.74 |
| The auxiliary needs of on-site energy suppliers | $EC_{aux,2,y}$ | MWh/year | $EC_{aux,2,y} = HC_{2,y} \times SEC_{aux,2,y} \times 10^{-3}$ | 3 142 |
| Other power consumption | $EC_{other,2,y}$ | MWh/year | Actual data for 2006 | 990 |
| Total power consumption | $EC_{2,y}$ | MWh/year | $EC_{2,y} = EC_{saw,2,y} + EC_{dry,2,y} + EC_{aux,2,y} + EC_{other,2,y}$ | 21 655 |

Power consumption by the residence sector is not considered. It is assumed that in any case, power for the residence sector will be supplied from the public grid.

Bark and wood waste (BWW) consumption

Under the baseline scenario and according to the available data for the last years, the management of Maimaksa production site tries to provide heat energy generation through BWW burning using the existing capacities at most. Note that they managed to do this quite well at wood sawing volumes of about 450 000 m³ per year. Fossil fuel consumption was rather insignificant in 2005-2006 (see below).

However, according to the expert assessment performed by the specialists of sawmill's energy service, the highest possible volume of BWW utilization in the old boiler house is 85 000-90 000 m³/year. And this limit will undoubtedly be reached at sawing of 600 000 m³ per year with the corresponding heat consumption increase. Conservatively, the higher number of the specified range, i.e. 90 000 m³/year, is assumed further.

Besides, as calculations showed, it is possible to burn 3 216 m³ of BWW per year in the boiler house of the motor transport shop given that coal combustion is completely stopped.

Thus, the total highest baseline BWW consumption is **93 216 m³** per year.

Under the project, the old boiler house will provide heat only for the residence sector that will need only 24 646 m³ of BWW per year. The coal boiler house of the motor transport shop will be put out of the operation. The CHP plant will provide heat and power for the Maimaksa production site solely through burning of 96 051 m³ of BWW per year.

The total volume of project BWW burning is **120 698 m³** per year.

BWW shortage for burning is absent in both scenarios.

All the necessary data and results of calculations are represented in Table B.1-9.

¹ Referred to the cumulative useful output of heat energy from on-site energy suppliers

Table. B.1-9. BWW consumption at the Maimaksa production site (calculation)¹

| Name | Symbol | Unit | Justification | Base Line | Project |
|---|----------------------|----------------------|--|-----------|---------|
| The old sawmill's boiler-house | | | | | |
| Useful output of heat energy owing to BWW burning | $HC_{BWW,2,old,y}$ | GJ/year | BL: $HC_{BWW,2,old,y} = FC_{BWW,2,old,y} \times \eta_{BWW,2,old,y} \times \rho_{BWW} \times (1 - HA_{BWW,2,old,y})$; PJ: output of heat energy to the residence sector (see Table B.1-7) | 401 451 | 109 937 |
| Utilizing boilers efficiency | $\eta_{BWW,2,old,y}$ | - | Boilers tests data [R9] | 0.813 | 0.813 |
| Heat share for auxiliary needs | $HA_{BWW,2,old,y}$ | - | Assumed | 0.07 | 0.07 |
| Net calorific value of BWW | $NCV_{BWW,2,y}$ | JG/t | Thermotechnical fuel analysis [R4] | 7.3744 | 7.3744 |
| BWW consumption | $FC_{BWW,2,old,y}$ | m ³ /year | BL: max capacity of utilizing boilers; PJ: $FC_{BWW,2,old,y} = HC_{BWW,2,old,y} / (\eta_{BWW,2,old,y} \times (1 - HA_{BWW,2,old,y}) \times NCV_{BWW,2,y} \times \rho_{BWW})$ | 90 000 | 24 646 |
| Boiler-house of the motor transport shop | | | | | |
| Useful output of heat energy | $HC_{2,auto,y}$ | GJ/year | Average value for the last three years (2003-2005) | 14 346 | 0 |
| Boilers efficiency | $\eta_{2,auto,y}$ | - | Assumed as in the "main" old boiler house | 0.813 | - |
| Heat share for auxiliary needs | $HA_{2,auto,y}$ | - | Assumed | 0.07 | - |
| BWW consumption | $FC_{BWW,2,auto,y}$ | m ³ /year | $FC_{BWW,2,auto,y} = HC_{2,auto,y} / (\eta_{2,auto,y} \times (1 - HA_{2,auto,y}) \times NCV_{BWW,2,y} \times \rho_{BWW})$ | 3 216 | 0 |
| The new CHP plant | | | | | |
| Useful output of heat energy | $HC_{2,new,y}$ | GJ/year | See Table B.1-7 | - | 356 171 |
| Utilizing boilers efficiency factor | $\eta_{BWW,2,new,y}$ | - | Similar boilers tests data [R4] | - | 0.85 |
| Heat share for auxiliary needs | $HA_{2,new,y}$ | - | Assumed | - | 0.07 |
| Amount of the generated power | $EC_{2,y}$ | MWh/year | See Table B.1-8 | - | 21 655 |
| Turbine electromechanical efficiency | $\eta_{em,2,turb,y}$ | - | Assumed | - | 0.95 |
| Heat flow efficiency | $\eta_{hs,2,turb,y}$ | - | Assumed | - | 0.98 |
| Gross heat generation | $HG_{gross,2,new,y}$ | GJ/year | $HG_{gross,2,new,y} = \frac{3,6 \times \frac{EC_{2,y}}{\eta_{em,2,turb,y}} + HC_{2,new,y}}{\eta_{hs,2,turb,y} - HA_{2,new,y}}$ | - | 481 659 |
| Factor of power generation based on heat output | χ | MWh/GJ | Estimation taking into account steam conditions at the turbine input and output | - | 0.0573 |

¹ In the calculation heat losses at heat transporting from the new boiler house to the dryers were not calculated separately as the boiler house is located at the enterprise's territory and the technical state of the heating conduits insulation meets all modern requirements unlike the heating conduits of the old boiler house. These heat losses are attributed to auxiliary needs both under the baseline and under the project.

| Name | Symbol | Unit | Justification | Base Line | Project |
|---|---------------------|----------------------|---|---------------|----------------|
| Heat with waste steam | $HC_{out,2,turb,y}$ | GJ/year | $HC_{out,2,turb,y} = \frac{EC_{2,y}}{\chi}$ | - | 378 058 |
| Heat consumption for CHP plant auxiliary ¹ | $HC_{aux,2,new,y}$ | GJ/year | $HC_{aux,2,new,y} = HA_{2,new,y} \times HG_{gross,2,new,y}$ | - | 33 716 |
| Steam consumption through reducing and cooling installation | $HC_{red,2,new,y}$ | GJ/year | $HC_{red,2,new,y} = HS_{2,new,y} + HC_{aux,2,new,y} - HC_{out,2,turb,y}$ | - | 11 830 |
| BWW consumption | $FC_{BWW,2,new,y}$ | m ³ /year | $FC_{BWW,2,new,y} = HG_{gross,2,new,y} / (\eta_{BWW,2,old,y} \times NCV_{BWW,2,y} \times \rho_{BWW})$ | - | 96 051 |
| On the whole | | | | | |
| Total BWW consumption at the sawmill | $FC_{BWW,2,y}$ | m ³ /year | $FC_{BWW,2,y} = FC_{BWW,2,auto,y} + FC_{BWW,2,old,y} + FC_{BWW,2,new,y}$ | 93 216 | 120 697 |

Coal consumption

The coal is used in the boiler-house of the motor transport shop (MTS). However by 2006, it was almost completely replaced by BWW and at present, its use is minimal (Table B.1-10).

Table B.1-10. Coal consumption in the boiler-house of MTS (actual)

| Year | 2003 | 2004 | 2005 | 2006 |
|---------------------|-------|-------|------|------|
| Coal consumption, t | 790.3 | 569.7 | 75.0 | 15.0 |

Under the project, heat for the MTS will be supplied by the new CHP plant. The old coal boiler-house will be dismantled. However, taking into account the insignificance of coal consumption and following the conservative approach, coal consumption is assumed zero both in the baseline and in the project scenarios and is not further addressed in the PDD.

Fuel oil consumption

In the last several years, fuel oil consumption was very insignificant. According to the enterprise's reports, in 2005, fuel oil was not used at all, while in 2006, fuel oil consumption was only 2.5 tons.

The baseline fuel oil consumption is determined by the necessity of additional heat energy generation in the old boiler house to cover the shortage of heat that can be generated with the use of BWW (see above). The calculations shows that at sawing capacity 600 000 m³ per year, it will be necessary to burn **1 493** tones of fuel oil per year (see Table B.1-11).

Under the project, it is not necessary to burn fuel oil as the utilizing capacities of the old boiler house and the new CHP plant are more then enough to meet the needs of the sawmill and the residence sector. However in monitoring the account of fuel oil is stipulated.

¹ It is assumed that auxiliary heat consumption by CHP plant is covered by waste steam from the turbine

Table B.1-11. Fuel oil consumption at the Maimaksa production site under baseline (calculation)

| Name | Symbol | Unit | Justification | Value |
|--|----------------------|----------|---|--------------|
| Useful output of heat energy owing to fuel oil burning | $HC_{oil,2,old,y}$ | GJ/year | $HC_{oil,2,old,y} = HC_{2,y} - HC_{BWW,2,old,y} - HC_{2,auto,y}$ | 50 311 |
| Net calorific value of fuel oil | $NCV_{oil,2,y}$ | GJ/ton | Reference data [R5] | 39.81 |
| Oil-fired boilers efficiency | $\eta_{oil,2,old,y}$ | - | Rated index | 0.91 |
| Heat share for auxiliary needs | $HA_{oil,2,old,y}$ | - | Assumed | 0.07 |
| Fuel oil consumption | $FC_{oil,2,old,y}$ | ton/year | $FC_{oil,2,old,y} = \frac{HC_{oil,2,old,y}}{NCV_{oil,2,y} \times \eta_{oil,2,old,y} \times (1 - HA_{oil,2,old,y})}$ | 1 493 |

Dumped BWW

Due to the project, the amount of dumped BWW decreases by the amount of BWW additionally utilized as fuel, which is $120\,697 - 93\,216 = 27\,481\text{ m}^3$ per year. This will result in avoided methane emissions from the landfill. The calculations of avoided emissions of methane since 2008 are provided in Section E. Calculations of the GHG emissions reductions at the Maimaksa production site for the whole reporting period 2008-2012 are provided in Annexes 2.5-2.8.

B.2. Description of how the anthropogenic emissions of greenhouse gases by sources are reduced below those that would have occurred in the absence of the JI project:

(a) Description of the baseline scenario

The baseline scenario stipulates continuation of the existing practice of energy supply to the mill which includes:

- power supply from the grid at both Tsiglomen and Maimaksa sites;
- supply of heat to Tsiglomen production site from the external boiler house by JSC “Arkhangelsk generating company”;
- self production of heat at Maimaksa production site in old boiler house.

Under this scenario up to $93\,216\text{ m}^3$ of BWW (mostly saw dust and wood chips) would be utilized annually by the mill for heat production, another $87\,740\text{ m}^3$ of BWW would be supplied outside to Archangelsk and/or Solombala PPMs, and the rest $57\,843\text{ m}^3$ of BWW (mostly bark) dumped in the landfill. To produce heat for the mill’s needs, up to 5 080 tonnes of fuel oil would be combusted at Tsiglomen boiler house by JSC “Arkhangelsk generating company”, and up to 1 493 tonnes of fuel oil would be combusted for production of heat at Maimaksa production site by the mill itself. In the coming future the external boiler house rented by JSC “Arkhangelsk generating company” can be switched to coal which is much cheaper than fuel oil, but for conservative reasons this option has not been examined in the PDD since it leads to higher GHG emissions under the baseline and hence, to increased GHG emission reductions under the project. It was assumed that the boiler house would continue running on fuel oil at least until the end of 2012.

(b) Description of the project scenario

The project aims at self supply of heat to both Tsiglomen and Maimaksa production sites of the mill and to self supply of power to Maimaksa production site using exclusively BWW coming internally from processing of wood. The project includes:



- construction of a new 5 MW BWW boiler house worth €2 million at Tsiglomen production site where the minority of final timber products (dry saw materials) is produced, and
- construction of a new 15 MW BWW combined heat power (CHP) plant with 2.2 MW turbine, altogether worth €9.5 million, at Maimaksa production site where the most of the mill's production capacity is located.

For both components, water heating and steam boilers are supplied by the well known manufacturer "Polytechnik", Austria. The first project component, new boiler house at Tsiglomen site, became operational in late 2005.

The project will make it possible to utilize additionally up to 57 843 m³ of BWW per annum (thus prevailing their dumping in the landfill¹), and to substitute with BWW up to 6 573 tonnes/year of fuel oil used for production of heat both at the mill and at the outside boiler house, and up to 21 655 MWh/year of power supplied from the grid. No fossil fuel is intended for combustion together with BWW, and the share of bark fed into the boilers can be up to 100%.

This alternative requires from SM-25 to find €11.5 million of investments and additional operational costs associated with construction and running of new energy facilities thus making SM-25 to use available investment resources (both equity and loans) for improving and increasing of its main production capacities, including implementation of energy saving technologies at sawing and drying, as envisaged in the mill's corporate development and investment plan adopted in 2002.

(c) Additionality of emission reductions

To prove additionality of the project against the baseline, analysis of alternatives as well as barriers and common practice tests have been applied.

Analysis of alternatives to the project activity

The alternatives are described below for Tsiglomen and Maimaksa production sites separately.

Tsiglomen production site

The following alternatives are identified for the project activity at Tsiglomen production site:

- Alternative 1: The continuation of the existing practice of heat energy supply by the municipal boiler house working on fuel oil.
- Alternative 2: Construction of its own boiler house working on fuel oil.
- Alternative 3: Construction of its own boiler house working on coal.
- Alternative 4: Construction of its own boiler house working on natural gas.
- Alternative 5: Construction of its own boiler house working on BWW without participation in JI project.

Let us perform more detailed analysis of each alternative.

Alternative 1: The continuation of the existing practice of heat energy supply by the municipal boiler house working on fuel oil.

Before the project implementation heat was supplied by the municipal boiler house. The boiler house has been rented by JSC "Arkhangelsk generating company" since 2006. The boiler house works on fuel oil as the leaser is not interested in using BWW as fuel. This situation is largely explained by imperfection of state tariff policy which does not stimulate using local kinds of fuel. More complex technologies are

¹ Following the conservative approach we assume that volumes of BWW sale under the project would not be less than under the baseline.



necessary to use local kinds of fuel. At present conditions it is technologically easier and economically more profitable to burn fuel oil in existing boiler-house shifting fuel oil cost on consumers' shoulders through tariffs.

In principle this situation was convenient for Sawmill 25 which could avoid considerable costs connected with construction and maintenance of its own source of heat energy.

BWW formed at Tsiglomen site are partly sold while the remains are dumped. Bark is dumped first of all as the technologies of its burning are not introduced under the baseline scenario. The main purchaser of BWW is Arkhangelsk pulp and paper mill (APPM) which has preinstalled BWW utilizing capacities. Apart from APPM, only Solombala pulp and paper mill (SPPM) has sawdust-burning capacities. Both mills have limited opportunities for receiving BWW from outside. Moreover, the installed capacities of the two mills do not make even for complete utilization of bark formed at their own sites. Therefore, they have to dump their own bark too.

In the absence of the Kyoto mechanisms that in fact is anticipated in the baseline scenario, neither two mentioned PPMs, i.e. APPM and SPPM, nor other enterprises in the area have interest and/or incentives to increase BWW burning capacities. This is proved by the numerous BWW landfills situated practically near each wood processing enterprise and by extremely weak development of BWW utilizing capacities in the region. Therefore, under the baseline scenario, a big part of remaining BWW at the Tsiglomen site would not find market demand and would thus be dumped at the landfill.

This alternative can be considered as most likely baseline scenario.

Alternative 2: Construction of its own boiler house working on fuel oil.

This alternative was excluded from review as it is known irrational to construct its own source of heat supply working on fuel oil similar to the municipal boiler house which has excessive capacity. This scenario does not provide any economic benefit for the mill.

Alternative 3: Construction of its own boiler house working on coal.

Switch to coal is unlikely as coal burning technology is rather complicated and requires alienation of large territories for fuel store and ash-and-slag landfill. It would be quite problematic as the enterprise does not dispose of extra areas. Besides more harmful emissions into the atmosphere are formed at coal burning compared with burning of other kinds of fuel. And from this point of view there could arise considerable difficulties regarding the project's approval by environmental bodies. Installation of highly efficient cleaning facilities, for instance, electric filters would be required to capture ash particles that would raise the project's cost. Based on the above mentioned we may state that switch of the boiler house to coal would be accompanied by considerable technical and ecological barriers. *This alternative was excluded* from review.

Alternative 4: Construction of its own boiler house working on natural gas.

This alternative was excluded from review as gasification of Arkhangelsk and its suburbs is not expected in the nearest future (at least till 2012). Moreover when natural gas will come to Arkhangelsk its price would unlikely be competitive to the price of coal and heavy oil. Federal authorities and JSC "Gazprom" speak at every turn about necessity to raise price for gas explaining this by too large share of gas in Russia's energy balance and forthcoming entrance of Russia into WTO.

Alternative 5: Construction of its own boiler house working on BWW without participation in JI project.

This alternative faces substantial technological, operational and financial barriers and also does not represent common practice in the industry at all (see below).

This alternative requires from SM-25 to find €2 million of investments and then bear additional operational costs associated with running of new boiler house thus making SM-25 to use available investment resources (both equity and loans) for improving and increasing of its main production capacities. All the more heat supply by the existing municipal boiler house was quite convenient for the sawmill.



Thus in the absence of JI mechanism and additional revenue from selling of GHG emission reductions *this scenario could hardly have been implemented.*

Maimaksa production site

The following alternatives are identified for this project activity:

Alternative 1: The continuation of the existing practice of heat energy supply by its own boiler house and electricity supplied from the grid.

Alternative 2: Construction of its own CHP plant working on fuel oil.

Alternative 3: Construction of its own CHP plant working on coal.

Alternative 4: Construction of its own CHP plant working on natural gas.

Alternative 5: Construction of its own CHP plant working on BWW without participating in JI project.

Let us perform more detailed analysis of each alternative.

Alternative 1: The continuation of the existing practice of heat energy supply by its own boiler house and electricity supplied from the grid.

This alternative is most probable without Kyoto Protocol as the enterprise already had its own source of heat energy supply and the purchase of electricity from the grid is common practice at sawmills in Russia.

If wood sawing reached up to 600 thousand m³ per year utilizing boilers capacities would not be enough to generate all necessary heat energy. Maximum capacity of BWW burning in the boiler houses makes about 93 thousand m³/year. Heat energy shortage would be covered owing to fuel oil combustion up to 1.5 thousand tons per year. Coal consumption is assumed equal zero.

Similar to the Tsiglomen production site here it is impossible to sell all BWW surplus to nearby enterprises as well as they would not be much interested in the increase of amount of BWW used as fuel without Kyoto mechanisms. BWW which did not find demand would be dumped.

This alternative can be considered as most likely baseline scenario.

Alternative 2: Construction of its own CHP plant working on fuel oil.

This alternative was excluded from review as construction of energy source working on fuel oil is economically inexpedient due to high fuel cost.

Alternative 3: Construction of its own CHP plant working on coal.

This alternative was excluded from review due to the reasons similar to Tsiglomen production site.

Alternative 4: Construction of its own CHP plant working on natural gas.

This alternative was excluded from review due to the reasons similar to Tsiglomen production site.

Alternative 5: Construction of its own CHP plant working on BWW without participating in JI project.

This alternative would be senseless without participation in JI project under the Kyoto Protocol as the enterprise already had its own source of heat energy working mainly on BWW and covering the needs of both the enterprise and the housing estate. The purchase of electricity from the grid is common practice and does not require rather risky costs for purchase and maintenance of electrogenerating facilities.

This alternative requires from SM-25 to find €9.5 million of investments and then bear additional operational costs associated with running of CHP plant thus making SM-25 to use available investment resources (both equity and loans) for improving and increasing of its main production capacities.



Thus in the absence of JI mechanism and additional revenue from selling of GHG emission reductions *this scenario could hardly have been implemented.*

Barrier analysis

Implementation of the project at Sawmill-25 faces substantial barriers in terms of technology, operations and finance.

Technological barriers

Bark and wood waste are difficult-to-burn kinds of fuel due to their high humidity and heterogeneous breakup. Technologies for their burning are more complicated and expensive compared with technologies for burning gas and liquid fuel correspondingly.

High humidity of bark and wood waste causes decrease of their calorific value, adiabatic burning point, furnace process stability and finally efficiency of the whole boiler unit operation. For comparison: fuel oil and gas boilers efficiency factor – 89-93%, BWW boilers - 70-85%.

BWW breakup should be optimal for this furnace unit. Increasing or decreasing deviation of particles size from optimal size reduces the efficiency of the boiler operation. Too small particles can fall through fire grates and be carried out of furnace by smoke fumes without even beginning to burn. Large particles can put fuel feeding system out of operation and prevent from normal burning conditions in the furnace.

Construction of special covered fuel store with “moving” bed is required to feed BWW into the boiler.

Besides BWW boilers should have increased tail and convective heating surfaces which provide decrease of waste gases temperature down to 110-120 °C.

As BWW contain mineral admixtures which produce ash and slag at burning it is necessary to install an additional highly efficient fly-ash collector. According to the experience of other enterprises it can be mentioned that when the operation of fly-ash collectors is unsatisfactory large amount of ash particles are thrown out precipitating on ready production (lumber piles) at the storage yard and thus decreasing its quality. Such production is not suitable for export any more. In this case the enterprise has large financial losses. It is a very important risk factor.

It is necessary to bring slag and ash produced in the process of burning out of the furnace and fly-ash collectors and to transport them to ash-and-slag landfill periodically.

Russian industry does not manufacture BWW boilers that can burn BWW without any fossil fuel added. As mentioned bark is utilized in Russia for energy purposes to a very small extent due to its extremely high humidity content and low calorific value. Technologies that enable effectively retrieve energy from BWW, especially from bark, are only available in the US (e.g. Wellons) and Europe (e.g. Polytechnik, Vartsilla etc). These technologies are rather complicated, and because of that an advanced measurement and automatic control system had to be installed to provide for the smooth running of the boilers. Otherwise, there was a risk of technological breakdown of the boilers.

SM-25 had never built or exploited BWW boilers of such type. All the more SM-25 never exploited steam turbines.

Altogether it was a real challenge for SM-25 to implement the project. That is why the project was divided into two stages of which the first stage envisaged construction of a small boiler house at the minor production site to test the technology and the equipment and the second stage was designed with reference to the results of the first stage and envisaged construction of mini BWW CHP plant at the major production site of the mill to provide for both heat and power generation from BWW.

Operational barriers

SM-25 had to overcome certain difficulties not only during the installation phase but also during operation. Workers engaged in the operation of the boilers had to be hired, trained and certified by the supplier. This involved certain costs and time. Besides, operation of the high-tech energy equipment and technology requires higher motivation as well as improved culture, skills and knowledge from all staff



including workers, engineers and managers. It also bears noting that high humidity content and low calorific values of bark creates a problem which requires permanent attention while operating the project.

Exploiting of turbines requires their synchronization with frequency of electric current in the grid. SM-25 has no experience of operation of electrogenerating facilities at all.

Financial barriers

Among the financial barriers, the following are worth mentioning:

- High investment costs (€11.5 million) due to high cost of imported equipment, with delivery costs and custom duties included, and high cost of civil works for construction and assembly;
- High alternative cost of capital. Investment in improving and increasing of the main production capacities, including implementation of modern energy saving technologies at sawing and drying, can bring much bigger benefit to the owners being comparable in size with the project;
- Additional operational costs are required to operate and maintain the new installations;
- Internal use of BWW for energy purpose can in future prevent the mill from increasing sales of BWW to the outside buyers in raw and/or as wood pellets. This would mean additional costs to the mill in terms of missed profit;
- Lack of adequate sources for project funding in the Russian Federation. Because of this, SM-25 had to apply to NEFCO for a long-term loan targeted at pollution abatement and at creation of carbon credits.

Commercial risks

- Due to the risk of periodical decrease of heat energy quality, risk of decrease of quality of the end products also exists, as the stability of heat carrier's parameters influences the longitude and quality of wood desiccation.
- Apart from that, the quality can be influenced by ash emissions from chimney. This spoiled timber is not suitable for export any more.
- As a result, utilisation of BWW as a fuel gives rise to questions of decreasing quality of end products and thus commercial risks.
- Besides, internal use of BWW for energy purpose can in future prevent the mill from increasing sales of BWW to the outside buyers in raw and/or as wood pellets that would result in commercial losses.

Due to these barriers the mill have been seeking the opportunity to sell ERUs and also early carbon credits that can be generated before 2008 which issue was discussed by the mill with Environmental Investment Center back in 2002 (Annex 2.9), with NEFCO in 2006 (Annex 2.10), and finally with Camco who was selected by the mill particularly (though not only) because Camco has an access to voluntary carbon markets worldwide.

Common practice analysis

The common practice in the power system of sawmills in Russia includes:

1. Electricity supply from the grid.
2. Heat supply from own boiler houses working on BWW with fuel oil or natural gas adding for flame stabilization.
3. Among BWW sawdust is mainly used as fuel.
4. Bark is mainly dumped.



Electricity supply from the grid is really common practice for sawmills in Russia. Rate of capital costs on low capacity turbines is higher compared with turbines installed at large CHP plants. Efficiency of heat and electricity generation at large CHP plants is higher compared with small CHP plants. Besides domestic industry has not produced low capacity 0.5-2 MW turbines till recently. Therefore it has been more profitable for the sawmills to purchase electricity from the grid instead of generating it themselves. The necessity to have nearby heat supply source is defined by the fact that heat energy (especially steam) cannot be transported to long distances due to large losses, while electricity can be transported to hundreds of kilometers.

Sawdust burning is common practice as furnace equipment (mainly produced domestically) installed at most sawmills is rather efficient and allows burning only sawdust without fuel oil adding. Mainly series-produced boilers of Biysky boiler factory equipped with Pomerantsev furnace extension are used for that purpose. Bark is mainly dumped because of its complicated burning. Therefore decision to install import energy equipment that can work only on bark is outside common practice in Russia.

Factors characterizing common Russian practice which does not stimulate BWW utilization as fuel include:

- no laws on BWW utilization in Russian Federation;
- relatively low set payment for BWW dumping;
- no system of state control on BWW production and utilization;
- imperfection of state tariff policy for heat energy and electricity;
- no expected significant changes of environmental legislation in Russia which could force enterprises to refuse operation of the old equipment;
- no limitations on GHG emissions exist and are expected for enterprises in Russia;
- as a rule, enterprises have all necessary permits for operation of existing equipment and landfills including those of ecological character agreed with relevant control bodies.

Back at the time the project started it was and still is a new and unusual example of investing into new energy facilities in Russian timber industry. In most cases timber companies uses existing energy sources either external, or internal. The innovative character of the project becomes even more obvious if one would take into account that the old boiler house which used to supplying heat to Tsiglomen site of SM-25 is situated on the same site, literally at now material distance from it. In most cases, industrial companies would buy such energy facilities at rather small price to reduce their energy costs instead of spending some €2 million on new boiler house running totally on BWW.

The second project component at Maimaksa site is even more innovative since the common practice in the industry is power supply from the grid. So the decision to invest €9 million in construction of the own mini CHP plant running totally on BWW at Maimaksa site to avoid the use of heavy oil as well as power supply from the grid can be really considered a pioneer project in the industry.

And finally, it is worth noting that traditionally in Russia bark is not used or is only used in a very small proportion (less than 20%) with saw dust and other woodwaste in the boiler houses and CHP plants. Moreover, in most cases BWW is combusted together with heavy oil. From this prospective, the project at Sawmill-25 aimed at combustion of up to 100% of bark without any fossil fuel added is definitely a technological breakthrough.

Referencing to the above the reductions obtained as a result of the project are additional to any that would otherwise occur.

B.3. Description of how the definition of the project boundary is applied to the project:

Fig. B.3-1 represents the principal components and boundaries of the project. At the same time, the diagram shows the main flows of fuel, steam and biomass waste.




Fig. B.3-1. Principal components and boundaries of the project

Table B.3-1 specifies particular gases and sources which are included in and excluded from the project boundaries. The same table indicates possible leakages.

Table B.3-1. Sources of emissions included in and excluded from consideration

| | Source | Gas | Incl./Excl. | Justification/Explanation | |
|---|----------------------------------|---|-------------------------------------|---------------------------|--|
| Baseline | Tsiglomen production site | Old boiler-house, fuel oil burning | CO₂ | Incl. | Main source of emissions |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | | Landfill of industrial waste, avoided (owing to the project) emissions from anaerobic decomposition of BWW | CO ₂ | Excl. | Assumed to be equal to zero |
| | | | CH₄ | Incl. | Main source of emissions |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | Maimaksa production site | Old boiler-house, fuel oil burning | CO₂ | Incl. | Main source of emissions |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | | Old boiler-house, BWW burning | CO ₂ | Excl. | Assumed to be equal to zero |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | | Coal boiler-house of MTS, coal burning | CO ₂ | Incl. | Coal consumption is very insignificant. Conservative |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | | Coal boiler-house of MTS, BWW burning | CO ₂ | Incl. | Assumed to be equal to zero |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| | | Outside power suppliers, combustion of fossil fuel (power replaced due to the project) | CO₂ | Incl. | Main source of emissions |
| | | | CH ₄ | Excl. | Considered negligible. Conservative |
| | | | N ₂ O | Excl. | Considered negligible. Conservative |
| Landfill of industrial waste, avoided emissions from anaerobic decomposition of BWW (due to the project) | CO ₂ | Excl. | Assumed to be equal to zero | | |
| | CH₄ | Incl. | Main source of emissions | | |
| | N ₂ O | Excl. | Considered negligible. Conservative | | |



| | | Source | Gas | Incl./Excl. | Justification/Explanation |
|------------------|--|------------------------------------|------------------|---|-----------------------------|
| Project activity | Tsiglomen production site | Old boiler-house, fuel oil burning | CO ₂ | Incl. | Main source of emissions |
| | | | CH ₄ | Excl. | Considered negligible. |
| | | | N ₂ O | Excl. | Considered negligible. |
| | | New boiler-house, BWW burning | CO ₂ | Excl. | Assumed to be equal to zero |
| | | | CH ₄ | Excl. | Considered negligible. |
| | | | N ₂ O | Excl. | Considered negligible. |
| | Maimaksa production site | Old boiler-house, BWW burning | CO ₂ | Excl. | Assumed to be equal to zero |
| | | | CH ₄ | Excl. | Considered negligible. |
| | | | N ₂ O | Excl. | Considered negligible. |
| | | New CHP plant, BWW burning | CO ₂ | Excl. | Assumed to be equal to zero |
| | | | CH ₄ | Excl. | Considered negligible. |
| | | | N ₂ O | Excl. | Considered negligible. |
| Leakages | Reduction of the amount of produced and transported fossil fuels | CO ₂ | Excl. | Considered to be an insignificant source of emissions. Conservative | |
| | | CH ₄ | Excl. | Considered to be an insignificant source of emissions. Conservative | |
| | | N ₂ O | Excl. | Considered negligible. Conservative | |

B.4. Further baseline information, including the date of baseline setting and the name(s) of the person(s)/entity(ies) setting the baseline:

Date of BL setting – 30 December 2006

BL was developed by Camco International

Contact person: Vladimir Dyachkov

E-mail: vladimir.dyachkov@camco-international.com



SECTION C. Duration of the project / crediting period

C.1. Starting date of the project:

April 2005 (starting of construction of the boiler house at Tsiglomen production site)

C.2. Expected operational lifetime of the project:

25 years/300 months

C.3. Length of the crediting period:

5 years/ 60 months (Kyoto Protocol first commitment period – from 1st January 2008 to 31st December 2012)



SECTION D. Monitoring plan

D.1. Description of monitoring plan chosen:

On the whole, all the key parameters required for determination of GHG emissions reductions are collected in accordance with the practice of registration of fuel, energy, waste and assessment of environmental impact used at “Sawmill 25”.

Sources of energy are provided with modern equipment which registers energy resources. Project monitoring will not require changes into the existing and newly mountable systems of data registration and collection. All the necessary data is determined and registered in any case.

Annex 3 includes additional data on major sources of information.

D.1.1. Option 1 – Monitoring of the emissions in the project scenario and the baseline scenario:

This Option is not applied to monitoring the project

D.1.1.1. Data to be collected in order to monitor emissions from the project, and how these data will be archived:

| ID number <i>(Please use numbers to ease cross-referencing to D.2.)</i> | Data variable | Source of data | Data unit | Measured (m), calculated (c), estimated (e) | Recording frequency | Proportion of data to be monitored | How will the data be archived? (electronic/ paper) | Comment |
|--|---------------|----------------|-----------|---|------------------------|--|--|---------|
| | | | | | | | | |
| | | | | | | | | |

D.1.1.2. Description of formulae used to estimate project emissions (for each gas, source etc.; emissions in units of CO₂ equivalent):

D.1.1.3. Relevant data necessary for determining the baseline of anthropogenic emissions of greenhouse gases by sources within the project boundary, and how such data will be collected and archived:

| ID number <i>(Please use numbers to ease cross-referencing to D.2.)</i> | Data variable | Source of data | Data unit | Measured (m), calculated (c), estimated (e) | Recording frequency | Proportion of data to be monitored | How will the data be archived? (electronic/ paper) | Comment |
|--|---------------|----------------|-----------|--|------------------------|--|---|---------|
| | | | | | | | | |
| | | | | | | | | |

**D.1.1.4. Description of formulae used to estimate baseline emissions (for each gas, source etc.; emissions in units of CO₂ equivalent):****D. 1.2. Option 2 – Direct monitoring of emission reductions from the project (values should be consistent with those in section E.):****D.1.2.1. Data to be collected in order to monitor emission reductions from the project, and how these data will be archived:**

| ID number (Please use numbers to ease cross-referencing to D.2.) | Data variable | Source of data | Data unit | Measured (m), calculated (c), estimated (e) | Recording frequency | Proportion of data to be monitored | How will the data be archived? (electronic/ paper) | Comment |
|---|--|--|-----------|---|---------------------|------------------------------------|--|--|
| TSIGLOMEN PRODUCTION SITE | | | | | | | | |
| 1. $HS_{1,new,y}$ | Heat energy supply from the new boiler house | Department of head energy engineer | GJ | m | Continuously | 100 % | Electronic and paper | Heat meter readings |
| 2. $NCV_{BWW,1,y}^{dry}$ | Net calorific value of BWW on dry mass | Heat engineering laboratory of ASTU ¹ | GJ/t | m | Quarterly | 100 % | Electronic and paper | The average value is determined at the end of the year |
| 3. $W_{BWW,1,y}$ | Moisture of BWW | Heat engineering laboratory of ASTU | % | m | Monthly | 100 % | Electronic and paper | The average value is determined at the end of the year |
| MAYMAKSA PRODUCTION SITE | | | | | | | | |
| 4. $HG_{gross,2,new,y}$ | Gross heat generation at the new CHP plant | Department of head energy engineer | GJ | m | Continuously | 100 % | Electronic and paper | Steam-flow meter readings |
| 5. $HS_{2,new,y}$ | Heat energy supply from the new CHP plant | Department of head energy engineer | GJ | m | Continuously | 100 % | Electronic and paper | Heat meter readings |

¹ ASTU – Arkhangelsk State Technical University



| | | | | | | | | |
|---|---|-------------------------------------|------|---|-------------------------------------|-------|----------------------|--|
| 6. <i>HS</i> _{2,old,PJ,y} | Heat energy supply from the old boiler house | Department of head energy engineer | GJ | m | Continuously | 100 % | Electronic and paper | Heat meter readings |
| 7. <i>EG</i> _{2,new,y} | Gross electric power generation at the new CHP plant | Department of head energy engineer | MWh | m | Continuously | 100 % | Electronic and paper | Power meter readings |
| 8. <i>NCV</i> _{BWW,2,y} ^{dry} | Net calorific value of BWW on dry mass | Heat engineering laboratory of ASTU | GJ/t | m | Quarterly | 100 % | Electronic and paper | The average value is determined at the end of the year |
| 9. <i>W</i> _{BWW,2,y} | Moisture of BWW | Heat engineering laboratory of ASTU | % | m | Monthly | 100 % | Electronic and paper | The average value is determined at the end of the year |
| 10. <i>FC</i> _{oil,2,PJ,y} ^m | Mass fuel oil consumption at Maimaksa production site | Department of head energy engineer | t | m | Monthly | 100 % | Electronic and paper | Readings of level meter in the fuel oil storage tank |
| 11. <i>NCV</i> _{oil,2,y} | Net calorific value of fuel oil | Certification of fuel | GJ/t | m | For each incoming batch of fuel oil | 100 % | Electronic and paper | The average value is determined at the end of the year |

D.1.2.2. Description of formulae used to calculate emission reductions from the project (for each gas, source etc.; emissions/emission reductions in units of CO₂ equivalent):

The formula to calculate total GHG emission reductions in the year y is, t CO₂-eq:

$$ER_y = ER_{1,y} + ER_{2,y}, \quad (D.1-1)$$

where $ER_{1,y}$ is total GHG emission reductions at the Tsiglomen production site over a year y, t CO₂-eq;

$ER_{2,y}$ is total GHG emission reductions at the Maimaksa production site over a year y, t CO₂-eq.

**TSIGLOMEN PRODUCTION SITE**

GHG emission reductions at Tsiglomen production site over a year y , t of CO₂-eq:

$$ER_{1,y} = ER_{oil,1,old,y} + ER_{BWW,dump,1,y}, \quad (D.1-2)$$

where $ER_{oil,1,old,y}$ is CO₂ emission reductions from fuel oil burning at the old (municipal) boiler house over a year y , t CO₂;

$ER_{BWW,dump,1,y}$ is CH₄ emission reductions from anaerobic decomposition of dumped BWW over a year y , t CO₂-eq.

$$ER_{oil,1,old,y} = \frac{HS_{1,new,y}}{\eta_{oil,1,old,y} \times (1 - HA_{oil,1,old,y})} \times EF_{CO_2,oil}, \quad (D.1-3)$$

where $HS_{1,new,y}$ is heat energy supply from the new boiler house over a year y , GJ;

$\eta_{oil,1,old,y}$ is efficiency factor for oil-fired boilers of the old boiler house. According to Section B.1 it is taken constant and equal to 0.753;

$HA_{oil,1,old,y}$ is share of heat for auxiliary needs of oil-fired boilers. According to Section B.1 it is taken constant and equal to 0.07;

$EF_{CO_2,oil}$ is emission factor of CO₂ for fuel oil, t CO₂/GJ. According to IPCC Tier 1 [R11] this factor is taken as constant and equal to $EF_{CO_2,oil} = 21.1 \times 44 / 12 \times 0.99 / 1000 = 0.07659$ t CO₂/GJ.

Numerical values of $ER_{BWW,dump,1,y}$ are determined by the “Calculation of CO₂-equivalent emission reduction from BWW prevented from stockpiling or taken from stockpiles” model developed by BTG biomass technology group B.V. on the basis of [R12].

The values of constants used in the model are explained and justified in Section E.

In this model variable parameter for a year y is mass amount of BWW burnt at the new boiler house $FC_{BWW,1,new,y}^m$ over a year y , t :

$$FC_{BWW,1,new,y}^m = \frac{HS_{1,new,y}}{\eta_{BWW,1,new,y} \times (1 - HA_{BWW,1,new,y}) \times NCV_{BWW,1,y}}, \quad (D.1-4)$$

where $\eta_{BWW,1,new,y}$ is efficiency factor for the new utilizing boilers. According to test data [R4] it is taken constant and equal to 0.85;

$HA_{BWW,1,new,y}$ is share of heat for auxiliary needs of the new utilizing boilers. According to Section B.1 it is taken constant and equal to 0.07;



$NCV_{BWW,1,y}$ is BWW net calorific value on working mass, GJ/t.

$$NCV_{BWW,1,y} = NCV_{BWW,1,y}^{dry} \frac{100 - W_{BWW,1,y}}{100} - 24.42 \times 10^{-3} \times W_{BWW,1,y} , \quad (D.1-5)$$

where $NCV_{BWW,1,y}^{dry}$ is BWW net calorific value on dry mass, GJ/t;

$W_{BWW,1,y}$ is BWW moisture, %;

24.42 is evaporation heat per 1 % moisture of fuel (or 2 442 kJ/kg of water).

MAIMAKSA PRODUCTION SITE

GHG emission reductions at Maimaksa production site over a year y , t of CO₂-eq:

$$ER_{2,y} = ER_{grid,2,y} + ER_{oil,2,y} + ER_{BWW,dump,2,y} , \quad (D.1-6)$$

where $ER_{grid,2,y}$ is CO₂ emission reductions from fossil fuel burning at grid-connected electric power plants over a year y , t CO₂

$ER_{oil,2,y}$ is CO₂ emission reductions from fuel oil burning at Maimaksa production site over a year y , t CO₂;

$ER_{BWW,dump,2,y}$ is CH₄ emission reductions from anaerobic decomposition of dumped BWW over a year y , t CO₂-eq.

$$ER_{grid,2,y} = EG_{2,new,y} \times EF_{CO_2,grid,y} , \quad (D.1-7)$$

where $EG_{2,new,y}$ is gross electric power generation at the new CHP plant over a year y , MWh;

$EF_{CO_2,grid,y}$ is CO₂ emission factor for power from grid. According to the special research “Power and district heating emission baselines. ECON Analysis. 2005” [R13] this factor for Arkhangelsk region of Russia till 2012 have been taken equal to $EF_{CO_2,grid,y} = 0.68$ t CO₂/MWh.

Baseline power consumption for auxiliary needs of energy sources at Maimaksa production site are considered to be not less than under the project with the same total useful heat supply ($HS_{2,new,y} + HS_{2,old,y}$). It means that power consumption under the project for auxiliary of the new CHP plant will be compensated by reduction of power consumption for the auxiliary of the old boiler house. In this connection it is enough to monitor in particular gross generation of power which would be supplied from the outside grid in the case of baseline.



$$ER_{oil,2,y} = (FC_{oil,2,BL,y} - FC_{oil,2,PJ,y}) \times EF_{CO_2,oil}, \quad (D.1-8)$$

where $FC_{oil,2,BL,y}$ is fuel oil consumption at Maimaksa production site under the baseline over a year y , GJ;

$FC_{oil,2,PJ,y}$ is fuel oil consumption at Maimaksa production site under the project over a year y , GJ;

$EF_{CO_2,oil}$ is emission factor of CO₂ for fuel oil, t CO₂/GJ. As aforesaid this factor is taken as constant and equal to $EF_{CO_2,oil} = 0.07659$ t CO₂/GJ.

$$FC_{oil,2,BL,y} = \frac{HS_{2,new,y} + HS_{2,old,PJ,y} - FC_{BWW,2,BL,y}^{max} \times \rho_{BWW} \times NCV_{BWW,2,y} \times \eta_{BWW,2,old,y} \times (1 - HA_{BWW,2,old,y})}{\eta_{oil,2,old,y} \times (1 - HA_{oil,2,old,y})}, \quad (D.1-9)$$

$$FC_{oil,2,PJ,y} = FC_{oil,2,PJ,y}^m \times NCV_{oil,2,y}, \quad (D.1-10)$$

where $HS_{2,new,y}$ is heat energy supply from the new CHP plant over a year y , GJ;

$HS_{2,old,PJ,y}$ is heat energy supply from the old boiler house under the project over a year y , GJ;

$FC_{BWW,2,BL,y}^{max}$ is maximal volume of BWW burnt in the old boiler houses (including boiler house of the MTS) under the baseline over a year y , m³. According to Section B.1 it is taken constant and equal to 93 216 m³/year;

ρ_{BWW} is BWW density, t/m³. $\rho_{BWW} = 0.8$ t/m³ is enterprise's norm (typical density of softwood that is processed at the Sawmill 25);

$\eta_{BWW,2,old,y}$ is efficiency factor for the utilizing boilers of the old boiler houses. According to Section B.1 it is taken constant and equal to 0.813;

$\eta_{oil,2,old,y}$ is efficiency factor for the oil-fired boilers of the old boiler house. According to Section B.1 it is taken constant and equal to 0.91;



$HA_{BWW,2,old,y}$ is share of heat for auxiliary needs of the utilizing boilers. According to Section B.1 it is taken constant and equal to 0.07;

$HA_{oil,2,old,y}$ is share of heat for auxiliary needs of the oil-fired boilers. According to Section B.1 it is taken constant and equal to 0.07;

$NCV_{BWW,2,y}$ is BWW net calorific value on working mass, GJ/t.

$$NCV_{BWW,2,y} = NCV_{BWW,2,y}^{dry} \frac{100 - W_{BWW,2,y}}{100} - 24.42 \times 10^{-3} \times W_{BWW,2,y}, \quad (D.1-11)$$

where $NCV_{BWW,2,y}^{dry}$ is BWW net calorific value on dry mass, GJ/t;

$W_{BWW,2,y}$ is BWW moisture, %;

24.42 is evaporation heat per 1 % moisture of fuel (or 2 442 kJ/kg of water).

It should be noted that if $ER_{oil,2,y} < 0$ then is should be taken $ER_{oil,2,old,y} = 0$.

Numerical values of $ER_{BWW,dump,2,y}$ are determined by the “Calculation of CO₂-equivalent emission reduction from BWW prevented from stockpiling or taken from stockpiles” model developed by BTG biomass technology group B.V. on the basis of [R12].

The values of constants used in the model are explained and justified in Section E.

In this model variable parameter for a year y is mass difference of total BWW amounts burnt at the Maimaksa production site under the project and the baseline over a year y , t:

$$\Delta FC_{BWW,2,y}^m = \rho_{BWW} \times (FC_{BWW,2,PJ,y} - FC_{BWW,2,BL,y}), \quad (D.1-12)$$

where $FC_{BWW,2,PJ,y}$ is volume of BWW burnt at Maimaksa production site under the project over a year y , m³;

$FC_{BWW,2,BL,y}$ is volume of BWW burnt at Maimaksa production site under the baseline over a year y , m³;

It should be noted that if $\Delta FC_{BWW,2,y}^m < 0$ then is should be taken $\Delta FC_{BWW,2,y}^m = 0$.

$$FC_{BWW,2,PJ,y} = FC_{BWW,2,new,y} + FC_{BWW,2,old,PJ,y}, \quad (D.1-13)$$

where $FC_{BWW,2,new,y}$ is volume of BWW burnt at the new CHP plant over a year y , m³;



$FC_{BWW,2,old,PJ,y}$ is volume of BWW burnt at the old boiler house under the project over a year y , m^3 .

$$FC_{BWW,2,new,y} = \frac{HG_{gross,2,new,y}}{\eta_{BWW,2,new,y} \times NCV_{BWW,2,y} \times \rho_{BWW}}, \quad (D.1-14)$$

where $HG_{gross,2,new,y}$ is gross heat generation at the new CHP plant over a year y , GJ;

$\eta_{BWW,2,new,y}$ is efficiency factor for the utilizing boilers of the new CHP plant. According to test data [R4] it is taken constant and equal to 0.85.

$$FC_{BWW,2,old,PJ,y} = \frac{HS_{2,old,PJ,y} - FC_{oil,2,PJ,y} \times \eta_{oil,2,old,y} \times (1 - HA_{oil,2,old,y})}{\eta_{BWW,2,old,y} \times (1 - HA_{BWW,2,old,y}) \times NCV_{BWW,2,y} \times \rho_{BWW}} \quad (D.1-15)$$

$$FC_{BWW,2,BL,y} = \frac{HS_{2,new,y} + HS_{2,old,PJ,y}}{\eta_{BWW,2,old,y} \times (1 - HA_{BWW,2,old,y}) \times NCV_{BWW,2,y} \times \rho_{BWW}}, \quad (D.1-16)$$

if $FC_{BWW,2,BL,y} > 93\,216\,m^3$ then $FC_{BWW,2,BL,y} = 93\,216\,m^3$.

D.1.3. Treatment of leakage in the monitoring plan:

As shown in Section B.3 all of the leakages can be neglected.

D.1.3.1. If applicable, please describe the data and information that will be collected in order to monitor leakage effects of the project:

| ID number (Please use numbers to ease cross-referencing to D.2.) | Data variable | Source of data | Data unit | Measured (m), calculated (c), estimated (e) | Recording frequency | Proportion of data to be monitored | How will the data be archived? (electronic/ paper) | Comment |
|---|---------------|----------------|-----------|---|---------------------|------------------------------------|--|---------|
| | | | | | | | | |
| | | | | | | | | |

**D.1.3.2. Description of formulae used to estimate leakage (for each gas, source etc.; emissions in units of CO₂ equivalent):****D.1.4. Description of formulae used to estimate emission reductions for the project (for each gas, source etc.; emissions/emission reductions in units of CO₂ equivalent):**

See Section D.1.2.2.

D.1.5. Where applicable, in accordance with procedures as required by the host Party, information on the collection and archiving of information on the environmental impacts of the project:

A special environmental department is operating at the enterprise. The department's activities are guided by the acting legislation, orders and instructions of the Director General, prescriptions of the State environmental monitoring service of the Committee on natural resources of the Arkhangelsk Region. The department has at its disposal highly qualified personnel and is able to ensure appropriate environmental monitoring under the project.

The department monitors:

- gas-dust emissions;
- quality of waste water and river water;
- utilization, storage, transfer and burial of industrial waste.

In process of the project implementation, analytical control over various effects on the environment will, as it is today, be exercised in compliance with the existing regulation. The data obtained by the analytical laboratory are processed and brought together in monthly and annual reports, which specify all the required itemized data, including those for the sections affected by the project.

Besides, the enterprise files reports by the following official annual statistical forms:

- 2-tp (air) *Data on protection of atmospheric air*, which contains information on amounts of trapped and neutralized atmospheric pollutants, itemized emissions of specific pollutants, number of emission sources, measures on reduction of emissions into the atmosphere, emissions from particular groups of pollution sources;
- 2-tp (water resources) *Data on water use*, which presents information on consumption of water from natural sources, discharge of waste water, and content of pollutants in it, capacity of treatment facilities, etc.;
- 2-tp (waste) *Data on formation, use, neutralization, transportation and placement of industrial and household waste*, which presents the annual balance of waste flow, by waste types and hazard classes.



| D.2. Quality control (QC) and quality assurance (QA) procedures undertaken for data monitored: | | |
|---|--|--|
| Data (Indicate table and ID number) | Uncertainty level of data (high/medium/low) | Explain QA/QC procedures planned for these data, or why such procedures are not necessary. |
| Tabl. D.1.2.1 ID 2, 3, 8, 9, 11 | Low | The laboratory equipment is regularly verified. |
| Tabl. D.1.2.1 ID 1, 4, 5, 6 | Low | Heat meters are regularly verified and regularly cross-checked with balance data. |
| Tabl. D.1.2.1 ID 7 | Low | Power meters are regularly verified. |
| Tabl. D.1.2.1 ID 10 | Low | Measurements of level in the fuel oil storage tank are regularly cross-checked with supplier's data. |

D.3. Please describe the operational and management structure that the project operator will apply in implementing the monitoring plan:

Collection of information required for calculations of reductions of GHG emissions as a result of the project is performed in accordance with the procedure common for the enterprise.

Initial data will be submitted by the environmental department, by the production manager, and by the head energy engineer.

Calculations of emission reduction will be prepared by specialists of “Camco International” at the end of every reporting year.

D.4. Name of person(s)/entity(ies) establishing the monitoring plan:

Monitoring plan was developed by “Camco International”

Contact person: Vladimir Dyachkov

E-mail: vladimir.dyachkov@camco-international.com.

**SECTION E. Estimation of greenhouse gas emission reductions****E.1. Estimated project emissions:**

GHG project emissions include only the CO₂ emissions from fuel oil combustion in the old municipal boiler house at Tsiglomen production site, t CO₂/year:

$$PE_{oil,1,old,y} = FC_{oil,1,old,PJ,y} \times NCV_{oil,1,y} \times EF_{CO_2,oil} \quad , \quad (E.1-1)$$

where $FC_{oil,1,old,PJ,y}$ is amount of fuel oil burnt in the old municipal boiler house under the project, t/year (see Table B.1-4 and Annex 2.3);

$NCV_{oil,1,y}$ is average net calorific value of fuel oil, GJ/t. According to reference data [R5] it was assumed $NCV_{oil,1,y} = 39.81$ GJ/t;

$EF_{CO_2,oil}$ is CO₂ emissions factor for fuel oil combustion, t CO₂/GJ. According to IPCC Tier 1 [R11] $EF_{CO_2,oil} = 21.1 \times 44 / 12 \times 0.99 / 1000 = 0.07659$ t CO₂/GJ.

CH₄ and N₂O emissions at fuel combustion are negligibly small.

Results of calculations of GHG project emissions are presented in Table E.1-1 and Annex 2.3.

Table E.1-1. Project GHG emissions, t CO₂-eq

| Value name | Reporting year | | | | | 2008-2012 |
|---------------------|----------------|--------|--------|--------|--------|-----------|
| | 2008 | 2009 | 2010 | 2011 | 2012 | |
| Total GHG emissions | 27 496 | 27 496 | 27 496 | 27 496 | 27 496 | 137 482 |

E.2. Estimated leakage:

As indicated in Section B.3, the leakages under the project may be neglected and, therefore, were taken equal zero.

E.3. The sum of E.1. and E.2.:

Since leakages can be neglected: E.1 + E.2 = E.1.

E.4. Estimated baseline emissions:

The GHG baseline emissions include the emissions of:

- CO₂ from fuel oil combustion at the old municipal boiler house of the Tsiglomen site;
- CO₂ from fuel oil combustion at the old boiler house of the Maimaksa site;
- CO₂ from fossil fuel combustion at the electric power plants generating power for public grid;
- Avoided (owing to the project) CH₄ emissions from the landfill because of BWW decay at the Tsiglomen and Maimaksa production sites.

CH₄ and N₂O emissions at fuel combustion are negligibly low and are neglected.

CO₂ emissions from fuel oil combustion at the old boiler house of the Tsiglomen site ($BE_{oil,1,old,y}$) and at the old boiler house of the Maimaksa site ($BE_{oil,2,old,y}$) have been estimated by the formulas:

$$BE_{oil,1,old,y} = FC_{oil,1,old,BL,y} \times NCV_{oil,1,y} \times EF_{CO_2,oil} \quad , \quad (E.4-1)$$



$$BE_{oil,2,old,y} = FC_{oil,2,old,BL,y} \times NCV_{oil,2,y} \times EF_{CO_2,oil} \quad , \quad (E.4-2)$$

where $FC_{oil,1,old,BL,y}$ is amount of fuel oil burnt in the old municipal boiler house of the Tsiglomen site under the base line, t/year (see Table B.1-4 and Annex 2.1);

$FC_{oil,2,old,BL,y}$ is amount of fuel oil burnt in the old boiler house of the Maimaksa site under the base line, t/year (see Table B.1-11 and Annex 2.5);

$NCV_{oil,1,y}$, $NCV_{oil,2,y}$ is average net calorific value of fuel oil, GJ/t. According to reference data [R5] it was assumed $NCV_{oil,1,y} = NCV_{oil,2,y} = 39.81$ GJ/t;

$EF_{CO_2,oil}$ is CO₂ emissions factor for fuel oil combustion, t CO₂/GJ. According to IPCC Tier 1 [R11] $EF_{CO_2,oil} = 21.1 \times 44 / 12 \times 0.99 / 1000 = 0.07659$ t CO₂/GJ.

CO₂ emissions from fossil fuel combustion at electric power plants of outside grid have been estimated by the formula, t CO₂/year:

$$BE_{grid,2,y} = EC_{2,y} \times EF_{CO_2,grid} \quad , \quad (E.4-3)$$

where $EC_{2,y}$ is total power consumption (replaced by its own generation under the project) of Maimaksa production site of the enterprise, MWh/year (see Table B.1-8 and Annex 2.5);

$EF_{CO_2,grid}$ is CO₂ emissions factor for power from the outside grid, t CO₂/MWh. On the basis of the work “Power and district heating emission baselines. ECON Analysis. 2005” [R13] this factor was assumed equal the constant $EF_{CO_2,grid,y} = 0.68$ t CO₂/MWh for the Arkhangelsk region till 2012.

Numerical evaluations of the avoided landfill methane emissions from BWW anaerobic decay were conducted under the model of “Calculation of CO₂-equivalent emission reduction from BWW prevented from stockpiling or taken from stockpiles» developed by the “BTG biomass technology group B.V.” for the World Bank [R12]. The model was based on the *First Order Decay method* with experimental specification of a number of parameters for waste wood landfills.

The developers provided a specific estimation file in Excel format for evaluation purposes. Separate calculations were performed for Tsiglomen and Maimaksa production sites (see pages prints in Annex 2.2, 2.6).

The input values for estimating reductions in methane emissions allowed for changing (or accepting on default) under this model are as follows:

1. *Methane concentration biogas*. Default value: 60%. Due to the conservative approach the value for BWW was accepted equal 50%.
2. *Half-life biomass*. The accepted default recommended value for BWW: 15 years.
3. *Generation factor*. The accepted default recommended value for BWW: 0.77.
4. *Methane oxidation factor* The accepted default recommended value for BWW: 0.10
5. *Percentage of the stockpile under aerobic conditions*. Default value: 10%. A more conservative value of 20% was accepted.
6. *Organic carbon content (dry basis)*. The default value proposed for BWW is 53.6%; we accepted a more conservative value of 50%.
7. *Moisture content*. The default value proposed for BWW is 50%; we accepted a more conservative value of 55%.



8. *Lignin fraction of C.* The accepted default recommended value for BWW: 0.25.
9. *Year in which fresh biomass is utilized instead of stockpiled.* 2006 was accepted for Tsiglomen production site. 2008 was accepted for Maimaksa production site.
10. *Year for which to calculate the CO₂-equivalent reduction.* 2006 was accepted for Tsiglomen production site and 2008 for Maimaksa production site.
11. *Amount of fresh biomass utilized.* Annual data on the reduced amounts of BWW (tons per year) removal to the landfill resulting from the project for the period till 2012 were input.

Results of calculations of GHG emissions under the baseline are presented in Table E.1-2. and Annex 2.1, 2.2, 2.5, 2.6.

Table E.1-2. Baseline GHG emissions, t CO₂-eq.

| Value name | Reporting year | | | | | 2008-2012 |
|---|----------------|---------------|---------------|---------------|---------------|----------------|
| | 2008 | 2009 | 2010 | 2011 | 2012 | |
| Total GHG emissions | 63 211 | 69 120 | 71 380 | 73 537 | 75 597 | 352 844 |
| CO ₂ from fossil fuel combustion | 58 719 | 62 262 | 62 262 | 62 262 | 62 262 | 307 766 |
| old boiler house of the Tsiglomen production site | 42 983 | 42 983 | 42 983 | 42 983 | 42 983 | 214 916 |
| old boiler house of the Maimaksa production site | 2 126 | 4 553 | 4 553 | 4 553 | 4 553 | 20 340 |
| grid electric power plants | 13 609 | 14 725 | 14 725 | 14 725 | 14 725 | 72 511 |
| CH ₄ from BWW decay at landfills | 4 492 | 6 859 | 9 118 | 11 275 | 13 335 | 45 078 |
| Tsiglomen production site | 3 593 | 4 780 | 5 912 | 6 994 | 8 026 | 29 305 |
| Maimaksa production site | 899 | 2 079 | 3 206 | 4 281 | 5 308 | 15 773 |

E.5. Difference between E.4. and E.3. representing the emission reductions of the project:

Reduction of GHG emissions by the units and the enterprise as a whole are presented in Table E.1-3.

Table E.1-3. Reduction of GHG emissions, t CO₂-eq.

| Value name | Reporting year | | | | | 2008-2012 |
|---|----------------|---------------|---------------|---------------|---------------|----------------|
| | 2008 | 2009 | 2010 | 2011 | 2012 | |
| Total for JSC "Sawmill 25" | 35 715 | 41 624 | 43 883 | 46 040 | 48 100 | 215 362 |
| Tsiglomen production site | 19 080 | 20 266 | 21 399 | 22 480 | 23 513 | 106 739 |
| CO ₂ from fuel oil combustion | 15 487 | 15 487 | 15 487 | 15 487 | 15 487 | 77 434 |
| CH ₄ from BWW decay at landfill | 3 593 | 4 780 | 5 912 | 6 994 | 8 026 | 29 305 |
| Maimaksa production site | 16 635 | 21 358 | 22 484 | 23 560 | 24 587 | 108 624 |
| CO ₂ from fuel oil combustion | 2 126 | 4 553 | 4 553 | 4 553 | 4 553 | 20 340 |
| CO ₂ from fossil fuel combustion at grid electric power plants | 13 609 | 14 725 | 14 725 | 14 725 | 14 725 | 72 511 |
| CH ₄ from BWW decay at landfill | 899 | 2 079 | 3 206 | 4 281 | 5 308 | 15 773 |

**E.6. Table providing values obtained when applying formulae above:**

| Year | Estimated project emissions (tonnes of CO₂ equivalent) | Estimated leakage (tonnes of CO₂ equivalent) | Estimated baseline emissions (tonnes of CO₂ equivalent) | Estimated emission reductions (tonnes of CO₂ equivalent) |
|--|--|--|---|--|
| 2008 | 27 496 | 0 | 63 211 | 35 715 |
| 2009 | 27 496 | 0 | 69 120 | 41 624 |
| 2010 | 27 496 | 0 | 71 380 | 43 883 |
| 2011 | 27 496 | 0 | 73 537 | 46 040 |
| 2012 | 27 496 | 0 | 75 597 | 48 100 |
| Total (tonnes of CO₂ equivalent) | 137 482 | 0 | 352 844 | 215 362 |

**SECTION F. Environmental impacts****F.1. Documentation on the analysis of the environmental impacts of the project, including transboundary impacts, in accordance with procedures as determined by the host Party:**

Before the start of the project implementation, JSC “Sawmill 25” has received all the required conclusions of the state ecology examinations.

Project implementation increases BWW consumption as fuel while decreasing consumption of fuel oil. This results in the reduction of GHG emissions into the atmosphere, as well as of harmful substances of 2-4 danger categories.

Table F.1-1. represents the design data of expected changes in the amount of harmful substances thrown into the atmosphere by the project against the baseline.

Project implementation results in the reduction of sulphur dioxide emissions by 544 t/year, carbon oxide by 111 t/year, nitrous oxide by 0.4 t/year, nitrous dioxide by 2.6 t/year, while the solid particles will increase by 3 t/year.

The total decrease of the pollutants emissions into the atmosphere for the whole project is 655 t/year.

Table F.1-1. Alterations in the harmful substance emissions into the atmosphere against the baseline, t/year; (+) -increase, (-) -decrease)

| Value name | Unit | Fuel oil* | BWW | Total |
|--------------------------------------|--------|-----------|-------|--------|
| - solid particles | t/year | -4,9 | 7,9 | 3,0 |
| - sulphur dioxide (SO ₂) | t/year | -544,0 | 0,0 | -544,0 |
| - nitrous dioxide (NO ₂) | t/year | -47,8 | 45,2 | -2,6 |
| - nitrous oxide (NO) | t/year | -7,8 | 7,4 | -0,4 |
| - carbon oxide (CO) | t/year | -179 | 68 | -111,1 |
| Total emissions | t/year | -783,1 | 128,0 | -655,1 |

* - includes the projected decrease of fuel oil use at the Arkhangelsk thermal power station, the main supplier of the electric power to “Sawmill 25”.

Ventilation of boiler rooms is provided due to louver grates installed in the upper and lower zones of wall enclosure and large-size fans. Emissions do not contain harmful substances.

Ash left in the boilers and whirlers are removed through hoses into closed containers excluding environmental dusting.

Household waste waters are disposed into existing sewage networks and further to cleaning facilities. There are no industrial waste waters.

There is no increase of maximum permissible concentrations of harmful substances on the edges of control areas.

F.2. If environmental impacts are considered significant by the project participants or the host Party, please provide conclusions and all references to supporting documentation of an environmental impact assessment undertaken in accordance with the procedures as required by the host Party:

Environmental impacts are not considered significant.



SECTION G. Stakeholders' comments

G.1. Information on stakeholders' comments on the project, as appropriate:

No comments.



REFERENCES

- [R1] Revision to the approved consolidated baseline and monitoring methodology ACM0006/Version 05 “Consolidated methodology for electricity generation from biomass residues”. CDM – Executive Board. 18 May 2007
- [R2] Decision 9/CMP.1. Guidelines for the implementation of Article 6 of the Kyoto Protocol. FCCC/KP/CMP/2005/8/Add.2. 30 March 2006
- [R3] Building norms and rules 23-01-99 “Building climatology”.
- [R4] Report “Energy inspection of utilizing-energy boiler units PR-2500 №№1,2 to determine their technical, economic and ecological indices”, Energy center, Arkhangelsk State Technical University, Arkhangelsk, 2005.
- [R5] Power-plant fuel of the USSR. Reference book, M.: Energoatomizdat, 1995.
- [R6] Report “Test results of utilizing boiler units of Tsiglomen sawmill”, Energy center, Arkhangelsk State Technical University, Arkhangelsk, 2003.
- [R7] Project of measures on environmental protection.
- [R8] Investment project justification “Boiler house reconstruction aimed for complete BWW utilization and environmental protection”, 2002.
- [R9] Report “Test results of utilizing boiler units of Sawmill 25”, Energy center, Arkhangelsk State Technical University, Arkhangelsk, 2003.
- [R10] Guidance on Criteria for Baseline Setting and Monitoring, Version 01. JISC Fourth meeting. Report - Annex 6, 2006
- [R11] 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2, Energy
- [R12] Methane and Nitrous Oxide Emissions from Biomass Waste Stockpiles, Worldbank PCFplus research, August 2002
- [R13] Power and district heating emission baselines. Commissioned by Nordic Council of Ministers. ECON-Report no 2004-114.
- [R14] Tool for the demonstration and assessment of additionality. Version 03. UNFCCC.

Annex 1**CONTACT INFORMATION ON PROJECT PARTICIPANTS**

| | |
|------------------|--|
| Organisation: | JSC "Sawmill 25" |
| Street/P.O.Box: | Postysheva |
| Building: | 26 |
| City: | Arkhangelsk |
| State/Region: | Arkhangelsk Region |
| Postal code: | 163025 |
| Country: | Russia |
| Phone: | +7 8182 638100 |
| Fax: | +7 8182 638062 |
| E-mail: | info@sawmill25.ru |
| URL: | http://www.sawmill25.ru/ |
| Represented by: | |
| Title: | Financial Director |
| Salutation: | Mrs. |
| Last name: | Krasilnikova |
| Middle name: | Vladimirovna |
| First name: | Elena |
| Department: | Finance |
| Phone (direct): | +7 8182 638100 |
| Fax (direct): | +7 8182 638062 |
| Mobile: | +7 921 720 4272 |
| Personal e-mail: | Krasilnikova.Elena@sawmill25.ru |

| | |
|------------------|--|
| Organisation: | CAMCO International GmbH |
| Street/P.O.Box: | Burggasse |
| Building: | 116 |
| City: | Wien |
| State/Region: | |
| Postal code: | 1070 |
| Country: | Austria |
| Phone: | +43 1 52520256 |
| Fax: | +43 1 52520266 |
| E-mail: | |
| URL: | www.camco-international.com |
| Represented by: | |
| Title: | |
| Salutation: | Mr. |
| Last name: | Houston |
| Middle name: | Kirk |
| First name: | Arthur |
| Department: | |
| Phone (direct): | +43 1 525 20280 |
| Fax (direct): | |
| Mobile: | +7 905 507 2293 |
| Personal e-mail: | arthur.houston@camco-international.com |

| | |
|-----------------|-----------------------------|
| Organisation: | Camco Carbon Russia Limited |
| Street/P.O.Box: | Green Street |



| | |
|------------------|-----------------------------|
| Building: | Channel House |
| City: | St. Helier |
| State/Region: | |
| Postal code: | JE2 4UH |
| Country: | Jersey |
| Phone: | |
| Fax: | |
| E-mail: | |
| URL: | www.camcoglobal.com |
| Represented by: | |
| Title: | Director |
| Salutation: | Mr. |
| Last name: | Cohen |
| Middle name: | |
| First name: | Yariv |
| Department: | |
| Phone (direct): | +44 20 7121 6126 |
| Fax (direct): | |
| Mobile: | +44 7920 799566 |
| Personal e-mail: | yariv.cohen@camcoglobal.com |



Annex 2
BASELINE INFORMATION

Annex 2.1.
Estimated baseline GHG emissions at Tsiglomen production site

| Data name | Unit | Years | | | | | |
|--|--------------------------|---------------|---------------|---------------|---------------|---------------|----------------|
| | | 2008 | 2009 | 2010 | 2011 | 2012 | 2008-2012 |
| Productivity of sawing and wood waste | | | | | | | |
| Productivity of sawing | m ³ | 240 000 | 240 000 | 240 000 | 240 000 | 240 000 | 1 200 000 |
| Drying | m ³ | 130 572 | 130 572 | 130 572 | 130 572 | 130 572 | 652 862 |
| | % | 0,544 | 0,544 | 0,544 | 0,544 | 0,544 | - |
| Amount of wood waste | m ³ | 64 800 | 64 800 | 64 800 | 64 800 | 64 800 | 324 000 |
| | t | 51 840 | 51 840 | 51 840 | 51 840 | 51 840 | 259 200 |
| including | | | | | | | |
| bark | % | 10,0 | 10,0 | 10,0 | 10,0 | 10,0 | - |
| | m ³ | 24 000 | 24 000 | 24 000 | 24 000 | 24 000 | 120 000 |
| | t | 19 200 | 19 200 | 19 200 | 19 200 | 19 200 | 96 000 |
| sawdust | % | 17,0 | 17,0 | 17,0 | 17,0 | 17,0 | - |
| | m ³ | 40 800 | 40 800 | 40 800 | 40 800 | 40 800 | 204 000 |
| | t | 32 640 | 32 640 | 32 640 | 32 640 | 32 640 | 163 200 |
| Utilized | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| For sale | m ³ | 34 438 | 34 438 | 34 438 | 34 438 | 34 438 | 172 190 |
| To the dump | m ³ | 30 362 | 30 362 | 30 362 | 30 362 | 30 362 | 151 810 |
| Heat | | | | | | | |
| Useful output of energy from boilers | GJ | 392 995 | 392 995 | 392 995 | 392 995 | 392 995 | 1 964 975 |
| Housing estate | GJ | 251 400 | 251 400 | 251 400 | 251 400 | 251 400 | 1 257 000 |
| Sawmill | GJ | 141 595 | 141 595 | 141 595 | 141 595 | 141 595 | 707 975 |
| including | | | | | | | |
| drying | GJ/m ³ | 0,995 | 0,995 | 0,995 | 0,995 | 0,995 | - |
| | GJ | 129 863 | 129 863 | 129 863 | 129 863 | 129 863 | 649 315 |
| heating | GJ | 11 732 | 11 732 | 11 732 | 11 732 | 11 732 | 58 660 |
| Fuel - total | | | | | | | |
| Consumption of fuel (total) | tce | 19 134 | 19 134 | 19 134 | 19 134 | 19 134 | 95 668 |
| | GJ | 561 189 | 561 189 | 561 189 | 561 189 | 561 189 | 2 805 945 |
| Fuel - mazut | | | | | | | |
| Consumption of mazut | t | 14 098 | 14 098 | 14 098 | 14 098 | 14 098 | 70 492 |
| | tce | 19 134 | 19 134 | 19 134 | 19 134 | 19 134 | 95 668 |
| | GJ | 561 189 | 561 189 | 561 189 | 561 189 | 561 189 | 2 805 945 |
| Percentage | % | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 | 100,0 |
| Combustion value | GJ/t | 39,81 | 39,81 | 39,81 | 39,81 | 39,81 | - |
| Efficiency of boilers | - | 0,753 | 0,753 | 0,753 | 0,753 | 0,753 | - |
| Auxiliary and energy loss | - | 0,070 | 0,070 | 0,070 | 0,070 | 0,070 | - |
| Useful output of energy from boilers | GJ | 392 995 | 392 995 | 392 995 | 392 995 | 392 995 | 1 964 975 |
| Greenhouse gases | | | | | | | |
| from burning of mazut | t CO ₂ e | 42 983 | 42 983 | 42 983 | 42 983 | 42 983 | 214 916 |
| from the dump | t CO ₂ e | 3 593 | 4 780 | 5 912 | 6 994 | 8 026 | 29 305 |
| Emissions of greenhouse gases | t CO₂e | 46 577 | 47 763 | 48 895 | 49 977 | 51 009 | 244 221 |



Annex 2.2.

Estimated reductions of methane emissions from landfill because of BWW anaerobic decay at Tsiglomen production site

Calculation of CO₂-equivalent emission reduction from BWW prevented from stockpiling or taken from stockpiles

| General input data | |
|--|--------------------------------------|
| Conversion factor organic carbon to biogas (a) | 1,87 m ³ biogas/kg carbon |
| GWP CH ₄ | 21 |
| Density methane | 0,654 kg/m ³ |
| Methane concentration biogas | 50% |
| Half-life biomass (tau) | 15 year |
| Decomposition constant (k) | 0,046 year ⁻¹ |
| Generation factor (zeta) | 0,77 |
| Methane oxidation factor | 0,10 |
| Percentage of the stockpile under aerobic condition: | 20% |

BWW - bark wood waste

| LEGEND |
|------------------------------------|
| db = dry basis |
| wb = wet basis |
| yellow cells = unprotected cells |
| red marks = comment field included |

Spreadsheet model developed by:

BTG biomass technology group B.V.
P.O. Box 217
7500 AE Enschede
The Netherlands
tel: +31 53 4892897
fax: +31 53 4893116
email: office@btgworld.com
www.btgworld.com

| Biomass specific input data | Biomass from stockpile | Fresh |
|-----------------------------|------------------------|----------|
| Organic carbon content (db) | | 50,0% db |
| Moisture content | | 55% wb |
| Organic carbon content (wb) | 0,0% | 22,5% wb |
| Lignin fraction of C | | 0,25 |

| Year | Fresh biomass prevented from stockpiling or taken from stockpile | | | Year | | | | | | | 2008 | 2009 | 2010 | 2011 | 2012 | Total 2008-2012 |
|---|--|------------------------|---------------------------|----------|----------|----------|----------|----------|--------------|--------------|--------------|---------------|---------------|---------------|---------------|-----------------|
| | Biomass from stockpile (ton _w) | Age of biomass (years) | Fresh (ton _w) | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | | | | | | |
| 2001 | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2002 | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2003 | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2004 | | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2005 | | | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2006 | | | 18 917 * | | | | | | 1 050 | 1 003 | 957 | 914 | 873 | 834 | 796 | |
| 2007 | | | 24 290 | | | | | | | 1 348 | 1 288 | 1 229 | 1 174 | 1 121 | 1 070 | |
| 2008 | | | 24 290 | | | | | | | | 1 348 | 1 288 | 1 229 | 1 174 | 1 121 | |
| 2009 | | | 24 290 | | | | | | | | | 1 348 | 1 288 | 1 229 | 1 174 | |
| 2010 | | | 24 290 | | | | | | | | | | 1 348 | 1 288 | 1 229 | |
| 2011 | | | 24 290 | | | | | | | | | | | 1 348 | 1 288 | |
| 2012 | | | 24 290 | | | | | | | | | | | | 1 348 | |
| Total | 0 | | 164 654 | | | | | | | | | | | | | |
| Total emission prevention | | | | 0 | 0 | 0 | 0 | 0 | 1 050 | 2 351 | 3 593 | 4 780 | 5 912 | 6 994 | 8 026 | 29 305 |
| Cumulative total emission prevention | | | | 0 | 0 | 0 | 0 | 0 | 1 050 | 3 401 | 6 995 | 11 774 | 17 687 | 24 680 | 32 706 | |

* - data have been received by results of monitoring 2006



Annex 2.3.
Estimated project GHG emissions at Tsiglomen production site

| Data name | Unit | 2008 | | | 2009 | | | 2010 | | | 2011 | | | 2012 | | | 2008-2012 |
|--|---------------------|------------------|------------------|---------|------------------|------------------|---------|------------------|------------------|---------|------------------|------------------|---------|------------------|------------------|---------|-----------|
| | | New boiler house | Old boiler house | Total | New boiler house | Old boiler house | Total | New boiler house | Old boiler house | Total | New boiler house | Old boiler house | Total | New boiler house | Old boiler house | Total | |
| Productivity of sawing and wood waste | | | | | | | | | | | | | | | | | |
| Productivity of sawing | m ³ | 240 000 | | | 240 000 | | | 240 000 | | | 240 000 | | | 240 000 | | | 1 200 000 |
| Drying | m ³ | 130 572 | | | 130 572 | | | 130 572 | | | 130 572 | | | 130 572 | | | 783 435 |
| | % | 0,544 | | | 0,544 | | | 0,544 | | | 0,544 | | | 0,544 | | | - |
| Amount of wood waste | m ³ | 64 800 | | | 64 800 | | | 64 800 | | | 64 800 | | | 64 800 | | | 324 000 |
| | t | 51 840 | | | 51 840 | | | 51 840 | | | 51 840 | | | 51 840 | | | 259 200 |
| including | | | | | | | | | | | | | | | | | |
| bark | % | 10,0 | | | 10,0 | | | 10,0 | | | 10,0 | | | 10,0 | | | 10,00 |
| | m ³ | 24 000 | | | 24 000 | | | 24 000 | | | 24 000 | | | 24 000 | | | 120 000 |
| | t | 19 200 | | | 19 200 | | | 19 200 | | | 19 200 | | | 19 200 | | | 96 000 |
| sawdust | % | 17,0 | | | 17,0 | | | 17,0 | | | 17,0 | | | 17,0 | | | - |
| | m ³ | 40 800 | | | 40 800 | | | 40 800 | | | 40 800 | | | 40 800 | | | 244 800 |
| | t | 32 640 | | | 32 640 | | | 32 640 | | | 32 640 | | | 32 640 | | | 195 840 |
| Utilized | m ³ | 30 362 | | | 30 362 | | | 30 362 | | | 30 362 | | | 30 362 | | | 182 172 |
| For sale | m ³ | 34 438 | | | 34 438 | | | 34 438 | | | 34 438 | | | 34 438 | | | 172 190 |
| To the dump | m ³ | 0 | | | 0 | | | 0 | | | 0 | | | 0 | | | 0 |
| Heat | | | | | | | | | | | | | | | | | |
| Useful output of energy from boiler | GJ | 141 595 | 251 400 | 392 995 | 141 595 | 251 400 | 392 995 | 141 595 | 251 400 | 392 995 | 141 595 | 251 400 | 392 995 | 141 595 | 251 400 | 392 995 | 1 964 975 |
| Housing estate | GJ | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 1 257 000 |
| Sawmill | GJ | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 707 975 |
| including | | | | | | | | | | | | | | | | | |
| drying | GJ/m ³ | 0,995 | 0 | - | 0,995 | 0 | - | 0,995 | 0 | - | 0,995 | 0 | - | 0,995 | 0 | - | - |
| | GJ | 129 863 | 0 | 129 863 | 129 863 | 0 | 129 863 | 129 863 | 0 | 129 863 | 129 863 | 0 | 129 863 | 129 863 | 0 | 129 863 | 649 315 |
| heating | GJ | 11 732 | 0 | 11 732 | 11 732 | 0 | 11 732 | 11 732 | 0 | 11 732 | 11 732 | 0 | 11 732 | 11 732 | 0 | 11 732 | 58 660 |
| Fuel - total | | | | | | | | | | | | | | | | | |
| Consumption of fuel (total) | tce | 6 107 | 12 240 | 18 347 | 6 107 | 12 240 | 18 347 | 6 107 | 12 240 | 18 347 | 6 107 | 12 240 | 18 347 | 6 107 | 12 240 | 18 347 | 91 735 |
| | GJ | 179 121 | 358 994 | 538 115 | 179 121 | 358 994 | 538 115 | 179 121 | 358 994 | 538 115 | 179 121 | 358 994 | 538 115 | 179 121 | 358 994 | 538 115 | 2 690 575 |
| Fuel - mazut | | | | | | | | | | | | | | | | | |
| Consumption of mazut | t | 0 | 9 019 | 9 019 | 0 | 9 019 | 9 019 | 0 | 9 019 | 9 019 | 0 | 9 019 | 9 019 | 0 | 9 019 | 9 019 | 9 019 |
| | tce | 0 | 12 240 | 12 240 | 0 | 12 240 | 12 240 | 0 | 12 240 | 12 240 | 0 | 12 240 | 12 240 | 0 | 12 240 | 12 240 | 61 199 |
| | GJ | 0 | 358 994 | 358 994 | 0 | 358 994 | 358 994 | 0 | 358 994 | 358 994 | 0 | 358 994 | 358 994 | 0 | 358 994 | 358 994 | 1 794 971 |
| Percentage | % | 0 | 100 | 67 | 0 | 100 | 67 | 0 | 100 | 67 | 0 | 100 | 67 | 0 | 100 | 67 | 67 |
| Combustion value | GJ/t | - | 39,81 | - | - | 39,81 | - | - | 39,81 | - | - | 39,81 | - | - | 39,81 | - | - |
| Efficiency of boilers | - | - | 0,753 | - | - | 0,753 | - | - | 0,753 | - | - | 0,753 | - | - | 0,753 | - | - |
| Auxiliary and energy loss | - | - | 0,070 | - | - | 0,070 | - | - | 0,070 | - | - | 0,070 | - | - | 0,070 | - | - |
| Useful output of energy from boiler | GJ | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 0 | 251 400 | 251 400 | 1 257 000 |
| Fuel - bark and wood waste | | | | | | | | | | | | | | | | | |
| Consumption of wood waste | m ³ | 30 362 | 0 | 30 362 | 30 362 | 0 | 30 362 | 30 362 | 0 | 30 362 | 30 362 | 0 | 30 362 | 30 362 | 0 | 30 362 | 30 362 |
| | t | 24 290 | 0 | 24 290 | 24 290 | 0 | 24 290 | 24 290 | 0 | 24 290 | 24 290 | 0 | 24 290 | 24 290 | 0 | 24 290 | 121 448 |
| | tce | 6 107 | 0 | 6 107 | 6 107 | 0 | 6 107 | 6 107 | 0 | 6 107 | 6 107 | 0 | 6 107 | 6 107 | 0 | 6 107 | 30 535 |
| | GJ | 179 121 | 0 | 179 121 | 179 121 | 0 | 179 121 | 179 121 | 0 | 179 121 | 179 121 | 0 | 179 121 | 179 121 | 0 | 179 121 | 895 604 |
| Efficiency of boilers | - | 0,850 | 0,731 | - | 0,850 | 0,731 | - | 0,850 | 0,731 | - | 0,850 | 0,731 | - | 0,850 | 0,731 | - | - |
| Auxiliary and energy loss | - | 0,070 | 0,070 | - | 0,070 | 0,070 | - | 0,070 | 0,070 | - | 0,070 | 0,070 | - | 0,070 | 0,070 | - | - |
| Useful output of energy from boiler | GJ | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 141 595 | 0 | 141 595 | 707 975 |
| Percentage | % | 100 | 0 | 33 | 100 | 0 | 33 | 100 | 0 | 33 | 100 | 0 | 33 | 100 | 0 | 33 | 33 |
| Combustion value | GJ/t | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | - |
| Greenhouse gases | | | | | | | | | | | | | | | | | |
| from burning of mazut | t CO ₂ e | | | 27496 | | | 27496 | | | 27496 | | | 27496 | | | 27496 | 137 482 |
| Emissions of greenhouse gases | t CO ₂ e | | | 27 496 | | | 27 496 | | | 27 496 | | | 27 496 | | | 27 496 | 137 482 |

This template shall not be altered. It shall be completed without modifying/adding headings or logo, format or font.



Annex 2.4.

Estimated GHG emission reductions at Tsiglomen production site

| Data name | Unit | 2008 | 2009 | 2010 | 2011 | 2012 | 2008-2012 |
|--|---------------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| Productivity of sawing and wood waste | | | | | | | |
| Productivity of sawing | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| Drying | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| Amount of wood waste | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| including | t | 0 | 0 | 0 | 0 | 0 | 0 |
| bark | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| | t | 0 | 0 | 0 | 0 | 0 | 0 |
| sawdust | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| | t | 0 | 0 | 0 | 0 | 0 | 0 |
| Utilized | m ³ | 30 362 | 30 362 | 30 362 | 30 362 | 30 362 | 151 810 |
| For sale | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| To the dump | m ³ | -30 362 | -30 362 | -30 362 | -30 362 | -30 362 | -151 810 |
| Heat | | | | | | | |
| Useful output of energy from boilers | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Housing estate | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Sawmill | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| including | | | | | | | |
| drying | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| heating | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Fuel (total) | | | | | | | |
| Consumption of fuel (total) | tce | -787 | -787 | -787 | -787 | -787 | -3 934 |
| | GJ | -23 074 | -23 074 | -23 074 | -23 074 | -23 074 | -115 370 |
| Fuel (mazut) | | | | | | | |
| Consumption of mazut | t | -5 080 | -5 080 | -5 080 | -5 080 | -5 080 | -25 398 |
| | tce | -6 894 | -6 894 | -6 894 | -6 894 | -6 894 | -34 469 |
| | GJ | -202 195 | -202 195 | -202 195 | -202 195 | -202 195 | -1 010 974 |
| Fuel (bark and wood waste) | | | | | | | |
| Consumption of wood waste | m ³ | 30 362 | 30 362 | 30 362 | 30 362 | 30 362 | 151 810 |
| | t | 24 290 | 24 290 | 24 290 | 24 290 | 24 290 | 121 448 |
| | tce | 6 107 | 6 107 | 6 107 | 6 107 | 6 107 | 30 535 |
| | GJ | 179 121 | 179 121 | 179 121 | 179 121 | 179 121 | 895 604 |
| Greenhouse gases | | | | | | | |
| from burning of mazut | t CO ₂ e | -15 487 | -15 487 | -15 487 | -15 487 | -15 487 | -77 434 |
| from the dump | t CO ₂ e | -3 593 | -4 780 | -5 912 | -6 994 | -8 026 | -29 305 |
| Emissions of greenhouse gases | | -19 080 | -20 266 | -21 399 | -22 480 | -23 513 | -106 739 |



Annex 2.5.

Estimated baseline GHG emissions at Maimaksa production site

| Data name | Unit | Year | | | | | 2008-2012 |
|--|--------------------------|---------------|---------------|---------------|---------------|---------------|----------------|
| | | 2008 | 2009 | 2010 | 2011 | 2012 | |
| Productivity of sawing and wood waste | | | | | | | |
| Productivity of sawing | m ³ | 550 000 | 600 000 | 600 000 | 600 000 | 600 000 | 2 950 000 |
| Drying | m ³ | 296 581 | 323 542 | 323 542 | 323 542 | 323 542 | 1 590 751 |
| | % | 0,539 | 0,539 | 0,539 | 0,539 | 0,539 | - |
| Amount of wood waste | m ³ | 159 500 | 174 000 | 174 000 | 174 000 | 174 000 | 855 500 |
| | t | 127 600 | 139 200 | 139 200 | 139 200 | 139 200 | 684 400 |
| including | | | | | | | |
| bark | % | 10,00 | 10,0 | 10,0 | 10,0 | 10,0 | - |
| | m ³ | 55 000 | 60 000 | 60 000 | 60 000 | 60 000 | 295 000 |
| | t | 44 000 | 48 000 | 48 000 | 48 000 | 48 000 | 236 000 |
| sawdust | % | 19,00 | 19,0 | 19,0 | 19,0 | 19,0 | - |
| | m ³ | 104 500 | 114 000 | 114 000 | 114 000 | 114 000 | 560 500 |
| | t | 83 600 | 91 200 | 91 200 | 91 200 | 91 200 | 448 400 |
| Utilized | m ³ | 93 216 | 93 216 | 93 216 | 93 216 | 93 216 | 466 081 |
| For sale | m ³ | 46 043 | 53 302 | 53 302 | 53 302 | 53 302 | 259 251 |
| To the dump | m ³ | 20 241 | 27 482 | 27 482 | 27 482 | 27 482 | 130 168 |
| Electricity | | | | | | | |
| Consumption of electricity | MWh | 20014 | 21655 | 21655 | 21655 | 21655 | 106 633 |
| including | | | | | | | |
| sawmill equipment | MWh/m ³ | 0,010 | 0,010 | 0,010 | 0,010 | 0,010 | - |
| | MWh | 5 440 | 5 934 | 5 934 | 5 934 | 5 934 | 29 176 |
| drying and packing line | MWh/m ³ | 0,036 | 0,036 | 0,036 | 0,036 | 0,036 | - |
| | MWh | 10 624 | 11 589 | 11 589 | 11 589 | 11 589 | 56 981 |
| boiler houses | MWh/GJ | 0,0067 | 0,0067 | 0,0067 | 0,0067 | 0,0067 | - |
| | MWh | 2 961 | 3 142 | 3 142 | 3 142 | 3 142 | 15 527 |
| other | MWh | 990 | 990 | 990 | 990 | 990 | 4 950 |
| From the outside | MWh | 20 014 | 21 655 | 21 655 | 21 655 | 21 655 | 106 633 |
| Heat (tenno) | | | | | | | |
| Useful output | GJ | 439 293 | 466 108 | 466 108 | 466 108 | 466 108 | 2 303 727 |
| Housing estate | GJ | 109 937 | 109 937 | 109 937 | 109 937 | 109 937 | 549 686 |
| Sawmill | GJ | 329 356 | 356 171 | 356 171 | 356 171 | 356 171 | 1 754 041 |
| including | | | | | | | 0 |
| drying | GJ/m ³ | 0,995 | 0,995 | 0,995 | 0,995 | 0,995 | - |
| | GJ | 294 969 | 321 785 | 321 785 | 321 785 | 321 785 | 1 582 108 |
| heating | GJ | 20 041 | 20 041 | 20 041 | 20 041 | 20 041 | 100 204 |
| automobile facilities | GJ | 14 346 | 14 346 | 14 346 | 14 346 | 14 346 | 71 730 |
| Fuel (total) | | | | | | | |
| Consumption of fuel (total) | tce | 19 696 | 20 777 | 20 777 | 20 777 | 20 777 | 102 803 |
| | GJ | 577 694 | 609 379 | 609 379 | 609 379 | 609 379 | 3 015 211 |
| Fuel (mazut) | | | | | | | |
| Consumption of mazut | t | 697,5 | 1 493,5 | 1 493,5 | 1 493,5 | 1 493,5 | 6 671,48 |
| | tce | 946,6 | 2 026,9 | 2 026,9 | 2 026,9 | 2 026,9 | 9 054,1 |
| | GJ | 27 763 | 59 449 | 59 449 | 59 449 | 59 449 | 265 558,10 |
| Percentage | % | 4,81 | 9,76 | 9,76 | 9,76 | 9,76 | - |
| Combustion value | GJ/t | 39,81 | 39,81 | 39,81 | 39,81 | 39,81 | - |
| Efficiency of boilers | - | 0,910 | 0,910 | 0,910 | 0,910 | 0,910 | - |
| Auxiliary and energy loss | - | 0,070 | 0,070 | 0,070 | 0,070 | 0,070 | - |
| Useful output of energy from boilers | GJ | 23 496 | 50 311 | 50 311 | 50 311 | 50 311 | 224 742 |
| Fuel (bark and wood waste) | | | | | | | |
| Consumption of wood waste | m ³ | 93 216 | 93 216 | 93 216 | 93 216 | 93 216 | 466 081 |
| | t | 74 573 | 74 573 | 74 573 | 74 573 | 74 573 | 372 865 |
| | tce | 18 750 | 18 750 | 18 750 | 18 750 | 18 750 | 93 749 |
| | GJ | 549 931 | 549 931 | 549 931 | 549 931 | 549 931 | 2 749 653 |
| Percentage | % | 95,2 | 90,2 | 90,2 | 90,2 | 90,2 | 91,2 |
| Combustion value | GJ/t | 7,3744 | 7,3744 | 7,3744 | 7,3744 | 7,3744 | - |
| Efficiency of boilers | - | 0,813 | 0,813 | 0,813 | 0,813 | 0,813 | - |
| Auxiliary and energy loss | - | 0,070 | 0,070 | 0,070 | 0,070 | 0,070 | - |
| Useful output of energy from boilers 1 | GJ | 415 797 | 415 797 | 415 797 | 415 797 | 415 797 | 71 730 |
| Greenhouse gases | | | | | | | |
| from burning of mazut | t CO ₂ e | 2 126 | 4 553 | 4 553 | 4 553 | 4 553 | 20 340 |
| from electricity | t CO ₂ e | 13 609 | 14 725 | 14 725 | 14 725 | 14 725 | 72 511 |
| from dump | t CO ₂ e | 899 | 2 079 | 3 206 | 4 281 | 5 308 | 15 773 |
| Total | t CO₂e | 16 635 | 21 358 | 22 484 | 23 560 | 24 587 | 108 624 |



Annex 2.6.

Estimated reductions of methane emissions from landfill because of BWW anaerobic decay at Maimaksa production site

Calculation of CO₂-equivalent emission reduction from BWW prevented from stockpiling or taken from stockpiles

| General input data | |
|--|--------------------------------------|
| Conversion factor organic carbon to biogas (a) | 1,87 m ³ biogas/kg carbon |
| GWP CH ₄ | 21 |
| Density methane | 0,654 kg/m ³ |
| Methane concentration biogas | 50% |
| Half-life biomass (tau) | 15 year |
| Decomposition constant (k) | 0,046 year ⁻¹ |
| Generation factor (zeta) | 0,77 |
| Methane oxidation factor | 0,10 |
| Percentage of the stockpile under aerobic conditions | 20% |

BWW - bark wood waste

| LEGEND |
|------------------------------------|
| db = dry basis |
| wb = wet basis |
| yellow cells = unprotected cells |
| red marks = comment field included |

Spreadsheet model developed by:

BTG biomass technology group B.V.
P.O. Box 217
7500 AE Enschede
The Netherlands
tel: +31 53 4892897
fax: +31 53 4893116
email: office@btgworld.com
www.btgworld.com

| Biomass specific input data | Biomass from stockpile | Fresh | |
|-----------------------------|------------------------|-------|----|
| Organic carbon content (db) | | 50,0% | db |
| Moisture content | | 55% | wb |
| Organic carbon content (wb) | 0,0% | 22,5% | wb |
| Lignin fraction of C | | 0,25 | |

| Year | Fresh biomass prevented from stockpiling or taken from stockpile | | | Year | | | | | | | Total | | | |
|---|--|------------------------|---------------------------|----------|----------|----------|----------|----------|------------|--------------|--------------|---------------|---------------|---------------|
| | Biomass from stockpile (ton _w) | Age of biomass (years) | Fresh (ton _w) | 2003 | 2004 | 2005 | 2006 | 2007 | 2008 | 2009 | | 2010 | 2011 | 2012 |
| 2003 | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2004 | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2005 | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2006 | | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2007 | | | | | | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2008 | | | 16 193 | | | | | | 899 | 858 | 820 | 783 | 747 | |
| 2009 | | | 21 985 | | | | | | | 1 221 | 1 165 | 1 113 | 1 063 | |
| 2010 | | | 21 985 | | | | | | | | 1 221 | 1 165 | 1 113 | |
| 2011 | | | 21 985 | | | | | | | | | 1 221 | 1 165 | |
| 2012 | | | 21 985 | | | | | | | | | | 1 221 | |
| Total | 0 | | 104 134 | | | | | | | | | | | |
| Total emission prevention | | | | 0 | 0 | 0 | 0 | 0 | 899 | 2 079 | 3 206 | 4 281 | 5 308 | 15 773 |
| Cumulative total emission prevention | | | | 0 | 0 | 0 | 0 | 0 | 899 | 2 978 | 6 183 | 10 465 | 15 773 | |



Annex 2.7.
Estimated project GHG emissions at Maimaksa production site

| Data name | Unit | 2008 | | | 2009 | | | 2010 | | | 2011 | | | 2012 | | | 2008-2012 |
|--|--------------------|---------|------------------|-------|---------|------------------|---------|---------|------------------|-------|---------|------------------|---------|---------|------------------|-------|-----------|
| | | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | |
| Productivity of sawing and wood waste | | | | | | | | | | | | | | | | | |
| Productivity of sawing | m ³ | | 550 000 | | 600 000 | | 600 000 | | 600 000 | | 600 000 | | 600 000 | | 600 000 | | 2 950 000 |
| Drying | m ³ | | 296 581 | | 323 542 | | 323 542 | | 323 542 | | 323 542 | | 323 542 | | 323 542 | | 1 590 751 |
| | | | 0,539 | | 0,539 | | 0,539 | | 0,539 | | 0,539 | | 0,539 | | 0,539 | | 2,696 |
| Amount of wood waste | m ³ | | 159 500 | | 174 000 | | 174 000 | | 174 000 | | 174 000 | | 174 000 | | 174 000 | | 855 500 |
| | t | | 127 600 | | 139 200 | | 139 200 | | 139 200 | | 139 200 | | 139 200 | | 139 200 | | 684 400 |
| including | | | | | | | | | | | | | | | | | |
| bark | % | | 10,0 | | 10,0 | | 10,0 | | 10,0 | | 10,0 | | 10,0 | | 10,0 | | - |
| | m ³ | | 55 000 | | 60 000 | | 60 000 | | 60 000 | | 60 000 | | 60 000 | | 60 000 | | 295 000 |
| | t | | 44 000 | | 48 000 | | 48 000 | | 48 000 | | 48 000 | | 48 000 | | 48 000 | | 236 000 |
| sawdust | % | | 19,0 | | 19,0 | | 19,0 | | 19,0 | | 19,0 | | 19,0 | | 19,0 | | - |
| | m ³ | | 104 500 | | 114 000 | | 114 000 | | 114 000 | | 114 000 | | 114 000 | | 114 000 | | 560 500 |
| | t | | 83 600 | | 91 200 | | 91 200 | | 91 200 | | 91 200 | | 91 200 | | 91 200 | | 448 400 |
| Utilized | m ³ | | 113 457 | | 120 698 | | 120 698 | | 120 698 | | 120 698 | | 120 698 | | 120 698 | | 596 249 |
| For sale | m ³ | | 46 043 | | 53 302 | | 53 302 | | 53 302 | | 53 302 | | 53 302 | | 53 302 | | 259 251 |
| To the dump | m ³ | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 |
| Electricity | | | | | | | | | | | | | | | | | |
| Consumption of electricity | MWh | | 20 014 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 106 633 |
| including | | | | | | | | | | | | | | | | | |
| sawmill equipment | MWh/m ³ | | 0,00989 | | 0,00989 | | 0,00989 | | 0,00989 | | 0,00989 | | 0,00989 | | 0,00989 | | - |
| | MWh | | 5 440 | | 5 934 | | 5 934 | | 5 934 | | 5 934 | | 5 934 | | 5 934 | | 29 176 |
| drying and packing line | MWh/m ³ | | 0,03582 | | 0,036 | | 0,036 | | 0,036 | | 0,036 | | 0,036 | | 0,036 | | - |
| | MWh | | 10 624 | | 11 589 | | 11 589 | | 11 589 | | 11 589 | | 11 589 | | 11 589 | | 56 981 |
| boiler houses | MWh/GJ | | 0,00674 | | 0,00674 | | 0,00674 | | 0,00674 | | 0,00674 | | 0,00674 | | 0,00674 | | - |
| | MWh | | 2 961 | | 3 142 | | 3 142 | | 3 142 | | 3 142 | | 3 142 | | 3 142 | | 15 527 |
| other | MWh | | 990 | | 990 | | 990 | | 990 | | 990 | | 990 | | 990 | | 4 950 |
| Self-generation of electricity (new HPP) | MWh | | 20 014 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 21 655 | | 106 633 |
| From the outside | MWh | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 | | 0 |



| Data name | Unit | 2008 | | | 2009 | | | 2010 | | | 2011 | | | 2012 | | | 2008-2012 |
|--|--------------------------|---------|------------------|------------|---------|------------------|------------|---------|------------------|------------|---------|------------------|------------|---------|------------------|------------|------------|
| | | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | New HPP | Old boiler house | Total | |
| Heat (tenno) | | | | | | | | | | | | | | | | | |
| Useful output | GJ | 329 356 | 109 937 | 439 293 | 356 171 | 109 937 | 466 108 | 356 171 | 109 937 | 466 108 | 356 171 | 109 937 | 466 108 | 356 171 | 109 937 | 466 108 | 2 303 727 |
| Housing estate | GJ | 0 | 109 937 | 109 937 | 0 | 109 937 | 109 937 | 0 | 109 937 | 109 937 | 0 | 109 937 | 109 937 | 0 | 109 937 | 109 937 | 549 686 |
| Sawmill | GJ | 329 356 | 0 | 329 356 | 356 171 | 0 | 356 171 | 356 171 | 0 | 356 171 | 356 171 | 0 | 356 171 | 0 | 356 171 | 0 | 1 754 041 |
| including | | | | | | | | | | | | | | | | | |
| drying | GJ/m ³ | 0,995 | - | - | 0,995 | - | - | 0,995 | - | - | 0,995 | - | - | 0,995 | - | - | - |
| | GJ | 294 969 | 0 | 294 969 | 321 785 | 0 | 321 785 | 321 785 | 0 | 321 785 | 321 785 | 0 | 321 785 | 321 785 | 0 | 321 785 | 1 582 108 |
| heating | GJ | 20 041 | 0 | 20 041 | 20 041 | 0 | 20 041 | 20 041 | 0 | 20 041 | 20 041 | 0 | 20 041 | 20 041 | 0 | 20 041 | 100 204 |
| automobile facilities | GJ | 14 346 | 0 | 14 346 | 14 346 | 0 | 14 346 | 14 346 | 0 | 14 346 | 14 346 | 0 | 14 346 | 14 346 | 0 | 14 346 | 71 730 |
| Heat generation gross | GJ | 445 351 | 0 | 445 351 | 481 659 | 0 | 481 659 | 481 659 | 0 | 481 659 | 481 659 | 0 | 481 659 | 481 659 | 0 | 481 659 | 2 371 985 |
| Spent steam from the turbine | GJ | 349 409 | 0 | 349 409 | 378 058 | 0 | 378 058 | 378 058 | 0 | 378 058 | 378 058 | 0 | 378 058 | 378 058 | 0 | 378 058 | 1 861 640 |
| Auxiliary | GJ | 31175 | 0 | 31 175 | 33 716 | 0 | 33 716 | 33 716 | 0 | 33 716 | 33 716 | 0 | 33 716 | 33 716 | 0 | 33 716 | 166 039 |
| Steam through installation of cooling and pressu | GJ | 11 122 | 0 | 11 122 | 11 830 | 0 | 11 830 | 11 830 | 0 | 11 830 | 11 830 | 0 | 11 830 | 11 830 | 0 | 11 830 | 58 440 |
| Fuel (bark and wood waste) | | | | | | | | | | | | | | | | | |
| Consumption of wood waste | m ³ | 88 811 | 24 646 | 113 457 | 96 051 | 24 646 | 120 698 | 96 051 | 24 646 | 120 698 | 96 051 | 24 646 | 120 698 | 96 051 | 24 646 | 120 698 | 596 249 |
| | t | 71 049 | 19 717 | 90 766 | 76 841 | 19 717 | 96 558 | 76 841 | 19 717 | 96 558 | 76 841 | 19 717 | 96 558 | 76 841 | 19 717 | 96 558 | 476 999 |
| | tce | 16 957 | 4 706 | 21 663 | 18 339 | 4 706 | 23 045 | 18 339 | 4 706 | 23 045 | 18 339 | 4 706 | 23 045 | 18 339 | 4 706 | 23 045 | 113 842 |
| | GJ | 523 942 | 145 402 | 669 345 | 566 657 | 145 402 | 712 059 | 566 657 | 145 402 | 712 059 | 566 657 | 145 402 | 712 059 | 566 657 | 145 402 | 712 059 | 3 517 583 |
| Percentage | % | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 | 100,00 |
| Combustion value | GJ/t | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | 7,3744 | 7,3744 | - | - |
| Efficiency of boilers | - | 0,85 | 0,813 | - | 0,85 | 0,813 | - | 0,85 | 0,813 | - | 0,85 | 0,813 | - | 0,85 | 0,813 | - | - |
| Auxiliary and energy loss | - | 0,07 | 0,070 | - | 0,07 | 0,070 | - | 0,07 | 0,070 | - | 0,07 | 0,070 | - | 0,07 | 0,070 | - | - |
| Useful output of energy from boilers | GJ | 414 177 | 109 937 | 524 114 | 447 942 | 109 937 | 557 880 | 447 942 | 109 937 | 557 880 | 447 942 | 109 937 | 557 880 | 447 942 | 109 937 | 557 880 | 2 755 633 |
| Greenhouse gases | | | | | | | | | | | | | | | | | |
| from electricity | t CO ₂ e | | | 0,0 | | | 0,0 | | | 0,0 | | | 0,0 | | | 0,0 | 0,0 |
| from dump | t CO ₂ e | | | | | | 0,0 | | | 0,0 | | | 0,0 | | | 0,0 | 0,0 |
| Total | t CO₂e | | | 0,0 | | | 0,0 | | | 0,0 | | | 0,0 | | | 0,0 | 0,0 |



Annex 2.8.

Estimated GHG emission reductions at Maimaksa production site

| Data name | Unit | Year | | | | | 2008-2012 |
|--|--------------------------|----------------|----------------|----------------|----------------|----------------|-----------------|
| | | 2008 | 2009 | 2010 | 2011 | 2012 | |
| Productivity of sawing and wood waste | | | | | | | |
| Productivity of sawing | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| Drying | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| Amount of wood waste | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| | t | 0 | 0 | 0 | 0 | 0 | 0 |
| including | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| | t | 0 | 0 | 0 | 0 | 0 | 0 |
| sawdust | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| | t | 0 | 0 | 0 | 0 | 0 | 0 |
| Utilized | m ³ | 20 241 | 27 482 | 27 482 | 27 482 | 27 482 | 130 168 |
| For sale | m ³ | 0 | 0 | 0 | 0 | 0 | 0 |
| To the dump | m ³ | -20 241 | -27 482 | -27 482 | -27 482 | -27 482 | -130 168 |
| Electricity | | | | | | | |
| Consumption of electricity | MWh | 0 | 0 | 0 | 0 | 0 | 0 |
| including | | 0 | 0 | 0 | 0 | 0 | 0 |
| sawmill equipment | MWh/m ³ | 0 | 0 | 0 | 0 | 0 | - |
| | MWh | 0 | 0 | 0 | 0 | 0 | 0 |
| drying and packing line | MWh/m ³ | 0 | 0 | 0 | 0 | 0 | - |
| | MWh | 0 | 0 | 0 | 0 | 0 | 0 |
| boiler house | MWh | 0 | 0 | 0 | 0 | 0 | 0 |
| Self-generation of electricity (new HPP) | MWh | 20 014 | 21 655 | 21 655 | 21 655 | 21 655 | 106 633 |
| From the outside | MWh | -20 014 | -21 655 | -21 655 | -21 655 | -21 655 | -106 633 |
| Heat (тепло) | | | | | | | |
| Useful output of energy | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Housing estate | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Sawmill | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| including | | | | | | | |
| drying | GJ/m ³ | 0 | 0 | 0 | 0 | 0 | - |
| | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| heating | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| automobile facilities | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| generation of electricity | GJ | 0 | 0 | 0 | 0 | 0 | 0 |
| Fuel (total) | | | | | | | |
| Consumption of fuel (total) | tce | 1 966 | 2 268 | 2 268 | 2 268 | 2 268 | 11 039 |
| | Gcal | 21 874 | 24 506 | 24 506 | 24 506 | 24 506 | 119 898 |
| | GJ | 91 651 | 102 680 | 102 680 | 102 680 | 102 680 | 502 371 |
| Fuel (mazut) | | | | | | | |
| Consumption of mazut | t | -697 | -1 493 | -1 493 | -1 493 | -1 493 | -6 671 |
| | tce | -947 | -2 027 | -2 027 | -2 027 | -2 027 | -9 054 |
| | Gcal | -6 626 | -14 188 | -14 188 | -14 188 | -14 188 | -63 379 |
| | GJ | -27 763 | -59 449 | -59 449 | -59 449 | -59 449 | -265 558 |
| Fuel (bark and wood waste) | | | | | | | |
| Consumption of wood waste | m ³ | 20 241 | 27 482 | 27 482 | 27 482 | 27 482 | 130 168 |
| | t | 16 193 | 21 985 | 21 985 | 21 985 | 21 985 | 104 134 |
| | tce | 2 913 | 4 295 | 4 295 | 4 295 | 4 295 | 20 093 |
| | GJ | 119 414 | 162 129 | 162 129 | 162 129 | 162 129 | 767 929 |
| Greenhouse gases | | | | | | | |
| from burning of mazut | t CO ₂ e | -2 126 | -4 553 | -4 553 | -4 553 | -4 553 | -20 340 |
| from electricity | t CO ₂ e | -13 609 | -14 725 | -14 725 | -14 725 | -14 725 | -72 511 |
| from dump | t CO ₂ e | -899 | -2 079 | -3 206 | -4 281 | -5 308 | -15 773 |
| Total | t CO₂e | -16 635 | -21 358 | -22 484 | -23 560 | -24 587 | -108 624 |



Annex 2.9.

Автономная некоммерческая
организация

**ЦЕНТР
ЭКОЛОГИЧЕСКИХ
ИНВЕСТИЦИЙ
(ЦЭИ)**

*г. Архангельск, Троицкий проспект 63,
офис 49, тел/факс: (8182)646452
г. Москва, ул. Тверская 22, г-ца «Минск»,
офис 509, тел/факс: (095) 299 1509*

Генеральному директору
ООО «Цигломенский лесозавод»
г-ну Плетневу Г.А.

№ 120-А от 03.04.02

Уважаемый Глеб Анатольевич!

Для того чтобы намечаемый Вами "Проект мероприятий по сокращению вредного воздействия на окружающую среду" рассматривался в том числе и как проект совместного осуществления по линии Рамочной Конвенции ООН об изменении климата и Киотского Протокола, необходимо выполнить следующие расчеты, которые могут быть проведены сотрудниками ЦЭИ:

1. За период 1990-2001 гг. рассчитать ежегодное количество выбросов парниковых газов, регулируемых Киотским протоколом, и перевести их в эквивалент выбросов CO₂.
2. Построить базовую линию выбросов парниковых газов в эквиваленте CO₂ с учетом прогноза выбросов в ближайшие годы при условии, что "Проект мероприятий..." не был бы реализован.
3. Рассчитать ежегодное снижение выбросов в эквиваленте CO₂ по сравнению с базовой линией при условии реализации "Проекта мероприятий..."

Для выполнения указанных расчетов просим Вас представить следующие статистические данные по предприятию за период 1990-2001 гг. и 1-й квартал 2002 г.:

1. Расход топлива в котельной в натуральном и условном выражении по возможности с указанием данных теплотехнического анализа (Приложение 1).
2. Выработка тепловой и электрической энергии (Приложение 2).
3. Объемы производства по распиловке древесины (Приложение 3).
4. Объемы образовавшихся кородревесных отходов и объемы вывоза их в места складирования (Приложение 4).

Кроме того, желательно указать прогнозируемые объемы производства по распиловке древесины в ближайшие годы.

Надеемся на Ваше содействие ЦЭИ в получении необходимой информации.

Непосредственно вопросами, касающимися проведения проекта как климатического, занимается сотрудник ЦЭИ Самородов Александр Викторович.

С уважением,
Директор

Юлкин М.А.



Autonomous non-profit organization
**ENVIRONMENTAL
INVESTMENT
CENTER (EIC)**

General director
«Tsiglomen Sawmill», Ltd.
Mr. G.A.Pletnev

office 49, building 63, Troitsky prospect, Arkhangelsk, 16306.
tel/fax: (8182) 215436
office 509, hotel "Minsk", building 22, Tverskaya street,
Moscow, 103050, тел/факс: (095) 299 1509

120-A_dated _03.04.02._

Dear Gleb Anatolievich!

To view the planned "Project of measures on reduction of harmful effect on the environment" as a JI project under UN framework convection on climate change and Kyoto protocol as well it is necessary to perform the following calculations that could be done by EIC specialists:

1. To calculate yearly amount of GHG emissions regulated by Kyoto protocol and to convert them into CO₂-equivalent units for the period of 1990-2001.
2. To design baseline of GHG emissions in CO₂-equivalent units taking into account emissions prognosis in the nearest years if "Project of measures..." was not implemented.
3. To calculate yearly reduction of emissions in CO₂-equivalent units compared to baseline if "Project of measures..." was implemented.

To do the following calculations we ask you to submit the following statistic data on the enterprise for the period of 1990-2001 and the first quarter of 2002:

1. Fuel consumption in the boiler house in natural and conditional expression with possible specification of the data of the thermotechnical analysis (Annex 1.).
2. Consumption of heat energy and electricity (Annex 2.).
3. Production volumes of wood sawing (Annex 3.).
4. Volumes of formed BWW and volumes of their removal to the stockpiling places (Annex 4.).

Besides it is desirable to specify the predictable production volumes of wood sawing in the nearest years.

We look forward to your assistance to EIC in the obtaining of the required data.


EIC specialist Alexander Victorovich Samorodov deals with the issues of project implementation as a climate one directly.

Regards,
Director

M.A.Yulkin



Annex 2.10.



Annex 3**MONITORING PLAN****Information sources for the definition of greenhouse gas emissions by the plant**

The application of the reckoning method for the definition of GHG emissions requires, except for emission factors, the availability of initial information on different types of the emission-related company operations.

As the control practice of Russian enterprises shows, the main volume of initial data may be derived from the official annual statistical statements compiled by the companies and submitted to the regional statistics committee. If a company doesn't compile some official statistical statements or if they don't include the information required, the internal company data should be used.

The available information sources mutually checking and supplementing each other allow obtaining a reliable volume of the data on company operations, which is the basis for performing reliable GHG emission control.

Let's briefly describe the main information sources.

Statistical form 11-ter „Data on the fuel, thermal power and power use“

This form demonstrates annual data on the power, heat and fuel consumed by the plant for different types of industrial operations, works, specific needs and operation types, as well as on energy consumption by the household sector. Besides that, there is the annex of "Data on the formation and use of secondary energy resources" to the 11-ter form.

The report includes power and fuel consumption, both gross and per product unit. Form 11-ter demonstrates fuel consumption in equivalent units for different types of hard, liquid and gaseous fuels. Separate lines include the fuel energy resources sold to households, fuel consumed as raw material and for non-fuel needs.

The form 11-ter-based reports are especially useful for controlling power consumption, combusted fuel consumption for both the plant as a whole and for separate technological operations and units. The corresponding lines on fuel consumption for power and heat production shall correspond to the data reported under the form 6-tp. The annex to the 11-ter form for secondary resources allows obtaining more specific types and amounts of the biomass combusted.

2-tp (wastes) „Data on the formation, use, sterilization, transportation and allocation of production and consumption wastes“

In the past, this form represented only the data on the toxic waste movements, and since 2002 it has been representing all the company wastes divided by types and danger categories. Some data on the waste dumps are represented as well.

This form can be used for controlling purposes due to its assistance in detecting the amount of wastes with organic content disposed to the dump during the year.

Internal information sources

Additional and detailed information on the fuel consumption and energy balance (in particular, for fuel distribution between small units) can be derived from the internal reports of the chief energy engineer.

In many cases, specific data can be received from the company accounting department.