Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko" page 1

JI MONITORING REPORT FORM. ANNUAL REPORT

Version 2.1 22 October 2008

CONTENTS

- A. General project activity and monitoring information
- B. Key monitoring activities
- C. Quality assurance and quality control measures
- D. Calculation of GHG emission reductions

Initial remark (referring to Decision 17/CP.7, Annex H, paragraph 54, 56, 58 and 60)

54. A monitoring plan for a proposed project activity shall be based on a previously approved monitoring methodology or a new methodology, in accordance with paragraphs 37 and 38 above, that:

(a) Is determined by the designated operational entity as appropriate to the circumstances of the proposed project activity and has been successfully applied elsewhere;

(b) Reflects good monitoring practice appropriate to the type of project activity.

56. Project participants shall implement the monitoring plan contained in the registered project design document.

58. The implementation of the registered monitoring plan and its revisions, as applicable, shall be a condition for verification, certification and the issuance of CERs.

60. The project participants shall provide to the designated operational entity, contracted by the project participants to perform the verification, a monitoring report in accordance with the registered monitoring plan set out in paragraph 53 above for the purpose of verification and certification.

SECTION A. General Project activity information

A.1 Title of the project activity:

"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

A.2. JI registration number:

JI 0035

A.3. Short description of the project activity:

According to data of the mine the following amount of methane was utilized during the first six months of the year 2008:

For electricity (and heat) m ³ (fuel gas)	18,668,161
For electricity (and heat) m ³ (ignition gas)	704,027
For AGFCP m ³	1,079,419
Total 2008 H1	20,451,607

Table 1: Amount of methane utilized during monitoring period.

A.4. Monitoring period:

- Monitoring period starting date: 1/01/2008;
- Monitoring period closing date: 30/06/2008.¹

A.5. Methodology applied to the project activity (incl. version number):

A.5.1. Baseline methodology: The approved consolidated methodology ACM0008/Version 03 "*Consolidated baseline methodology for coal bed methane and coal mine methane capture and use for power (electrical or motive) and heat and/or destruction by flaring*") has been used to identify the baseline scenario of the proposed JI project. This methodology also refers to the "Tool for calculation of emission factor for electricity systems", the latest version of the "Tool for the demonstration and assessment of additionality" and the latest version of the "Tool to determine project emissions from flaring gases containing Methane".

A.5.2. Monitoring methodology: The approved consolidated methodology ACM0008/Version 03 "*Consolidated monitoring methodology for coal bed methane and coal mine methane capture and use for power (electrical or motive) and heat and/or destruction by flaring*") has been used to monitor the proposed JI project.

A.6. Status of implementation including time table for major project parts:

Activity	Date
Commissioning of blocks (#1,#2) at gas filling compressor stations at Vostochnaya site	March 2004
Commissioning of new block #3 at gas filling compressor station at Vostochnaya site	March 2005
Commissioning of the 1 st CHP modules at Vostochnaya site	January 2006
Commissioning of the 12 th CHP modules at Vostochnaya site	April 2006
Shut-down of boilers at Vostochnaya site	September 2006

¹ Both days were included. Monitoring period includes time from 00:00 01/01/08 up to 24:00 30/06/08.

Construction of vacuum pump station N 4 at Grigoryevskaya shaft with six vacuum pumps VVN-150 and build up 3 pipe lines	March 2007
Commissioning of the twelfth power unit on Yakovlevskaya industrial site	July- December 2009
Construction of heat supply unit on Central industrial site; Shut down of boiler houses on Centralnaya industrial site	May 2008
Construction and laying of heating main from Centralnaya site to municipal boiler houses	September 2008
Construction of heating main from Yakovlevskaya to Vostochnaya site. Construction of main Heat Substation. Shutdown boilers at Yakovlevskaya.	October 2009

 Table 2: Status of implementation (according to PDD version 4.4)

A.7. Intended deviations or revisions to the registered PDD:

Activity	Date
Construction of the first power unit on Yakovlevskaya industrial site	Third Quarter 2008
Commissioning of the power units on Yakovlevskaya industrial site	First Quarter 2009
Construction of heat supply unit on Central industrial site; Shut down of boiler houses on Centralnaya industrial site	Second Quarter 2009
Construction and laying of heating main from Centralnaya site to municipal boiler houses	Second Quarter 2009
Construction of heating main from Yakovlevskaya to Vostochnaya site. Construction of main Heat Substation. Shutdown boilers at Yakovlevskaya.	Second Quarter 2009
Construction of heating main from Vostochnaya to Centralnaya industrial site	Third quarter 2008

Table 3: Status of implementation

A.8. Intended deviations or revisions to the registered monitoring plan (Decision 17/CP.7, Annex H, paragraph 57 to be considered):

Compared to the monitoring plan, as described in the PDD version 4.4 which determination was made final on the 24th of August 2008, some meters were changed and added to improve the robustness of the monitored parameters. All these meters were calibrated (see below). The parameters were not changed nor where the formulae altered.

The following meters were added/changed effective 1 January 2008:

The primary and secondary meters were swapped as the metering at the CHP units was upgraded and improved In addition new metering system blocks for methane of high concentration were installed:

- The Universal 1 meter for ignition methane at the CHP facility site instead of Gn6 with its sensors
- The Universal 2 meter for fuel methane at AGFCS in addition to equipment of gas filling blocks
- BKTM metering systems for fuel methane instead of Keuter, ADM Electronic

For detailed description of scheme and operation of equipment refer please to section B.

A.9. Changes since last verification:

Refer please to section A.8 as the changes described in section A.8 occurred after the last verification which was over the period 1/1/2007 until and including 31/12/2007

A.10. Person(s) responsible for the preparation and submission of the monitoring report:

Lease enterprise "Coal Mine named after A.F. Zasyadko"

• Boris Bokiy, Deputy General Director

Global Carbon B.V.

- Lennard de Klerk, Director
- Valeriy Sade, Consultant

SECTION B. Key monitoring activities according to the monitoring plan² for the monitoring period stated in A.4. (Referring to Decision 17/CP.7, Annex H, paragraph 53 (a) – (d) on data collection and archiving)³

The control and monitoring system can be divided into an electrical part, a heat part and a gas part⁴.

Electrical measurements

There are no changes since last monitoring period.

Heat measurements

There are no changes since last monitoring period⁵.

Measurement of CMM consumption

For the purpose of monitoring the emission reductions the following parameters are measured:

- CMM consumed as fuel and ignition gas at the CHP modules (MM_{CHP});
- CMM consumed as fuel at the gas filling stations (MM_{GAS}).

A modern automatic controlling on-line system made by DBT was installed⁶ at the gas treatment plant, including high accuracy measuring instruments and sensors as well as control and stop valves activated by remote drives. All data collected are been screened at the operator's desk monitors in the vacuum pumping station and in the cogeneration plant. Afterwards the work parameters are been channelled to the central dispatching office for further review and storing.

The system has to monitor the followings parameters:

- Mixture flow rate;
- Mixture pressure and temperature;
- Methane and oxygen concentration;

B.1. Monitoring equipment types

² Monitoring manual will be available at the site during verification.

³ Electricity and heart generation as well as methane consumption are calculated at an hourly basis by a computer system.

⁴ All calibration information for metering equipment will be submitted as separate documents.

⁵ There were no changes in the heat distributing over the Mine sites since last monitoring and no heat was supplied to the DH network yet (planned later). Parameters B15, B17, B18, B21 and B23 are therefore not measured and monitored in this monitoring period. All changes will be after commissioning of Yakovlevskaya CHP facility and construction main heat distribution substation at Centralnaya site.

⁶ DBT system works for Vostochnaya CHP plant since the beginning of year 2006. Sensors for methane concentration have been used to provide data for computer monitoring system. All sensors have now Ukrainian Metrology Certificates.

- 1. Electricity meters "Elster-Metronika"
- 2. Heat meter SA-94/2 M
- 3. Gas Analyzer ABB A02040 (for fuel and ignition methane)
- 4. DBT equipment.⁷ (for fuel and ignition methane)
- 5. DRGM flow meters⁸ (for fuel methane) as a part of BKTM metering systems.
- Metering system "Universal"

⁷ For the information about DBT equipment refer please to annex 4. Standard Manufacturer guarantee for calibration is valid till year 2007. This equipment is for supplying of proceeded data to computer system (cross-checking).

⁸ Primary meters

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

B.1.2. Table providing information on the equipment used (incl. manufacturer, type, serial number, date of installation, date of last calibration, information to specific uncertainty, need for changes and replacements)⁹:

The control and monitoring system can be divided into an electrical part, a heat part, and a gas part.

Electrical measurements

There are no changes since last monitoring period. For the purpose of monitoring the emission reductions the following parameters are to be measured:

- 1. Net electricity generation of both CHP systems¹⁰;
- 2. Net electricity consumption of the mine (all four production sites);

					Electrical	wieters						
Measuring	Work	Manufacturer	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks ¹¹
instrument	parameter			Number	level of	of	1.01.2008	30.062008	rence	last calibr.	next	
	kWh, kVar				data and	instal-					calibr.	
					accuracy	lation						
Electricity	Net	"Elster-	Electr	01116374	$\pm 0.2\%^{12}$	N/A	3748.553	4571.951	823.398	14.05.2005	2-nd	Double
meter at CHP	electricity	Metronika"	onic								Quarter	side.
system (6 kV)	generated by	Russia									2011	Cubicle
Wireway	CHP system.											#A2
	P,Q											

Electrical Meters

⁹ For all technical data refer please to Monitoring Report for year 2004-2006.

¹⁰ At the moment only electricity generated by CHP facility Vostochnaya is measured. The commercial amount of net electricity supplied to consumer is reflected in statement submitted by Chief Energy Manager of the Mine. Refer please to Supporting Document 8. Real amount of net electricity generated is reflected in Supporting Document 4

¹¹ The Meters in cubicles from A2 to #16 are installed at CHP facility used as secondary meters for cross-checking at CHP facility.

¹² measurement range (accuracy) 80...120 V;0...5 (10-max) A.

page 9

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Measuring instrument	Work parameter kWh, kVar	Manufacturer	Туре	Serial Number	Uncertainty level of data and accuracy	Date of instal- lation	Data 1.01.2008	Data 30.06.2008	Diffe rence	Date of last calibr.	Date of next calibr.	Remarks
Electricity meter at CHP system (6 kV) Wireway	Net electricity generated by CHP system. P,Q	"Elster- Metronika" Russia	Electr- onic	01116376	±0.2%	N/A	3651.190	4541.015	889.825	14.05.2005	2-nd quarter 2011	Double side. Cubicle #A22
Electricity ¹³ meter at CHP system (6 kV) Auxiliary transformer	Auxiliary electricity generated by CHP system	"Elster- Metronika" Russia	Electr- onic	01103251	±0.2%	N/A	1879.733	2320.401	440.668	03.09.2004	3-d quarter 2010	Cubicle #1
Electricity meter at CHP system (6 kV) Auxiliary transformer	Auxiliary electricity generated by CHP system	"Elster- Metronika" Russia	Electr- onic	01103208	±0.2%	N/A	2115.038	2545.635	430.597	03.09.2004	3-d quarter 2010	Cubicle #2
Electricity meters at individual CHP modules (6 kV) #1	Gross electricity generated by CHP system P,Q	"Elster- Metronika" Russia	Electr- onic	01117846	±0.2%	N/A	3325.768	4305.705	979.937	16.06.2005	2-nd quarter 2011	Double side. Cubicle #5
Electricity meters at individual CHP modules (6 kV) #3	Gross electricity generated by CHP system P,Q	"Elster- Metronika" Russia	Electr- onic	01117849	±0.2%	N/A	4145.375	5162.092	1016.717	16.06.2005	2-nd quarter 2011	Double side. Cubicle #7

¹³ Auxiliary transformer meters are located at distribution board at CHP facility.

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Electr-

Electr-

Electr-

onic

onic

onic

01117855

01117856

01117848

±0.2%

±0.2%

 $\pm 0.2\%$

N/A

N/A

N/A

Work

Gross electricity

P,Q

P,Q Gross

P,Q

P,Q

P,Q

Gross

electricity

generated by

CHP system

Gross

electricity

generated by

CHP system

Gross

electricity

electricity

generated by

CHP system

generated by CHP system

"Elster-

Metronika"

Russia

"Elster-

Metronika"

Russia

"Elster-

Metronika"

Russia

parameter kWh, kVar

generated by

CHP system

Measuring instrument

Electricity

meters at individual

(6 kV) #5

Electricity

meters at

individual

(6 kV) #7

Electricity

meters at

individual

(6 kV) #9

Electricity

meters at

individual

(6 kV) #11

Electricity

meters at

individual

(6 kV) #2

CHP modules

CHP modules

CHP modules

CHP modules

CHP modules

Manufactur	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks
er		Number	level of	of	1.01.2008	01.07.2008	rence	last calibr.	next	
			data and	instal-					calibr.	
			accuracy	lation						
"Elster-	Electr-	01117851	±0.2%	N/A	4879.196	5733.136	853.940	16.06.2005	2-nd	Double
Metronika"	onic								quarter	side.
Russia									2011	Cubicle
										#9
"Elster-	Electr-	01117852	±0.2%	N/A	4610.584	6128.105	1517.521	16.06.2005	2-nd	Double
Metronika"	onic								quarter	side.
Russia									2011	Cubicle
										#11

5024.958

4588.729

4785.782

6255.314

5911.937

6089.818

1230.356

1323.208

1304.036

16.06.2005

16.06.2005

16.06.2005

page 10

Double

Cubicle

Double

Cubicle

Double

Cubicle

side.

#6

side.

#15

side.

#13

2-nd

quarter

2011

2-nd

quarter

2011

2-nd

quarter

2011

Monitoring Rej	port #3 "Utiliza	tion of Coal Mi	ne Methane at	the Coal Mine	named after A	.F. Zasyadl	ko"				I	page 11
Measuring	Work	Manufacturer	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks
instrument	parameter			Number	level of	of	1.01.2008	01.07.2008	rence	last calibr.	next	
	kWh, kVar				data and	instal-					calibr.	
					accuracy	lation						
Electricity	Gross	"Elster-	Electr-onic	$\mathbb{N}_{\mathbb{Q}}$	±0.2%	N/A	4274.116	4865.285	591.169	10.08.2005	3-d	Double
meters at	electricity	Metronika"		01122645							quarter	side.
individual	generated by	Russia									2011	Cubicle
CHP modules	CHP system											#8
(6 kV) #4	P,Q											
Electricity	Gross	"Elster-	Electr-onic	No	±0.2%	N/A	4251.701	5224.365	972.664	10.08.2005	3-d	Double
meters at	electricity	Metronika"		01122650							quarter	side.
individual	generated by	Russia									2011	Cubicle
CHP modules	CHP system											#10
(6 kV) #6	P,Q											
Electricity	Gross	"Elster-	Electr-onic	N⁰	±0.2%	N/A	5158.059	6564.53	1406.47	16.06.2005	2nd	Double
meters at	electricity	Metronika"		01117845					1		quarter	side.
individual	generated by	Russia									2011	Cubicle
CHP modules	CHP system											#12
(6 kV) #8	P,Q											
Electricity	Gross	"Elster-	Electr-onic	\mathbb{N}_{2}	±0.2%	N/A	4886.848	6091.700	1204.85	09.02.2006	1-t	Double
meters at	electricity	Metronika"		01132765					2		quarter	side.
individual	generated by	Russia									2012	Cubicle
CHP modules	CHP system											#14
(6 kV) #10	P,Q											

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Measuring	Work	Manufactur	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks
instrument	parameter	er		Number	level of data	of instal-	1.01.2008	01.07.2008	rence	last calibr.	next	
	kWh, kVar				and accuracy	lation					calibr.	
Electricity	Gross	"Elster-	Electr-	N⁰	±0.2%	N/A	5163.289	6101.178	937.889	09.02.2006	1 - t	Double
meters at	electricity	Metronika"	onic	01132766							quarter	side.
individual	generated by	Russia									2012	Cubicle
CHP modules	CHP system											#16
(6 kV) #12	P,Q											
Commercial	Power	"Elster-	Electr-	N⁰	±0.2%	N/A	280.211	289.371	9,160,00	N/A	N/A	Substation
electricity	consumption	Metronika"	onic	1116378						Belongs to		110kV
meter at 110	from or supply	Russia								supply		
kV	to the									company		11
	Ukrainian grid											
Commercial	Power	"Elster-	Electr-	N⁰	±0.2%	N/A	285.586	303.921	18,335,00	N/A	N/A	Substation
electricity	consumption	Metronika"	onic	1116380						Belongs to		
meter at 110	from or supply	Russia								supply		
kV	to the									company		12
	Ukrainian grid											

Calibration interval for electricity meters is six years.

As it is impossible to use meters data directly to check electricity generated we have to take in account special coefficients which is appears from multiplying of coefficients transformation for current and voltage transformers connected to each meter. Their data are presented in table below.

Measuring	Work	Туре	Serial	Data	Data	Diffe	Current	Voltage	Coefficient	Electricity
instrument	parameter		Number	1.01.2008	1.072008	rence	transformer	transformer	for	Ammount
	kWh, kVar								calculations	KW

Monitoring Re	Aonitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"											
Electricity	Net	Electr	01116374	3748.553	4571.951	823.398	3000/5	6300/100	37800	31,351.224 ¹⁴		
meter at CHP	electricity	onic										
system (6 kV)	generated											
Wireway	by CHP											
	system. P,Q											
Electricity	Net	Electronic	01116376	3651.190	4541.015	889.825	3000/5	6300/100	37800	33,635.385		
meter at CHP	electricity											
system (6 kV)	generated											
Wireway	by CHP											
T 1	system. P,Q		01100051	1050 500		110.000	2 0 0 / 5	(200/100	0.500	1 1 1 0 1 0 0		
Electricity	Auxiliary	Electronic	01103251	18/9./33	2320.401	440.668	200/5	6300/100	2520	1,110.483		
meter at CHP	electricity											
system (6 kV)	generated											
Auxiliary	by CHP											
transformer	system		01100000	2115.000		120 505	2 0 0 / 5	(200/100	0.500	1.005.104		
Electricity	Auxiliary	Electronic	01103208	2115.038	2545.635	430.597	200/5	6300/100	2520	1,085.104		
meter at CHP	electricity											
system (6 kV)	generated											
Auxiliary	by CHP											
transformer	system	T I	01115016	2225 5 5 6	1205 505		400/5	(200/100	7 040	4 0 0 0 0 0		
Electricity	Gross	Electronic	01117846	3325.768	4305.705	979.937	400/5	6300/100	5040	4,938.882		
meters at	electricity											
individual	generated											
CHP modules	by CHP											
(6 kV) #1	system P,Q											

¹⁴ Because of high voltage and currents it is impossible to get direct figures from electricity meters for electricity generation or consumption without current and voltage transformers for monitor equipment. The way of calculation used as following: I.e for meter # 01116374: Current is 3000/5 = 600A; Voltage is 6300/100 = 63V(cumulative rate is 600x63 = 37800VA). Data of meter are 829.328. Electricity power monitored with this meter will be: $829.398 \times 600x63 = 31,351,244.4 VA = 31,351.244 kW$.

Monitoring R	eport #3 "Utili	ization of Coal	Mine Methan	e at the Coal	Mine named	d after A.F. Z	Zasyadko"			
Measuring instrument	Work parameter kWh, kVar	Туре	Serial Number	Data 1.01.2008	Data 1.072008	Diffe rence	Current transformer	Voltage transformer	Coefficient for calculations	Electricity Amount KW
Electricity meters at individual CHP modules (6 kV) #3	Gross electricity generated by CHP system P,Q	Electronic	01117849	4145.375	5162.092	1016.717	400/5	6300/100	5040	5,124.254
Electricity meters at individual CHP modules (6 kV) #5	Gross electricity generated by CHP system P,Q	Electronic	01117851	4879.196	5733.136	853.940	400/5	6300/100	5040	4,303.858
Electricity meters at individual CHP modules (6 kV) #7	Gross electricity generated by CHP system P,Q	Electronic	01117852	4610.584	6128.105	1517.521	400/5	6300/100	5040	7,648.306
Electricity meters at individual CHP modules (6 kV) #9	Gross electricity generated by CHP system P,Q	Electronic	01117855	5024.958	6255.314	1230.356	400/5	6300/100	5040	6,200.994
Electricity meters at individual CHP modules (6 kV) #11	Gross electricity generated by CHP system P,Q	Electronic	01117856	4588.729	5911.937	1323.208	400/5	6300/100	5040	6,668.968

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Electricity Gross Electronic 1117848 4785.782 6089.818 1304.036 400/56300/100 5040 6,572.341 electricity meters at individual generated by CHP modules CHP system (6 kV) #2 P,Q Electronic 01122645 4274.116 591.169 400/5 5040 2,979.492 Electricity Gross 4865.285 6300/100 electricity meters at individual generated by CHP modules CHP system (6 kV) #4 P,Q Electronic 01122650 5224.365 972.664 400/5 6300/100 5040 4,902,226 Electricity Gross 4251.701 electricity meters at individual generated by CHP system CHP modules (6 kV) #6 P,Q Electricity Electronic 01117845 5158.059 6564.53 1406.471 400/5 6300/100 5040 7,088.614 Gross electricity meters at individual generated by CHP modules CHP system P,Q (6 kV) #8 Electricity Gross Electronic 01132765 4886.848 6091.700 1204.852 400/5 6300/100 5040 6,072.454 electricity meters at individual generated by CHP system CHP modules P,Q (6 kV) #10 Electricity Electronic Gross 01132766 5163.289 6101.178 937.889 400/56300/100 5040 4,726,960 electricity meters at individual generated by CHP system CHP modules (6 kV) #12 P.O Commercial 01116378 110000/100 Power Electronic 280.211 289.371 9,160,00 1000/5 220000 2,015.035 electricity consumption from or supmeter at 110 ply to the kV Ukrainian

Monitoring Re	Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"												
	grid												
Commercial	Power	Electronic	01116380	285.586	303.921	18,335,00	1000/5	110000/100	220000	4,033.656			
electricity	consumption												
meter at 110	from or sup-												
kV	ply to the												
	Ukrainian												
	grid												

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Electricity Metering Scheme for Vostochnaya CHP Facility



Figure 1: Electricity Metering Scheme for Vostochnaya CHP Facility

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko" Heat Meter page 18

Heat measurements

The amount of generated heat is measured at each individual cogeneration unit. The total amount of heat supplied by the CHP station to Vostochnaya site is monitored by the meters given below.

For this monitoring period only heat was supplied to the Vostochnaya site so for this monitoring period the amount of heat supplied by the CHP system to the heat transportation pipes is identical to the heat consumed by the Vostochnaya site. After Yakovlevskaya CHP plant will be commissioned it is planned to combine the heat system from both Vostochnaya and Yakovlevskaya sites with a help of Central Heat Distribution facility where all metering for the consumed heat of each site and the heat delivered to district heating will be individually measured. This would mean the installation of separate meters for the Centralnaya and Grigoryevskaya sites and the delivery to the DH-system.

As it is impossible to stop electricity generation all generated heat is dissipated in case of no demand. For this purpose the system contains lamellate radiators and was installed at the roof of CHP facility.

Measuring	Work	Manufactu	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks
instrument	parameter	rer		number	level of	of	1.01.2008	30.06.2008	rence	last calibre.	next	
	GCal				data,	installation	Gcal	Gcal			calibre.	
					accuracy							
Heat meter	Amount of	ASWEGA	Mecha	22903	±2%	N/A	41675.59	57659.09	15983.5	04.06.07	04.06.09	T,V,Q
SA	heat		tronic									(Total)
$94/2M^{15}$	delivered to											
	site system											

Calibration interval for heat meters is two years.

¹⁵ For meter SA 94/2M DN=300mm; Q=1000m³/h

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"



Figure 2: Heat Metering Scheme for Vostochnaya CHP Facility

CMM Meters Measurement of CMM consumption

The CMM consumption of the project can be separated in three parts:

- 1. Fuel gas consumption of the CHP units
- 2. Ignition gas consumption of the CHP units
- 3. Gas consumption of the AGFCP

To determine the amount of pure consumed CH_4 (in tonnes) the amount of pure CH_4 (in m³) has to be measured under normal conditions. The amount of pure CH_4 (in m³) can be measured (or more correctly: calculated) based on four parameters:

- Concentration (%) of CH₄ in the gas mixture
- Flow (m³) of gas mixture
- Temperature (C) of gas mixture
- Pressure (bar) of gas mixture

In the scheme below the different meters and sensors are indicated that are installed at the Vostochnaya site. We can classify the different meters/sensors:

- Primary meters/sensors that supply the data for determining the emission reductions as provided in section D of the Monitoring Report;
- Secondary meters/sensors used for cross-checking the data of the primary meters;
- Tertiary meters/sensors used to operated and control the installation only.

The tertiary meters/sensors are not of interest for monitoring purposes and are not mentioned further. In the table below the primary (yellow) and secondary meters/sensors (orange) are indicated with their number which listed in the scheme.

	Primary meters/sensors	Secondary meters/sensors
		used for determining
		CMM consumption for
		cross-checking purposes
Fuel gas		
Concentration (%)	K7	ABB AO 2040 (A1)
Flow (V)	G1-G12 ¹⁶	Gn5
Temperature (T)	T6-T17	Gn5 sensor
Pressure (P)	P11-P22	P6(Gn5's sensor)
Unit that converts data into	Automatic control system in	DBT equipment
pure methane (m3)	dispatch	

¹⁶Meters G1-G12 are being used as primary meters.

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadk	:0"
--------------------------------------------------------------------------------------------------	-----

Ignition gas		
Concentration (%)	ABB AO 2040 (A2)	ABB AO 2040 (A2)
Flow (V)	G13	Gn6
Temperature (T)	T5	Gn6 sensor
Pressure (P)	P10	P10(Gn6's sensor)
Unit that converts data into pure methane (m3)	'Universal" metering system	DBT equipment
AGFCP gas		
Concentration (%)	ABB AO 2040 (A2)	ABB AO 2040 (A2)
Flow (V)	G14	Calculations according to pressure difference
Temperature (T)	T18	
Pressure (P)	P23	Manometers at AGFCS
Unit that converts data into pure methane (m3)	G14	Calculations

Table 4: Primary and secondary (cross-checking) metering of CMM

Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"



Monitoring Report #3 "Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko" page 23

The general flow of CMM and the metering can be described as follows.¹⁷

Coal mine gas of degassing and gas-suction activities is supplied through four lines from two Vacuum Pump Station (VPS) to the gas mixing section of the CHP gas treatment facility. The concentration and pressure of methane are different in each pipe-line. These parameters are measured by K1...K4 Monimet concentration sensors and P1...P4 Vegabar pressure sensors. *Measurements data of these sensors are not used in gas metering and are needed for operational purposes*; these data are channelled to an automatic control system of the dispatch *and used only for controlling purposes* in order to obtain at the output homogeneous fuel methane with necessary concentration.

The methane concentration that is fed to the gas treatment facility is measured by the Monimet K5 sensor. Also in the flow the T1 temperature sensor and the P5 pressure sensor are installed. Methane from surface wells is mixed into fuel methane in case of necessity to increase the concentration. The flow of goaf wells methane is measured by Gn4 flow meter Keuter together with velocity pressure and temperature sensors. The concentration of mix in methane from goaf wells is measured by Monimet K6 sensor. Having all this data the automatic control system of the dispatch can calculate the amount of methane in the gas mixture.

At the gas treatment section of the facility methane is distributed between three lines where it is dried, cooled, cleaned and wormed. Flow measurements are provided by Gn1 - Gn3 Keuter flow meters together with velocity, pressure and temperature sensors. They transmit information to the calculation equipment developed by DBT which is installed in separate premise of the gas metering section. This block calculates the values of actual consumption for normal conditions and channel them to the automatic control system of the dispatch computer system for operation. For checking and reserve, pressure P7 – P9 and temperature T2 – T4 sensors have been installed in the pipelines.

At the outflow of gas treatment section the processing discharge valve is installed which smoothes the pressure swings at abrupt changes of the CHP operation regime. Pressure at the outflow of the section is controlled by processing sensor P6.

For the purpose of fuel gas concentration determination, gas testing is made at the outflow of the gas treatment section of facility at point A1 which is fed to thegas analyzer AO 2040 (ABB) mounted at gas metering unit. Metered concentration is checked for the compliance with sensor date Monimet K7. The flow meter Gn5 (Keuter) as a unit with speed, pressure and temperature sensors measures the gas amount used by CHP units. The methane amount is calculated based on the data of methane concentration *but is not used monitoring purposes*.

Then fuel gas is supplied to the units of CHPs engine rooms. The flow meters G1- G12, type DPG.M-10000, temperature sensors T6 - T17 and pressure sensors P11 - P22 are mounted on the line of each 12 units. Their data are transmitted to microprocessing control system BKT.M for calculation of fuel gas amount which is used by each unit and total amount in each engine room. Fuel gas amount is calculated based on the data of methane concentration in it. *Total amount in engine rooms gives the methane amount in fuel gas utilized by CHP and is recorded in the database*.

Ignition gas is supplied to the CHP units from the gas pipes of surface degasification boreholes. Total current ignition gas consumption is metered by flow meter G13 (Universal). Gas concentration is metered by gas

¹⁷ From year 2008 DBT equipment is used as cross-checking equipment. Main meters installed at each CHP unite will be channel data to BKTM metering system. The BKTM meters will channel data to computer system. Besides all the data will be store at four BKTM. Every "BKTM unite" combines three CHP's. These systems operates with fuel methane. The ignition methane for all CHP is measured with a new metering system "Universal" which is include LGK-Meter, temperature, pressure and flow sensors. All these data are stored at place and channel to Cogen plant computer system.

analyzer AO 2040 (ABB) with gas test at the point A2, pressure and temperature are measured by sensors P10 and T5. Based on it automatic control system of dispatch service determines the methane amount which is fed to the CHPs with *ignition gas which is recorded in database*.

Gas that is supplied for automobiles filling is metered by sensor G14 "Universal", pressure and temperature are measured by sensors P10 and T18. Based on it the methane amount fed to AGFCS *for automobiles filling and recorded in database*.

Methane volume which is supplied with fuel gas and methane of ignition gas gives total amount of methane supplied to CHPs.

Methane volume which is supplied with fuel gas and methane of ignition gas, methane for automobiles filling gives total amount of methane consumed by Zasyadko coal mine Vostochnaya site.



Figure 4: Sensors of flow, temperature and pressure at the CHP unit fuel methane pipeline

In the table below the description of the secondary meters (indicated brown in the schema) are given:

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

page 25

Gas treatment section measuring equipment¹⁸

Gas analyzers

Measuring instrument	Work	Manufacturer	Туре	Serial	Uncertainty	Date	Date of	Date of	Remarks
Concentration ¹⁹	parameter,	20		number	level of data,	of	last calibr.	next calibr.	
	%				accuracy	installation			
Concentration of fuel	Concentrati	ABB	AO2040	3.244705.	±1%	2005	13.07.07	13.07.08	A1
gas	on, %		Electronic	5					connection
Concentration of	Concentrati	ABB	AO2040	3.244704.	±1%	2005	11.07.07	13.07.08	A2
ignition gas	on, %		Electronic	5					connection

Calibration interval for gas analyzers is two years

Flow meters

Measuring	Work	Manufac	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Re
instrument	parameter,	turer		numbe	level of data,	of install	1.01.2008	30.06.2008	rence	last calibr.	next calibr.	marks
	m ³ /h			r	accuracy	lation	m3	m3				
Amount of	Volume of	NVP"GREM	Univers	6023	±1%	4-th quarter	515075.1	1272092.1	757017,00	27.08.07	23.07.10	Main
ignition gas	combustible	PIS" ltd	al-2			2007				23.07.08		meter
	methane											
	supplied to											
	CHP modules											
Amount of	Volume of	NVP"GREM	Univers	327	±1%	4-th quarter	1321328	2477856	1156528	12.04.07	28.07.10	Main
fuel gas	methane	PIS" ltd	al-2			2007				28.07.08		meter
	supplied to											
	AGFCS											

Calibration interval for flow meters is two years

¹⁸ For technical date of the pressure and temperature sensors please refer to annex 4

¹⁹ See supporting document SD_1_CMM analysis

²⁰ One and a half year manufacturer warrantee obligations from commission date.

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Measuring	Work parameter,	Manufactu	Туре	Serial	Uncertainty	Date	Data	Data	Diffe	Date of	Date of	Remarks
instrument	m3/h	rer		number	level of	of	1.01.2008	30.06.2008	rence	last	next	
Flow meters					data,	instal	m3	m3		calibr.	calibr.	
					accuracy	lation						
Volume of combustible methane consumed as fuel gas at each CHP module (1)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	102	±1%	N/A	2934529	7832046	4897517	21.06.05	16.07.08	DRGM flow meters at 1-3- 5 units belongs to #245 BKTM meter
												Refer table bellow
Volume of combustible methane consumed as fuel gas at each CHP module (2)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	108	±1%	N/A	1525216	1525216	*	21.06.05	15.07.08	DRGM flow meters at 2-4- 6 units belongs to #094 BKTM meter Refer table
Volume of combustible methane consumed as fuel gas at each CHP module (3)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	109	±1%	N/A	1714301	6821492	5107191	21.06.05	18.07.08	bellow
Volume of combustible methane consumed as fuel gas at each CHP module (4)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	104	±1%	N/A	2544048	2602780	58732	17.06.05	15.07.08	*

^{*} See next table and explanations

^{*} See next table and explanations

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

*

Volume of combustible methane consumed as fuel gas at each CHP module (5)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	103	±1%	N/A	2686162	6895780	4209618	21.06.05	17.07.08	
Volume of combustible methane consumed as fuel gas at each CHP module (6)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	97	±1%	N/A	2113216	2113216	*	21.06.05	16.07.08	*
Volume of combustible methane consumed as fuel gas at each CHP module (7)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	98	±1%	N/A	2825530	8026030	5200500	21.06.05	16.07.08	DRGM flow meters at 7-9- 11 units belongs to #245 BKTM meter Refer table bellow
Volume of combustible methane consumed as fuel gas at each CHP module (8)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	105	±1%	N/A	2552144	9550037	6997893	21.06.05	17.07.08	DRGM flow meters at 8- 10-12 units belongs to #095 BKTM meter Refer table bellow
Volume of combustible methane consumed as fuel gas at each CHP module (9)	Volume of combustible methane supplied to CHP modules	Sibnefte avtomati ca, Russia	DRGM Elec- tronic	99	±1%	N/A	2647777	6129636	3481559	21.06.05	17.07.08	
Volume of combustible	Volume of combustible	Sibnefte avtomati	DRGM Elec-	96	±1%	N/A	2382586	8496821	6114235	21.06.05	18.07.08	

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

page 28

methane consumed	methane supplied	ca,	tronic									
as fuel gas at each	to CHP modules	Russia										
CHP module (10)												
Volume of	Volume of	Sibnefte	DRGM	101	±1%	N/A	2160516	6120278	3959762	21.06.05	17.07.08	
combustible	combustible	avtomati	Elec-									
methane consumed	methane supplied	ca,	tronic									
as fuel gas at each	to CHP modules	Russia										
CHP module (11)												
Volume of	Volume of	Sibnefte	DRGM	100	±1%	N/A	3049648	7843509	4793861	21.06.05	15.07.08	
combustible	combustible	avtomati	Elec-									
methane consumed	methane supplied	ca,	tronic									
as fuel gas at each	to CHP modules	Russia										
CHP module (12)												

Calibration interval DRGM flow meters is three years

During year 2008 it was necessary to replace for calibration some BKTM metering systems. So their data before and after calibration are present in the table bellow.

Measuring	Serial	Data	Data	Dif-		The initial	Data	Data after	Total ²¹ ,
instrument	number	1.01.200	30.06.200	ference		data after	30.06.2008	replacing for	m3
Flow meters		8	8			replacing,	m3	calibration,	
		m3	m3			m3		m3	
Volume of combustible	102	2934529	7832046	4897517					4897517
methane consumed									
as fuel gas at each									
CHP module (1)									
Volume of	108	1525216	1525216	0	Poplacing of	0	6173808	6173808	6473808
combustible					Replacing of	0	04/3090	04/3898	04/3090
methane consumed					calibration				
as fuel gas at each					Cambration				
CHP module (2)					02.01.2008				

²¹ This figures are used for calculations of methane consumption to generate electricity and heat for six months year 2008. They are reflect volume of methane- air mixture with average concentration 30%

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

Volume of	109	1714301	6821492	5107191					5107191
combustible									510/171
methane consumed									
as fuel gas at each									
CHP module (3)									
Volume of	104	2544048	2602780	58732	Replacing of	0	2023//0	2023//0	2082181
combustible					Replacing of BKTM for	0	2923449	2923449	2902101
methane consumed					calibration				
as fuel gas at each					canoration				
CHP module (4)					02.01.2008				
Volume of	103	2686162	6895780	4209618					4200618
combustible									4209018
methane consumed									
as fuel gas at each									
CHP module (5)									
Volume of	97	2113216	2113216	0	Replacing of	0	4976744	4976744	4976744
combustible					Replacing of BKTM for	Ŭ	++1017+	+7707++	+7707++
methane consumed					calibration				
as fuel gas at each					canoration				
CHP module (6)					02.01.2008				
Volume of	98	2825530	8026030	5200500	Replacing of	0	2472038	2472038	7672538
combustible					Replacing of RKTM for	U	2472030	2472030	1012330
methane consumed					calibration				
as fuel gas at each					canoration				
CHP module (7)					01.05.2008				
Volume of	105	2552144	9550037	2472038					2472038
combustible									2472030
methane consumed									
as fuel gas at each									
CHP module (8)									
Volume of	99	2647777	6129636	3481559	Replacing of	0	2590533	2590533	6072392
combustible					BKTM for		2070000	2070000	0012372
methane consumed					calibration				
as fuel gas at each					Cultoration				
CHP module (9)					01.05.2008				
Volume of	96	2382586	8496821	6114235					6114235
combustible]				0111233

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

methane consumed as fuel gas at each CHP module (10)									
Volume of combustible methane consumed as fuel gas at each CHP module (11)	101	2160516	6120278	3959762	Replacing of BKTM for calibration 01.05.2008	0	2676571	2676571	6636333
Volume of combustible methane consumed as fuel gas at each CHP module (12)	100	3049648	7843509	4793861					4793861

The monitoring system for the emission reductions achieved in the course of the project implementation has been integrated in the Zasyadko Coal Mine existing controlling and reporting system. That allows for obtaining reliable and easy verifiable data related to the project performance, ensuring thus the quality and efficiency of the monitoring system.

All source information on performance parameters and calculations have been obtained directly on site and after that reported to the Coal Mine dispatching office. The work parameters of CMM flows as well as heat and power produced is crosschecked to provide quality and reliability of monitored data.

CMM consumption of gas filling stations

Each of two blocks of Vostochnaya gas filling station has records in the registers. Calculations of methane fuel are executed according to data pressure difference of manometers. Concentration of methane is measured monthly with ABB AO 2040 at Power Station and ground wells analysis. Besides, the concentration of methane is measured locally with an interferometer. Temperature and pressure meters are installed as well. The volume of methane is measured by "Universal-2" metering system.

B.1.3. Calibration procedures

For Electricity Meters:

QA/QC procedures	Body responsible for calibration and
	certification
Calibration interval of such meters is six years. Calibration procedures for meters are implemented in compliance with calibration methodology developed for "Elster-Metronika" meters, Russia. Manufacturer's warranty-36 months	Ukrainian Centre for Standardization and Metrology

For Heat Meters

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after A.F. Zasyadko"

page 31

QA/QC procedures	Body responsible for calibration and certification
Calibration interval of such meters is two years. Calibration procedures for meters are implemented in compliance with calibration methodology developed for ASWEGA meters, Russia. Manufacturer's warranty-18 months	Ukrainian Centre for Standardization and Metrology

For CMM meters:

QA/QC procedures	Body responsible for calibration and certification
Keuter ADM1 Electronic. Calibration interval of such meters is 1 year ²² .	Ukrainian Centre for Standardization and Metrology
Gas Analyzer ABB A02040. Calibration interval of such meters is 1 year.	Ukrainian Centre for Standardization and Metrology

B.1.4. Involvement of Third Parties:

Ukrainian Centre for Standardization and Metrology²³.

B.2. Data collection (accumulated data for the whole monitoring period):

For the operational and management structure of the project see PDD, Figure 5 : Monitoring and quality control system for Vostochnaya and Yakovlevskaya sites

²² As there is no state regulation for such kind of equipment there was a decision of Ukrainian Centre for Standardization and Metrology for one year calibration period.

²³ All measurement equipment should be calibrated according to terms and methodology defined by this centre requirements.

Monitoring Report #3"Utilization of Coal Mine Methane at the Coal Mine named after AF.Zasyadko"page 32

B.2.1. List of fixed default values:

ID number	Data variable	Source of data	Data unit	Comment
P6 CEF _{CH4}	Carbon emission	2006 IPCC Guidelines for	tCO2e/tCH4	Set at 2.75 tCO2e /tCH4
	factor for combusted	National Greenhouse Gas		See also table CMM
	methane	Inventories.		meters
		Volume 2: Energy		
		Chapter 4: Fugitive Emissions		
P12 Eff _{CHP}	Efficiency of	2006 IPCC Guidelines for	%	Set at 99,5%
	methane	National Greenhouse Gas		
	destruction/oxidation	Inventories.		
	in CHP	Volume 2: Energy		
		Chapter 4: Fugitive Emissions		
P14 Eff _{GAS}	Overall efficiency of	2006 IPCC Guidelines for	%	Set at 98.5%
	methane	National Greenhouse Gas		
	destruction/oxidation	Inventories.		
	at the vehicles	Volume 2: Energy		
		Chapter 4: Fugitive Emissions		
P15 GWP _{CH4}	Global warming	2006 IPCC Guidelines for	tCO2e/tCH4	Set at 21
	potential of methane	National Greenhouse Gas		
		Inventories.		
		Volume 2: Energy		
		Chapter 4: Fugitive Emissions		

Table 5: Project variables

ID number	Data variable	Source of data	Data unit	Comment
B13 EFgrid,produced,y	Emissions factor of electricity of replaced grid electricity production by the project activity in year	See annex 2	tCO ₂ /MWh	See annex 2 PDD See also table "Electrical Meters"
B14 EF _{grid,reduced,y}	Emissions factor of electricity of replaced on-site electricity consumption by the project activity	See annex 2	tCO ₂ /MWh	See annex 2 PDD See also table "Electrical Meters"
B20 EF _{heat,vost}	Emissions factor for heat at Vostochnaya site in the baseline scenario	Boiler efficiency	tCO ₂ /GJ	See annex 2 PDD See also table "Heat Meters"
B22 EF _{heat,yak}	Emissions factor for heat at Yakovlevskaya site in the baseline scenario	Boiler efficiency	tCO ₂ /GJ	See annex 2 PDD See also table "Heat Meters"
B24 EF _{heat,centr}	Emissions factor for heat at Centralnaya site in the baseline scenario	Boiler efficiency	tCO ₂ /GJ	See annex 2 PDD. See also table "Heat Meters"
B25 VFUEL _y	Vehicle fuel provided by the project activity	Fuel Meters	GJ	This value will be calculated based MM_{GAS} of the project scenario

				multiplied with LHV of methane
B26 EF _v	Emissions factor for vehicle operation replaced by the project activity	2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 2: Energy Chapter 4: Fugitive Emissions	tCO ₂ /GJ	See annex 2 PDD

Table 6:Baseline Variables

B.2.2. List of variables:

Project emissions variables to be measured:

MM _{CHP}	Methane measured sent to power plant (tCH4)
MM_{GAS}	Methane measured supplied to gas grid for vehicle use (tCH4)

Baseline emissions variables to be measured:

GEN_{CHP}	Net electricity generated by the project activity by the CHP plants
$El_{Consumed}$	Net electricity consumed by the mine on-site
HEAT cons, vost, y	Heat consumed at Vostochnaya site delivered by the project year y
$VFUEL_y$	Vehicle fuel provided by the project activity

B2.3. Data concerning GHG emissions by sources of the project activity (referring to paragraph 53(a)):

Year	$MM_{GAS}(tCH4)$
2008 H1	774
Total	774

Table 7: Data to be collected in the project scenario

Year	$MM_{CHP}(tCH4)$
2008 H1	13,884
Total	13,884

 Table 8: Data to be collected in the project scenario

For Methane analysis data refer please to Annex 1 document.

B.2.4. Data concerning GHG emissions by sources of the baseline (referring to paragraph 53(b)):

Year	$GEN_{CHP}(MWh)$	El _{Cons} (MWh)	$HEAT_{cons, vost, y}(GJ)$	$VFUEL_y(m3)$
2008 H1	64,810	102,199	66,909	1,079,419
Total	64,810	102,199	66,909	1,079,419

Table 9: Data collected in the baseline scenario

B.2.5. Data concerning leakage (referring to paragraph 53(c)):

Not Applicable.

B.2.6. Data concerning environmental impacts (referring to paragraph 53(d)):

Not Applicable.

B.3. Data processing and archiving (incl. software used):

All data will be archived electronic and paper.

B.4. Special event log:

The two explosions took place at October-November 2007 due to high depth of coal at the coal mine and unknown geological process. The two horizon-faces were closed and flooded. This caused decreasing of CMM extraction and electricity generation in November-December.

SECTION C. Quality assurance and quality control measures²⁴

C.1. Documented procedures and management plan:

C.1.1. Roles and responsibilities:

The general project management is implemented by the Deputy General Director of the Zasyadko Coal Mine through supervising and coordinating activities of his subordinates, such as deputy director on surface degasification, chief power engineer, chief heating engineer, and heads of safety engineering departments. Onsite day-to-day management is implemented by the manager of cogeneration station who directs two shift operators responsible for cogeneration modules and gas treatment plant performance. An on-duty electrician works at the plant. During the daytime a group of mechanics who are responsible for preventive measures and maintenance of all technological equipment, measuring instruments as well as of automation tools and telemechanics are present on-site. On-line information transmitted directly to the head of the shift into the Coal Mine Central Dispatching Office. The cogeneration plant is in 24 hours operation. Three shifts by eight hours have been introduced.

At the main objects the responsibilities are as follows:

- VPS operator controls data before VPS and after VPS (at the gas treatment plant) including CMM and natural gas flow parameters;
- Two cogeneration plant operators control data at the inlets of cogeneration modules (at the gas treatment plant), work process parameters, and heat and power output;
- Substation operator controls data on electric power amounts dispatched to and supplied from the grid as well as in-house electricity consumption.

All the information will be channelled to the workstation of the Coal Mine central dispatching office and online monitored by the head of the shift that will be responsible for calculation of the CO_2 equivalent emission reductions. Such calculations are made on a monthly basis. The general supervision of the monitoring system is executed by Zasyadko Coal Mine administration under the existing control and reporting system.

C.1.2. Trainings:

The basic equipment for CHP plant, being the cogeneration units, was supplied by the GE Jenbacher Company (Austria). As stipulated in the delivery contract education of staff, that operates those units, were provided in

²⁴ See supporting document SD_2_Monitoring Manual

Austria. Additional training was provided by GE Jenbacher technicians during installation and commissioning works. The employees responsible for the monitoring control also were dully trained during installation of such system.

Extra trainings are to be provided during operation of equipment. Training programs for CHP and VPS staff as well as Emergency training will be submitted as separate document.

C.2. Involvement of Third Parties:

The Ukrainian Centre for Standardization and Metrology is a Third Party involved.

C.3. Internal audits and control measures:

Introduction of a modern computerized control system allows for efficient on-line monitoring and reviewing work process performance at the Zasyadko Central Dispatching office every fifteen minutes. (Especially for fuel and ignition gas consumption, their parameters and electricity and heat generated data can be obtained every 10 seconds if requested). Any considerable deviation of monitored data from given work parameters will be promptly noticed and source of such deviation will be easily identified. In turn this enables the head of shift to efficiently coordinate adjustment actions of his shift subordinates including on-duty technical staff that will improve work process and eliminate such deviations.

C.4. Troubleshooting procedures²⁵:

See C .1.2

In case of a break down of CMM supply system (either of whole system or separate feeding pipe) methane-air mixture will be urgently released into the atmosphere through the emergency gas vent stack. The shut-off valves will automatically close CMM supply pipes, natural gas will be fed into gas treatment plant and consequently into the inlets of engines and into pre-chambers. As the primary meters are *after* the venting stack, only combusted CMM will be accounted for.

²⁵ There is all necessary metering equipment of the same type at the CHP facility to replace main equipment for short period in case of break down or calibration – electrical and heat meters, CMM metering equipment, pressure, temperature sensors, e.t. c. Being connected or installed these devices are able to channel all data to computer system of monitoring and control. This equipment is also calibrated by the Ukrainian Centre for Standardization and Metrology in certain time.

SECTION D. Calculation of GHG emission reductions (referring to Decision 17/CP.7, Annex H, paragraph 53 (f) and 59)

D.3.1. Project emissions:

		2008 H1
Project emissions	[tCO2e/yr]	
Total 2008 H1	[tCO2e]	41,787

Table 10: Project emissions

D.3.2. Baseline emissions:

		2008 H1
Baseline emissions	[tCO2e/yr]	
Total 2008 H1	[tCO2e]	372,880

Table 11: Baseline emissions

D.3.3. Leakage:

Not Applicable

D.3.4. Summary of the emissions reductions during the monitoring period:

		2008 H1
Emission reductions	[tCO2e/yr]	
Total 2008 H1	[tCO2e]	331,093

Table 12: Emission Reductions