

Revised Monitoring Plan

Monitoring period
09/08/2008 to 03/11/2009

Version 1c
25 May 2010

CONTENTS

D. Revised Monitoring plan

Annexes

Annex 1: Data Sources

Annex 2: Monitoring plan

SECTION D. Monitoring plan**D.1. Description of monitoring plan chosen:**

A monitoring plan based on the “Approved consolidated baseline methodology ACM0008”, Version 03, Sectoral Scope: 8 and 10, EB28 is applied to the project [ACM0008]. The differences to the ACM0008 are listed below.

The calculation of the emission reductions is not calculated on a yearly basis, but for an individual period. The monitoring period lasts from 09/08/2008 to 03/11/2009.

Flow data and flare efficiency as well as the methane amount destroyed by flaring MD_{Fl} are calculated in 15 min. intervals in Excel sheets. The main emissions variables for project emissions, baseline emissions and emissions reductions are calculated on a monthly basis. Yearly sums and a total sum for the monitoring are calculated.

As both flares have been equipped with compressors for additional pressure generation, additional power has been consumed by the project. Formulae from the ACM0008 for the calculation of consumed power and additional project emissions have been included in the revised Monitoring Plan. These formulae were missing in the original monitoring plan.

The amount of the energy used by the compressors installed in the flares $CONS_{ELEC, Flare\ 3}$ and $CONS_{ELEC, Flare\ 4}$ has not been measured in the regarded monitoring period, but calculated using the operation hours of a flare unit and the electric load.

The formula for the calculation of project emissions from uncombusted methane has been updated. Formulae from the methodological “Tool to determine project emissions from flaring gases containing methane”, EB 28 Meeting report, Annex 13, has been adopted for the determination of the project emissions from flaring. The calculation of project emissions from uncombusted methane from flaring is now more accurate.

In difference to the flaring tool a combustion efficiency of 99.5%, according to the IPCC guidelines [IPCC] (see also ACM0008 Version 1 and Version 2), has been taken into account for combustion temperatures above 850°C; see justification in Annex 3. The default value of 90% is used in the range from 500°C to 850°C and the default value of 90% below 500°C.

Applicability requirements for the monitoring plan of the ACM0008 methodology are identical to respective requirements of the baseline setting. For a detailed overview of the ACM0008 applicability please refer to section B.I of the PDD.

General remarks to the Revised Monitoring Plan:

- This document is the first updated Monitoring Plan, made during the first verification

- Generally all project variables determined on a yearly basis in the original version of the monitoring plan have been transferred to individual periods
- this document will be updated during the second verification

D.1.1. Option 1 – Monitoring of the emissions in the project scenario and the baseline scenario:

The ID Numbers used in the tables below refer to the ID numbers as used in ACM0008; missing ID numbers refer to parameters, which are listed in the monitoring plan of the ACM0008, and which are not applicable to the project.

D.1.1.1. Data to be collected in order to monitor emissions from the project, and how these data will be archived:								
ID number (Please use numbers to ease cross-referencing to D.2.)	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/ paper)	Comment
P1 PE	Project emissions	monitored data	t CO _{2eq}	c	monitoring period	100%	electronic	calculated using formulae in Section D.1.1.2, see below
P2 PE _{ME}	Project emissions from energy use to capture and use methane	monitored data	t CO _{2eq}	c	monitoring period	100%	electronic	calculated using formulae in Section D.1.1.2, see below
P3 PE _{MD}	Project emissions from methane destroyed	monitored data	t CO _{2eq}	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.2, see below

P4 PE _{UM}	Project emissions from uncombusted methane	monitored data	tCO _{2eq}	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.2, see below
P5 CONS _{ELEC,PJ}	Additional electricity consumption by project	electricity meter	MWh	m	monitoring period	100%	Electronic and paper	cumulative value
P8 CEF _{ELEC,PJ}	Carbon emission factor of CONS _{ELEC,PJ}	data calculated and published by SenterNovem [SenterNovem]	tCO _{2eq}	e, c	ex ante, annually	main power generation plants	paper	Should a new officially approved standardised baseline for Ukraine be adopted, the baseline carbon emission factor will be changed accordingly.
P9 PE _{Flare}	Project emissions from flaring	monitored data	tCO _{2eq}	c	continuous	100%	electronic	calculated using formulae in Section D.1.1.2, see below
P11 MD _{FL}	Methane destroyed by flare	monitored data	tCH ₄	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.2, see below

P12 MM _{FL}	Methane sent to flare	flow meter	tCH ₄	m	15 min. cycle	100%	electronic	Flow meters will record gas volumes, pressure and temperature. Density of methane under normal conditions of temperature and pressure is 0.717 kg/m ³ [DIN ISO 6976 (1995)] (1013 mbar, 273.15°K)
P13 Eff _{FL} or <input type="checkbox"/> _{Flare}	Flare/combustion efficiency, determined by the flame temperature	monitored data	% / °C	m	15 min. cycle	100%	electronic	The efficiency is set to 99.5% for a flame temperature above 850°C, 90% in the range from 500°C to 850°C and 0% below 500°C See Annex 3 for justification. The flame temperature of the flare is monitored continuously.

P14 MD _{ELEC}	Methane destroyed by power generation	monitored data	t CH ₄	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.2, see below
P15 MM _{ELEC}	Methane sent to power plant	flow meter	t CH ₄	m	15 min. cycle	100%	electronic	Flow meters will record gas volumes, pressure and temperature. Density of methane under normal conditions of temperature and pressure is 0.717 kg/m ³ DIN ISO 6976 (1995) (1013 mbar, 273.15°K)
P16 Eff _{ELEC}	Efficiency of methane destruction / oxidation in power plant	IPCC	-	e	ex ante	100%	paper	set at 99.5% (IPCC)
P17 MD _{HEAT}	Methane destroyed by heat generation	monitored data	t CH ₄	c	monthly	100%	electronic	Hand readings from the internal counter of the units

P18 MM _{HEAT}	Methane sent to boiler	flow meter	t CH ₄	m	15 min. cycle	100%	electronic	Flow meters will record gas volumes, pressure and temperature. Density of methane under normal conditions of temperature and pressure is 0.717 kg/m ³ DIN ISO 6976 (1995) (1013 mbar, 273.15°K)
P19 Eff _{HEAT}	Efficiency of methane destruction / oxidation in heat plant	IPCC	-	e	ex ante	100%	paper	set at 99.5% (IPCC)
P23 CEF _{CH4}	Carbon emission factor for combusted methane	IPCC	-	e	ex ante	100%	paper	set at 2.75 t CO _{2eq} /t CH ₄ (IPCC)
P24 CEF _{NMHC}	Carbon emission factor for combusted non methane hydrocarbons (various)	lab analysis	-	c	annually	main components	paper	Calculated if applicable, based on the lab analysis. (See P26)
P25 PC _{CH4}	Concentration of methane in extracted gas	IR measurement	%	m	15 min. cycle	100%	electronic	measurement

P26 PC_{NMHC}	NMHC concentration in coal mine gas	lab analysis	%	m	annually	main components	paper	Used to check if more than 1% of emissions and to calculate r
P27 r	Relative proportion of NMHC compared to methane	lab analysis	%	c	annually	100%	paper	Calculated if applicable, based on the lab analysis.
P28 GWP_{CH4}	Global warming potential of methane	IPCC	-	e	ex ante	100%	paper	set at 21 (IPCC)
$CONS_{ELEC,Flare i}$	additional electric energy used by the compressors and other equipment installed in the flare i	monitored data	[MWh]	c	monitoring period	100%	electronic	calculated using formula (2c)
$h_{i,M}$	operation hours of compressor from flare i (operation)	counter	[h]	m	monitoring period	100%	paper	Hand readings from the internal digital counters of the flare units
$h_{i, total}$	operation hours of flare i (operation+standby)	counter	[h]	m	monitoring period	100%	paper	Hand readings from the internal digital counters of the flare units
P_M	motor capacity	Manufacturer data	[MW]	e	ex ante	100%	paper	set to 45 kW (0.045 MW) for each compressors

P_{total}	total capacity of the flare unit	manufacturer data	[MW]	e	ex ante	100%	paper	60 kW (0.060 mW) for each flare
Eff_M	effective load of electric motor	[KD]	[%]	e	ex ante	100%	paper	set to 75% for both flares [KD]
Eff_{SB}	effective load of the flare unit during standby	[KD]	[%]	e	ex ante	100%	paper	set to 45% for both flares [KD]
T_{flare}	Flame temperature of the flare	temperature meter	[°C]	m	15 min. cycle	100%	electronic	

D.1.1.2. Description of formulae used to estimate project emissions (for each gas, source etc.; emissions in units of CO₂ equivalent):

Project emissions are defined by the following equation

$$PE = PE_{ME} + PE_{MD} + PE_{UM} \quad (1)$$

Project emissions from energy use to capture and use methane (PE_{ME}), is obtained by the equation:

$$PE_{ME} = CONS_{ELEC,PJ} \times CEF_{ELEC,PJ} \quad (2)$$

Where:

- PE_{ME} Project emissions from energy use to capture and use methane (tCO₂e)
- $CONS_{ELEC,PJ}$ Additional electricity consumption for capture and use of methane, if any (MWh)
- CEF_{ELEC} Carbon emissions factor of electricity used by coal mine (tCO₂e/MWh)

All utilisation units are supplied with CMM from the CMM suction system of the coal mine. The CMM pressure provided by the suction system is not sufficient for the operation of all utilisation units and further compression is needed.

The additional energy consumption should be measured with power meters. In the case multiple meter are used, $CONS_{ELEC,PJ}$ represents the sum value:

$$CONS_{ELEC,PJ} = \sum_{i=1}^n CONS_{ELEC,i} \quad (2a)$$

where:

$CONS_{ELEC,PJ}$ Additional electricity consumption for capture and use of methane, if any (MWh)

$CONS_{ELEC,i}$ Additional electricity consumption by unit i (MWh)

n total of units

In the case of the first monitoring period formula (2a) resolves to:

$$CONS_{ELEC} = CONS_{ELEC, Flare 3} + CONS_{ELEC, Flare 4} \quad (2b)$$

In the case of the first monitoring period the energy used by the compressors installed in the flares $CONS_{ELEC}$ has not been measured by power meters but calculated using formula (2c), see justification in Annex 3.2 of this document:

$$CONS_{ELEC, Flare i} = (Eff_M * P_M * h_{i,M}) + ((h_{i,total} - h_{i,M}) * (P_{total} - P_M) * Eff_{SB}) \quad (2c)$$

with

$CONS_{ELEC, Flare i}$ additional electric energy used by the compressors and other equipment installed in the flares [MWh]

$h_{i,M}$ operation hours of compressor from flare i [h] (operation)

$h_{i, total}$ operation hours of flare i [h] (operation+standby)

P_M motor capacity [MW], set to 0.045 MW for each compressors

P_{total} total capacity of the flare unit [MW], set to 0.060 MW for each flare

Eff_M effective load of electric motor [%], set to 75% for both flares

Eff_{SB} effective load of the flare unit during standby [%], set to 45% for both flares

Project emissions from methane destroyed (PE_{MD}) can be obtained by the equation:

$$PE_{MD} = (MD_{FL} + MD_{ELEC} + MD_{HEAT}) \times (CEF_{CH4} + r \times CEF_{NMHC}) \quad (3)$$

with:

$$r = PC_{NMHC} / PC_{CH4} \quad (4)$$

where:

PE_{MD}	Project emissions from CMM destroyed (t CO ₂ eq)
MD_{FL}	Methane destroyed through flaring (t CH ₄)
MD_{ELEC}	Methane destroyed through power generation
MD_{HEAT}	Methane destroyed through heat generation
CEF_{CH_4}	Carbon emission factor for combusted methane (2.75 t CO ₂ eq/t CH ₄)
CEF_{NMHC}	Carbon emission factor for combusted non methane hydrocarbons (various) (t CO ₂ eq/tNMHC)
r	Relative proportion of NMHC compared to methane
PC_{CH_4}	Concentration (in mass) of methane in extracted gas (%)
PC_{NMHC}	NMHC concentration (in mass) in extracted gas (%)

The formula for the methane destroyed through flaring has been adopted from the «Methodological “Tool to determine project emissions from flaring gases containing methane”» [AM_Tool]):

$$MD_{FL} = \sum_{i=1}^n MM_{FL,i} \times \eta_{flare,i} \quad (5)$$

where:

MD_{FL}	Methane destroyed through flaring (t CH ₄)
$MM_{FL,i}$	Methane sent to flaring in the interval i (t CH ₄)
$\eta_{flare,i}$	Efficiency of methane destruction/oxidation in flare in the interval i, see below
n	number of samples (intervals) in the regarded period

The interval is set to 15 min during the monitoring period, which is more accurate than the 1 h intervals from the «Methodological “Tool to determine project emissions from flaring gases containing methane”» [AM_Tool]).

For $\eta_{flare,i}$ three different values are taken, depending on the current combustion temperature $T_{Flame,i}$ of the flare in the interval i:

$T_{Flame,i}$	$\eta_{flare,i}$
> 850°C	99.5%
500-850°C	90.0%

< 500°C	0.0%
---------	------

where:

$T_{\text{Flame},i}$ Flame temperature of the flare in the regarded interval i (°C)
 $\eta_{\text{flare},i}$ flare efficiency in the interval i , see Annex 3.1 of this document for justification

$$MD_{\text{ELEC}} = MM_{\text{ELEC}} \times \text{Eff}_{\text{ELEC}} \quad (7)$$

where:

MD_{ELEC} Methane destroyed through power generation (t CH₄)
 MM_{ELEC} Methane measured sent to power plant (t CH₄)
 Eff_{ELEC} Efficiency of methane destruction/oxidation in power plant (take as 99.5% from IPCC)

$$MD_{\text{HEAT}} = MM_{\text{HEAT}} \times \text{Eff}_{\text{HEAT}} \quad (8)$$

where:

MD_{HEAT} Methane destroyed through heat generation (t CH₄)
 MM_{HEAT} Methane measured sent to heat plant (t CH₄)
 Eff_{HEAT} Efficiency of methane destruction/oxidation in heat plant (take as 99.5% from IPCC)

Uncombusted methane from flaring and end uses (PE_{UM}) can be obtained through the equation:

$$PE_{\text{UM}} = \text{GWP}_{\text{CH}_4} \times [MM_{\text{ELEC}} \times (1 - \text{Eff}_{\text{ELEC}}) + MM_{\text{HEAT}} \times (1 - \text{Eff}_{\text{HEAT}})] + PE_{\text{Flare}} \quad (9)$$

where

PE_{UM} Project emissions from un-combusted methane (tCO₂e)
 GWP_{CH_4} Global warming potential of methane (21 tCO₂e/tCH₄)
 MM_{ELEC} Methane measured sent to power generation (tCH₄)
 MM_{HEAT} Methane measured sent to heat generation (tCH₄)
 Eff_{ELEC} Efficiency of methane destruction in power plant (%)
 Eff_{HEAT} Efficiency of methane destruction in heat plant (%)

PE_{flare} Project emissions from flaring (tCO₂e)

The project emissions from flaring are calculated using the equation:

$$PE_{flare} = (MM_{FL} - MD_{FL}) * GWP_{CH_4} \quad (9a)$$

where:

PE_{flare} Project emissions from flaring in the regarded period (t CO₂eq)

MD_{FL} Methane destroyed through flaring (t CH₄)

MM_{FL} Methane measured sent to flaring (t CH₄)

GWP_{CH_4} Global warming potential of methane (21 tCO₂eq/tCH₄)

D.1.1.3. Relevant data necessary for determining the <u>baseline</u> of anthropogenic emissions of greenhouse gases by sources within the project boundary, and how such data will be collected and archived:								
ID number (Please use numbers to ease cross-referencing to D.2.)	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/ paper)	Comment
B1 BE	Baseline emissions	monitored data	t CO ₂ eq	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.4, see below
B3 BE _{MR}	Baseline emissions from release of methane into the atmosphere that is avoided by the project activity	monitored data	t CO ₂ eq	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.4, see below

B4 BE _{Use}	Baseline emissions from the production of power, heat or supply to gas grid replaced by the project activity	monitored data	t CO _{2eq}	c	monthly	100%	electronic	calculated using formulae in Section D.1.1.4, see below
B14 CMM _{PJ}	CMM captured in the project activity	flow meters	t CH ₄	m	15 min. cycle	100%	electronic	cumulative value
B18 GWP _{CH4}	Global warming potential of methane	IPCC	t CO _{2eq} / t CH ₄	e	ex ante	100%	paper	21 t CO _{2eq} / t CH ₄
B19 CEF _{CH4}	Carbon emission factor for combusted methane	IPCC	t CO _{2eq} / t CH ₄	e	ex ante	100%	paper	44/16 = 2.75 tCO _{2e} /tCH ₄
B46 GEN	Electricity generation by project	electricity meter	MWh	m	monthly	100%	electronic and paper	cumulative value
B47 HEAT	Heat generation by project	heat meter	MWh	m	monthly	100%	electronic and paper	cumulative value

B49 EF _{elec}	CO ₂ emission factor of the grid	data calculated and published by SenterNovem [SenterNovem]	t CO ₂ / MWh	c	ex ante, annually	main power generation plants	paper	Should a new officially approved standardised baseline for Ukraine be adopted, the baseline carbon emission factor will be changed accordingly.
B55 EF _{CO₂,Coal}	CO ₂ emission factor of fuel used for captive power or heat	IPCC	tCO ₂ /TJ	e	ex ante	100%	paper	Set to 0.3406 tCO ₂ /MWh Using the value for “Other Bituminous Coal” of 94,600 kg CO ₂ /TJ (IPCC defaults).
B57 Eff _{heat}	Energy efficiency of heat plant	manufacturer data	%	e	ex ante	100%	paper	Set to 91% according to boiler passport

D.1.1.4. Description of formulae used to estimate baseline emissions (for each gas, source etc.; emissions in units of CO₂ equivalent):

Baseline emissions are given by the following equation:

$$BE = BE_{MR} + BE_{Use} \quad (10)$$

where

BE Baseline emissions of the project (tCO₂e)

BE_{MR} Baseline emissions from the release of methane into the atmosphere (tCO₂e)

BE_{Use} Baseline emissions from the production of power or heat replaced by the project activity (tCO₂e)

The baseline emissions from release of methane into the atmosphere (BE_{MR}) are obtained by the following equation:

$$BE_{MR} = CMM_{PJ} \times GWP_{CH_4} \quad (14)$$

where

BE_{MR} Baseline emissions from the release of methane into the atmosphere (tCO_2e)

CMM_{PJ} CMM captured in the project activity (tCH_4)

GWP_{CH_4} Global warming potential of methane ($21 tCO_2e/tCH_4$)

$$CMM_{PJ} = \sum_{i=1}^n MM_i \quad (14a)$$

where:

CMM_{PJ} CMM captured in the project activity (tCH_4)

MM_i Methane amount sent to unit i (tCH_4)

n total number of units

The total emissions reductions from displacement of power/heat generation are given by the following equation:

$$BE_{Use} = GEN * EF_{ELEC} + (HEAT / Eff_{HEAT}) * EF_{HEAT} \quad (24)$$

where

BE_{Use} Total baseline emissions from the production of power or heat replaced by the project activity (tCO_2e)

GEN Electricity generated by project activity (MWh)

EF_{ELEC} Emissions factor of electricity (grid, captive or a combination) replaced by the project (tCO_2/MWh)

$HEAT$ Heat generation by project activity (MWh)

EF_{HEAT} Emissions factor for heat production replaced by project activity (tCO_2/MWh)

Eff_{HEAT} Efficiency of the former heat generation unit, which is displaced by project activity (%)

D. 1.2. Option 2 – Direct monitoring of emission reductions from the project (values should be consistent with those in section E.):

D.1.2.1. Data to be collected in order to monitor emission reductions from the project, and how these data will be archived:

ID number (Please use numbers to ease cross-referencing to D.2.)	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/ paper)	Comment

not applicable

D.1.2.2. Description of formulae used to calculate emission reductions from the project (for each gas, source etc.; emissions/emission reductions in units of CO₂ equivalent):

not applicable

D.1.3. Treatment of leakage in the monitoring plan:

In accordance with ACM0008 the following leakages should be considered:

1. Displacement of baseline thermal energy uses
2. CBM drainage from outside the de-stressed zone
3. Impact of the JI project on coal production
4. Impact of the JI project on coal prices

There is no leakage in the project as:

1. There is no CMM being used for thermal demand under the baseline scenario. Hence there is no leakage for displacement of baseline thermal energy uses;
2. There is no CBM involved hence no leakage occurs from CDM drainage from outside the de-stressed zone
3. There is no impact of the JI project on coal production as degasification activities are independent from the JI project
4. The impact of the JI project on coal prices is difficult to assess. The JI project as such does not influence coal production so it is unlikely that the JI project will impact coal prices

D.1.3.1. If applicable, please describe the data and information that will be collected in order to monitor leakage effects of the project:

ID number (Please use numbers to ease cross-referencing to D.2.)	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/ paper)	Comment

Not applicable. There are no leakages and no indirect emissions

D.1.3.2. Description of formulae used to estimate leakage (for each gas, source etc.; emissions in units of CO₂ equivalent):

Not applicable. There are no leakages and no indirect emissions.

D.1.4. Description of formulae used to estimate emission reductions for the project (for each gas, source etc.; emissions/emission reductions in units of CO₂ equivalent):

The greenhouse gas emission reduction gained by the project over a period is the difference between the total baseline emissions over the period and the total project emissions over the period. This is given by the equation:

$$ER = BE - PE \quad (18)$$

where:

ER Emissions reductions of the project activity (t CO_{2eq})

BE Baseline emissions (t CO_{2eq})

PE Project emissions (t CO_{2eq})

D.1.5. Where applicable, in accordance with procedures as required by the host Party, information on the collection and archiving of information on the environmental impacts of the project:

To maintain a consistent and reliable performance of the automatic controlling and monitoring system an adequate quality control and assurance procedures have been implemented that is regulated by the calibration standards and quality norms of the national legislation. Under these requirements of quality control system, regular maintenance and testing regime to ensure accuracy of flow meters, gas-analysers, electricity and heat measuring instruments is provided. All

measuring instruments are calibrated periodically. The calibration protocols are archived and proved by an independent entity on an annual basis. A consistency check for all measurement data and the calculation of the emission reductions is carried out and reported monthly.

Furthermore emissions measurement for dust, CO, NO_x etc. for all combustion units will be carried out and archived as required by the legal requirements of the Ukrainian Authorities

D.2. Quality control (QC) and quality assurance (QA) procedures undertaken for data monitored:		
Data (Indicate table and ID number)	Uncertainty level of data (high/medium/low)	Explain QA/QC procedures planned for these data, or why such procedures are not necessary.
P5 <i>Power consumption</i>	low	The calibration interval is 1 year. Calibration procedures for power meters are implemented in compliance with the calibration methodology developed by the Ukrainian Centre for Standardization and Metrology.
P12 P15 P18 B14 <i>Methane amount</i>	medium	<p>The flow meters consist of an orifice and a pressure difference meter. The measured volumetric flow rates are designed for a standardised gas composition and have to be corrected by the actual gas condition.</p> <p>The measured flow rates is continuously converted from operation condition to standard state condition by use of the ideal gas law and the actually gas temperature and pressure.</p> <p>The meters have been initially controlled during the final inspection by the manufacturer and are checked regularly according to the manufacturer's instructions.</p> <p>The indications of the measurement instruments are controlled during the regular inspections while the operation time, and a gauge which is obviously out of order should be substituted.</p> <p>The calibration interval is 1 year. Calibration procedures for all meters are implemented in compliance with the calibration methodology developed by the Ukrainian Centre for Standardization and Metrology.</p>

<p>P13 <i>Combustion efficiency off the flare</i></p>	<p>low</p>	<p>The chosen flares are designed to fulfil the German regulations for flaring of landfill gas. In these regulations a minimum efficiency of 99.9 % is required. This efficiency is proved by a continuous measurement of the combustion temperature, which has to be above 850°C. Additionally the emissions of the flare have to be verified every three years by a measurement. According to the German Regulations a measurement of the emissions, especially the total C amount in the flue gas, which indicates the combustion efficiency of the flare, should be carried out every three years by an approved expert, laboratory, institute etc.</p> <p>The temperature meter has been initially controlled during the final inspection by the manufacturer and is checked regularly according to the manufacturer's instructions. The gauge has usually hardly any fluctuations and no recalibration is needed. The gauge should be controlled during the regular inspections while the operation time and a gauge which is obviously out of order should be substituted. The temperature meter has to be changed yearly according to the methodological "Tool to determine project emissions from flaring gases containing methane"</p>
<p>P25 <i>Methane concentration</i></p>	<p>medium</p>	<p>The indication of the CH₄ gas analyser is drifting and has to be recalibrated periodically. The recalibration is carried out regularly according to the manufacturer's instructions.</p>
<p>P26 <i>NMHC Concentration</i></p>	<p>low</p>	<p>The determination is provided by an accredited laboratory. (MAKNII Institute)</p>
<p>B46 <i>Power production</i></p>	<p>low</p>	<p>The calibration interval of the power meters is 1 years. Calibration procedures for power meters are implemented in compliance with the calibration methodology developed by the Ukrainian Centre for Standardization and Metrology.</p>
<p>B47 <i>Heat production</i></p>	<p>low</p>	<p>The indication of the measurement instrument should be initially controlled during the final inspection by the manufacturer and will be checked regularly according to the manufacturer's instructions. The gauge will be recalibrated by the manufacturer according to his own recalibration intervals.</p> <p>The indication of the measurement instrument should be controlled during the regular inspections while the operation time and a gauge which is obviously out of order should be substituted.</p>

Irrespective the monitoring plan all installed aggregates and gauges are controlled during the regular inspections, at least weakly, to assure a proper operation of the facility. Beside the monitored values any other values which are needed for the supervision of the plant should be logged.

Any gauge or apparatus which is detected as obviously out of order is immediately substituted.

D.3. Please describe the operational and management structure that the project operator will apply in implementing the monitoring plan:

The plants installed in the project are designed to run fully automatic, so that the operating personnel have only to supervise the correct operation of the plant and the plausibility of the collected and monitored data. In case of disturbances and emergency the plant is shut down automatically and no unintended emissions are caused. The CMM supply is locked by quick acting valves. Fire arresters prevent from backfiring into the CMM pipe for safety of the personnel and equipment. During the downtime of the plant the unused CMM is vented by the coal mine as it would be without the project activity.

In case of emergency an alarm message is sent to a permanently manned place in the control room. The operating personnel, who are on duty, check the plant status and decide on further procedures as clearing the fault, eliminating danger and restarting the plant, sending a service team, informing the project manager, a fire brigade, etc.

Every emergency case is journalised.

The collected data are stored electronically by a data logger and on paper in journals by the coal mine personnel. The data are read out hourly from the data logger and stored and archived in an internet-based data base. The data base is provided with an internet front end, by which all stored data can be visualised, controlled and analysed. Eco-Alliance, the administrator of the data base is responsible for the proper work of the data base, routine backups and save storage.

Eco-Alliance is responsible for correctness of the logged data and the administration of the data base. Eco-Alliance regularly verifies the electronically recorded data with the handwritten data and checks the stored data for plausibility, errors, deviations and non-conformity. All inconsistencies are discussed with the service and the operation teams, at which the operational and monitoring experience is gained, the plant operation is optimised, and a more accurate monitoring results.

All stored data are kept during the whole operation period of the plant and furthermore for at least 5 years.

The plant manager is responsible for the preparation of the standardised weekly report. He is also in charge for the preparation of the summarised monthly and yearly reports, which are revised by the project manager.

The plant manager is keeping an operational journal which includes the following information:

- compilation and description of all data recorded, required for the calculation of the emission reductions
- description of all records to be kept during the regular inspections, including all corrective action undertaken
- manually logged data collected during the regular inspections
- particular events
- all calibrations carried out, incl. all calibration protocols

The visualisation of the data via internet provides a prompt control of the project operation by the project manager. All data are continuously checked for consistency, completeness and integrity by Eco-Alliance. A detailed plausibility check should be carried out at least monthly.

Based on the procedure described above a detailed annual report should be prepared by Eco-Alliance and confirmed by the verifier.

The responsible personnel of Eco-Alliance has been trained on the handling with CMM-utilisation units and the applied monitoring systems, during an eight week long practical course in Germany in the autumn of 2005. In this course which has been carried out by A-TEC Anlagentechnik GmbH, a Joint-Venture participant of Eco-Alliance, also the basic principles of emissions trading and the background of the monitoring has been explained. A-TEC Anlagentechnik GmbH is already running several CMM utilisation plants and monitoring systems in Germany.

These trained personnel is the basis of a team of engineers, which should establish a specialised service team in the Ukraine and instruct further operating and monitoring personnel, as well for this project. Actually there is no final training procedure established. The project management is carried out by JSC Coal Mine Komsomolets Donbassa. The operation of the plants is done by Eco-Alliance together with the operational personnel of the coal mine. The service and maintenance of the boilers should be done by the operational personnel of the coal mine. The service and maintenance of the cogeneration units should be done by the service personnel of the manufacturer. The service of the flare has been performed and the personnel of the Ukrainian corporate group Ukrrosmetall JSC, Sumy, Ukraine until Summer 2009 and has been then handed over to Eco-Alliance. The monitoring is carried out by the project manager of Komsomolets Donbassa together with Eco-Alliance and Carbon-TF B.V.

The experience of the Ukrainian personnel is gained by training on the job. Detailed work instruction should be worked out and wrote down.




Figure D-1 - Project management structure

D.4. Name of person(s)/entity(ies) establishing the monitoring plan:

Date of completion of the monitoring plan: 2010-04-21

Name of person / entity setting the monitoring plan: Adam Hadulla, Carbon-TF B.V.

Annex 1Data Sources

- [IPCC] Revised 1996 IPCC Guidelines for National Greenhouse Gas Inventories, Reference Manual (Volume 3), Chapter Energy, 1.4.1 Unoxidized Carbon, Adjustments For Carbon Unoxidised, Page 1.32, and Table 1-6, pg. 1.29
<http://www.ipcc-nggip.iges.or.jp/public/gl/invs6a.htm>
- [IPCC-2006] 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Volume 2 (Energy) Chapter 1.4 Data collection issues, 1.4.2 Emission factors, Table 1-4, pg. 1.24
- [TA-Luft] TA-Luft 2002, Technical Instructions on Air Quality Control Act, Pages 170/172
- [AM_Tool] Methodological "Tool to determine project emissions from flaring gases containing methane", EB 28, Meeting report, Annex 13
- [KD] Coal Mine Komsomolets Donbassa

Annex 2

MONITORING PLAN

A3.1 Justification of the combustion efficiency of the chosen flare

The chosen flare is designed to fulfill the German regulations for flaring of landfill gas or other gases (CMM). In these regulations a minimum efficiency of 99.9 % is required [TA-Luft]. This efficiency is proved by a continuous measurement of the combustion temperature, which has to be above 1,000°C for landfill gas or above 850°C for other gases (CMM), whereas a minimum retention time of at least 0.3 s is required [TA-Luft]. The 2006 IPCC guidelines [IPCC-2006] specify a combustion efficiency of 100% for gas, while the 1996 IPCC guidelines [IPCC] specify a value of 99.5%. The conservative value of 99.5% from the 1996 IPCC guidelines has been taken into account as flaring efficiency above 850°C.

According to ACM0008 the methodological “Tool to determine project emissions from flaring gases containing methane”, EB 28 Meeting report, Annex 13, has been taken for the determination of the project emissions from flaring. In difference to the flaring tool a combustion efficiency of 99.5%, according to the 1996 IPCC guidelines [IPCC], has been taken into account for combustion temperatures above 850°C. The default value of 90% is used in the range from 500°C to 850°C and the default value of 0% below 500°C.

T_{Flame}	η_{flare}	Source
> 850°C	99.5%	[IPCC]
500-850°C	90.0%	[AM_Tool]
< 500°C	0.0%	[AM_Tool]

where:

T_{Flame} Flame temperature of the flare (°C)

η_{flare} flare efficiency

A3.1.1 German regulations

The chosen flare is designed to fulfill the German regulations for flaring of landfill gas or other gases (CMM). In these regulations a minimum efficiency of 99.9 % is required [TA-Luft]. This efficiency is proved by a continuous measurement of the combustion temperature, which has to be above 1,000°C for landfill gas or above 850°C for other gases (CMM), whereas a minimum retention time of at least 0.3 s is required [TA-Luft]. Additionally the emissions of the flare have to be verified every three years by a measurement.

In case of flaring of landfill gas the German Authorities started with a required combustion temperature of 1,200°C. The temperature has been dropped to 1,000°C after first good experience in flaring of landfill gas has been made. This minimum temperature of 1,000°C is claimed for landfill gas or gas from waste utilisation plants only; in case of other gases e.g. CMM a temperature of 850°C is sufficient (there are no polycyclic aromatic hydrocarbons contained in CMM).

A combustion temperature of more than 850°C assures the complete conversion of hydro carbons contained in the fuel gas into carbon dioxide with minimum proportion of carbon monoxide and marginal, negligible fraction of other components containing carbon, so that an efficiency of minimum

99.9 % is reached. This is state of the art and has been proven in numerous combustion plants in Germany and throughout the world.

There are no legal obligatory regulations about the monitoring of flares in Germany. According to the German [TA-Luft], these regulations have to be examined in every individual case by the Authorising Authority. Normally a periodical emissions measurement of the main components CO, NO_x and total carbon, which indicates the combustion efficiency of the flare, has to be carried out every three years by an approved expert laboratory, institute etc. At this the value of 20 mg/m³ total carbon in flue gas [TA-Luft] is taken.

A3.1.2 Description of the flare equipment

The flare, which is supposed to be used in this project, is an enclosed flare with a controlled combustion process. The flare is designed for a combustion temperature of more than 850°C and a retention time of about 0.3 sec. The flare is a further development of flares for landfill gas, which has been installed on numerous landfill sites in Germany, France, Belgium, Spain, Portugal, Hungary and Croatia.

Characteristic for landfill gas flares is the continuous operation of the flaring process and the controlled combustion process. The German Regulations require a minimum temperature of 1000°C for landfill gas flares and 850°C for CMM flares. To fulfil this legal requirement a special design of the burning system and an adequate controlling system is applied. The main difference to other flaring systems is the controlled combustion process – the combustion temperature and combustion output are controlled and regulated.

The fuel gas is fed in via a distribution system into the combustion chamber. The main pipe is split up in several distribution pipes fitted with nozzles, which are evenly distributed over the whole cross section of the combustion chamber. The uniform distribution of the fuel gas provides a smooth combustion over the whole cross section of the combustion chamber; generation of possible schlieren of uncombusted gas is minimised in that way.

The combustion air is sucked in into the combustion chamber by the natural draught of the chimney effect of the combustion pipe. The amount of the combustion air is regulated by lamellar lids in the supply air inlet, whereas the lid position is controlled by the temperature in the combustion chamber. In that way the desired value for the combustion temperature in the flare is kept constant.

The retention time of 0.3 s is achieved by the height of the flare pipe. The amount of the fuel gas is regulated by a throttle in the main fuel gas conduit. Hereby the combustion output of the flare is controlled.

The given combustion output is automatically controlled by the control system. The flare has a minimum combustion output, at which the minimum combustion temperature of 850°C can be reached and a maximum combustion output, at which the minimum retention time can be reached. Both limiting values are monitored by the control system. If the combustion temperature falls under the minimal value or the combustion output exceeds the maximal value, the system is automatically shut down.

The flare is provided with an automatic firing device and a flame detector. Both devices are standards from heating boilers section.

All process and operation data, especially the combustion temperature and the CMM amount is monitored, stored and archived.

A3.2 Project emissions from energy use to capture and use methane

The project emissions PE_{ME} are calculated as given in the monitoring plan using formula (2).

The power consumed by the project consisting of two flares is summed using resolved formula (2a):

$$CONS_{ELEC} = CONS_{ELEC, Flare 3} + CONS_{ELEC, Flare 4} \quad (2b)$$

The amount of the energy used by the compressors installed in the flares $CONS_{ELEC, Flare 3}$ and $CONS_{ELEC, Flare 4}$ has not been measured in the regarded monitoring period, but calculated using the operation hours of a flare unit and the electric load.

The operating hours have been manually recorded in operation journals by the personnel of the Coal Mine Komsomolets Donbassa separately for each flare. There are two values: the operation time (flare is running) $h_{i,M}$ and the total operation time (flare is running or standby) $h_{i, total}$. The effective electric load and capacity are different if the flare unit is in operation or standby, because the compressor as the main power consumer is not working in standby periods.

Standby means “ready for operation” but not in operation). There have also been “off” periods, where a flare unit was completely shut off and no power has been consummated. These periods are counted as zero for the operation hours.

The total electric capacity of a flare unit P_{total} is 60 kW, 45 kW of which is part of the compressor motor P_M and 15 kW are part of the remaining electric installation like switchgear, light, fans, and mostly heating systems for the winter period.

The effective load of the electric motor has been set to a value of 75%. The capacity of the electric motor is oversized, because the compressor is designed for pressure gradients up to 500 mbar, while the real operational pressure gradients didn't exceed 100 mbar. So the full motor capacity has not been used and the value of 75% is conservative.

The effective load of the remaining electric installation has been set to a value of 45%. The main part of the capacity belongs to heating systems for the winter period. The capacity has not been used and the value of 45% is conservative.

The energy used by the additional compressors installed in the flares $CONS_{ELEC}$ is calculated as follows:

$$CONS_{ELEC, Flare i} = (Eff_M * P_M * h_{i,M}) + ((h_{i,total} - h_{i,M}) * (P_{total} - P_M) * Eff_{SB}) \quad (2c)$$

with

$CONS_{ELEC, Flare i}$ additional electric energy used by the compressors and other equipment installed in the flares [MWh]

$h_{i,M}$ operation hours of compressor from flare i [h] (operation)

$h_{i, total}$ operation hours of flare i [h] (operation+standby)

P_M motor capacity [kW], set to 45 kW for each compressors

P_{total} total capacity of the flare unit [kW], set to 60 kW for each flare

Eff_M effective load of electric motor [%], set to 75% for both flares

Eff_{SB} effective load of the flare unit during standby [%], set to 45% for both flares